



BOILER SAFETY BUREAU
1101 MAIL SERVICE CENTER
RALEIGH, NC 27699-1101
PHONE (919) 807-2760
FAX (919) 807-2761

Information Bulletin: IB-22.002
Issue Date: 08/02/2022

POLICY NOTIFICATION
<Installation of Temperature & Pressure Relief Devices>

This policy notice is being issued to clarify jurisdictional requirements regarding the installation of temperature and pressure (T&P) relief devices on equipment subject to regulation by the Boiler Safety Bureau. This policy is intended to enhance the requirements found in the Chapter 13, Boiler and Pressure Vessel Administrative Rules.

- A system supplying potable hot water shall have a T&P relief device installed on the boiler, water heater, or hot water storage vessel.
- For HLW stamped, instantaneous type water heaters, a T&P relief device shall be installed on the water heater, or hot water storage vessel when so connected.
- For HLW stamped, instantaneous type water heaters not connected to a hot water storage vessel, a pressure only relief device may be installed in accordance with the manufacturer's installation instructions.

Don Kinney
Chief Inspector