




CHERIE BERRY
COMMISSIONER

THOMAS M. CHAMBERS
BUREAU CHIEF
ELEVATOR AND AMUSEMENT DEVICE BUREAU

DATE: June 29, 2017

MEMORANDUM TO: Elevator Companies

FROM: 
Thomas M. Chambers
Bureau Chief

RE: sprinklers in elevator pits

When sprinklers are installed in elevator pits, the following requirements will apply:

1. The sprinkler head shall be 24" from pit floor
2. 2 initiating devices shall be required; one for phase one recall, and one for shunting power prior to the application of water.
3. The devices shall be installed at 48" from the pit floor and within 24" of the sprinkler head

Thank you for your cooperation.

TC/cb