



CHERIE BERRY
COMMISSIONER

THOMAS M. CHAMBERS
BUREAU CHIEF
ELEVATOR AND AMUSEMENT DEVICE BUREAU

January 26, 2015

MEMORANDUM TO: Elevator Companies

FROM: Thomas M. Chambers
Bureau Chief

Recently we have noted several projects throughout the state where (communication Bundles), similar to what Time Warner cable offers, are not meeting the requirements for elevator communications. Most of what we have observed is the phone equipment not recognizing loss of signal, thereby flashing the indicator as required.

All elevator contractors should confirm compatibility to ensure that the phone equipment being provided will pass testing. It is suggested that a review of 2.27 section of ASME A17.1 be conducted to ensure compliance.

Thank you for your cooperation.

/nfv

Cc: Elevator Inspectors/Supervisors