

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (CABARRUS CS) Beverly Hills Elem **Location #:** 1768208 **Violations:** 1
87 Palaside Dr NE, , Concord, NC 28025-3056, Phone: 704-782-0115
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC291622 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 02/17/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 396. Missing nameplate.
CONDITION: 396. Operation of PRDs NCAC 13-13.0405: PRD nameplate unreadable
REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (CABARRUS CS) Cabarrus County Opportunity School **Location #:** 1792956 **Violations:** 1
120 Marsh Ave NW, , Concord, NC 28025-4889, Phone: 704-793-1736
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC291623 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 02/17/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 394. Valve inoperative.
CONDITION: 394. Operation of PRDs NCAC 13-13.0405: Valve inoperative: PRD was leaking at base and from weephole
REQUIREMENT: 394. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (CABARRUS CS) Carl A Furr Elem **Location #:** 2002374 **Violations:** 1
2725 Clover Rd NW, , Concord, NC 28027-3804, Phone: 704-788-4300
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC364598 - Boiler - Weil-McLain - 2006 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 02/15/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. The installer put the wrong ASME nameplate on.

REQUIREMENT: 363. Undefined Boiler Violations. Customer is to obtain and fill out the needed form and have the manufacturer send the correct AMSE nameplate for attachment.

Location: (COLUMBUS CS) Acme Delco Elem

Location #: 1761932

Violations: 1

16337 Old Lake Rd, , Riegelwood, NC 28456-7077, Phone: 910-655-2957

Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Object: NC252134 - Boiler - Weil-McLain - 1990 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 11/04/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (DPS-C) Alexander CI - 4870

Location #: 1762873

Violations: 7

633 Old Landfill Rd, , Taylorsville, NC 28681-8420, Phone: 828-632-1331

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC349896 - Boiler - Lochinvar - 2002 - Blr Rm Unit 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: Non-temperature and pressure type pressure relief device (PRD) installed on HLW stamped boiler.
REQUIREMENT: 399. Replace the current PRD with an ASME/NB stamped temperature and pressure relieving type PRD having a set pressure of 160 PSI or less and a relieving capacity of 990,000 BTU/Hour or more. This PRD must also be designed to lift and relieve temperature/pressure at 210 degrees Fahrenheit.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC349897 - Boiler - Lochinvar - 2002 - Blr Rm Unit 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: Pressure relief device (PRD) data plate illegible due to apparent manufacturing defect (Data not properly stamped on data plate).
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: Replace the current PRD with an ASME/NB stamped temperature and pressure relieving PRD having a set pressure of 160 PSI or less and a relieving capacity of 1,260,000 BTU/Hour. The replacement PRD must also be designed to lift and relieve temperature/pressure at 210 degrees Fahrenheit.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC349899 - PV - LTC - 2002 - Blr Rm Tank 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 452. Set pressure too high.
CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high: Pressure relief device (PRD) set pressure rating exceeds maximum allowable working pressure rating of hot water.
REQUIREMENT: 452. Replace the current PRD with an ASME/NB stamped temperature and pressure relieving PRD having a set pressure of 125 PSI or less and a relieving capacity of 1,980,000 BTU/Hour or more. This PRD must also be designed to lift and relieve temperature/pressure at 210 degrees Fahrenheit.

ENTERED BY: Judd, Janie

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC349900 - Boiler - Lochinvar - 2002 - Outside Bldg Unit 6 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: Pressure Relief Device (PRD) inlet piping leaking/corroded.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: Replace the PRD inlet plumbing connection in order to correct this condition the replacement inlet piping must be piped full size between the boiler and PRD inlet opening.

Object: NC351303 - PV - Lochinvar - 2002 - Rm P17 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 461. Incorrect pressure relieving device(s) for the application.
CONDITION: 461. Installation of PRDs NCAC 13-13.0405: Incorrect pressure relieving device(s) for the application: Non-temperature and pressure type pressure relief device (PRD) installed on HLW stamped boiler.
REQUIREMENT: 461. Replace the current PRD with an ASME/NB stamped temperature and pressure relieving type PRD having a set pressure of 125 PSI or less and a relieving capacity of 3,600,000 BTU/Hour or more. This PRD must also be designed to lift and relieve temperature/pressure at 210 degrees Fahrenheit.

Object: NC414237 - Boiler - Cleveland Range - 2017 - Kitchen - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 271. Handhole plug leaks.
CONDITION: 271. Boiler Components: Handhole plug leaks.
REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Catawba CC - 4555
1347 Prison Camp Rd, , Newton, NC 28658-9307, Phone: 828-466-5521
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Location #: 1774912 **Violations:** 1

Object: NC394358 - PV - WPC - 2012 - E & F Dorm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 03/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Pressure relieving device too small for this application.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Location: (DPS-C) Lanesboro CI - 4865
552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Location #: 1805021 **Violations:** 1

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/01/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler can not run due to faulty modulating motor. Part is on order with C&C Boiler but is currently not available to nation wide parts shortage. Boiler is not in use and tagged out.
REQUIREMENT: 363. Undefined Boiler Violations. Repair boiler as required. Part needed to repair is on backorder.

Location: (DPS-C) Lanesboro Minimum CI - 3510 **Location #:** 1770840 **Violations:** 1
248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622
Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Object: NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 07/19/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 378. Discharge opening directed improperly.
CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.
REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (DPS-C) NCCIW - 3010 **Location #:** 1779964 **Violations:** 2
1034 Bragg St, , Raleigh, NC 27610-3846, Phone: 919-733-4340
Contact: Phillip Jones, Maintenance Supervisor, NCCIW - 3010, Phone: 919-508-1690

Object: NC381483 - Boiler - PVI Industries - 2010 - Falcom Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 12/08/2020 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report. If welding is required, a qualified "R" certificate holder is necessary to perform the repair.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC401596 - Boiler - PVI Industries - 2014 - Sparrow N - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 12/08/2020 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Tank leaking at unknown location.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report. If welding is required, a qualified "R" certificate holder is necessary to perform the repair.

Location: (GRAHAM CS) Robbinsville High & Middle **Location #:** 1824861 **Violations:** 1
301 Sweetwater Rd, , Robbinsville, NC 28771-9435, Phone: 828-479-3330 HIGH/828-479-8488 MIDDLE
Contact: Attn Patrick Nicholes, Maintenance Supervisor, Graham County Schools, Phone: 828-479-6636

Object: NC321896 - Boiler - Teledyne Laars - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/17/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (HAYWOOD CS) Canton Middle **Location #:** 1772761 **Violations:** 2
60 Penland St, , Canton, NC 28716-4704, Phone: 828-646-3467
Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC228431 - Boiler - Weil-McLain - 1987 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/01/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service however it has not been properly disconnected from all sources of potential energy.
REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC352595 - Boiler - Weil-McLain - 2004 - A Bldg - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/01/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: The boiler could not be started for the inspection. The controls could not be tested.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: schedule a follow up inspection for a day and time when the boiler can be started.

ENTERED BY: Judd, Janie

CLOSED BY:

Location: (HAYWOOD CS) Meadowbrook Elem

Location #: 1809629

Violations: 1

85 Morning Star Rd, , Canton, NC 28716-9459, Phone: 828-646-3445

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Object: NC355116 - Boiler - Weil-McLain - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/01/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 273. Shell leaks.
CONDITION: 273. Boiler Components: Shell leaks.
REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

ENTERED BY: Keyes, Amanda

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HENDERSON) County Courthouse **Location #:** 1796551 **Violations:** 1

200 N Grove St Ste 163, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Chris Hill, Maintenance Supervisor, Henderson County Courthouse, Phone: 828 458 4882

Object: NC270732 - Boiler - PVI Industries - 1994 - Court Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (HENDERSON) County Detention Center **Location #:** 1796552 **Violations:** 2

200 N Grove St Ste 223, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Thad Ninnemann, Maintenance Director, Henderson County Detention Center, Phone: 828-808-9701,

Object: NC324687 - Boiler - PVI Industries - 2000 - Courthouse Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (LENOIR CS) La Grange Elem **Location #:** 1804602 **Violations:** 1
402 W Railroad St, , La Grange, NC 28551-1640, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC336833 - Boiler - Weil-McLain - 2001 - BLR RM - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/07/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: (LENOIR CS) North Lenoir High **Location #:** 1815064 **Violations:** 1
2400 Institute Rd, , La Grange, NC 28551-6716, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC287096 - Boiler - Lochinvar - 1997 - Kitchen Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Boiler not operating.
REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (LENOIR CS) Northwest Elem **Location #:** 1815337 **Violations:** 1
1701 Old Well Rd, , Kinston, NC 28504-2600, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC041545 - Boiler - NRC - 1957 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/07/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Boiler Not operating

REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that system safety devises can be verified to operate properly.

Location: (LENOIR CS) Rochelle Middle

Location #: 1825083

Violations: 2

301 N Rochelle Blvd, , Kinston, NC 28501-5240, Phone: 252-527-1407

Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC065774 - Boiler - Fitzgibbon - 1962 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (LENOIR CS) Southwood Elem

Location #: 1831270

Violations: 1

1245 Hwy 58 S, , Kinston, NC 28504-6909, Phone: 252-527-1407

Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC298004 - Boiler - Weil-McLain - 1999 - Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (LENOIR CS) Woodington Middle **Location #:** 1845083 **Violations:** 2
4939 US Highway 258 S, , Kinston, NC 28504-7083, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC320551 - Boiler - Weil-McLain - 1999 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 371. Inadequate relieving capacity.
CONDITION: 371. Installation of PRDs NCAC 13-13.0405: Inadequate relieving capacity.
REQUIREMENT: 371. Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Object: NC398635 - Boiler - Weil-McLain - 2013 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 371. Inadequate relieving capacity.
CONDITION: 371. Installation of PRDs NCAC 13-13.0405: Inadequate relieving capacity.
REQUIREMENT: 371. Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Location: (MARTIN CS) Rodgers Elem **Location #:** 1825274 **Violations:** 1
2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637
Contact: Martin County Schools, Phone: 252-792-1575

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 10/19/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MH UNIV) Pittman Dining Hall

Location #: 1930566

Violations: 1

121 Cascade St, , Mars Hill, NC 28754-9135, Phone: 828-689-1201

Contact: Attn David May, Director Of Facilities, Mars Hill University, Phone: 828-689-1172, Cell:864-653-0230

Object: NC262677 - Boiler - Fulton - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (NC A&T) Band Bldg

Location #: 1776866

Violations: 1

1120 E Bessemer Ave, , Greensboro, NC 27405-7106, Phone: 336-334-7025

Contact: NC A & T State University, Phone: 336-334-3806

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC007630 - Boiler - Atlantic - 1948 - Blr Rm 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 11/01/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 275. Tube/tube ends leak.

CONDITION: 275. Boiler Components: Tube/tube ends leak: Leak of unknown origin. Possible tube or tube sheet leakage, but exact source could not be verified.

REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (NCDOT) Highway Div 2 Maint Shop

Location #: 1783474

Violations: 1

2443 NC 306 Hwy S, , Grantsboro, NC 28529-9623, Phone: 252-514-4735

Contact: Attn Jennifer Savage, Accounting, NC Dept Of Transportation, Phone: 919-835-8002

Object: NC244812 - PV - Buckeye - 1987 - Shop - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 04/05/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 030. Pressure gauge not installed.

CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not installed.

REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: (UNC-CH) Friday Continuing Ed Ctr-369

Location #: 1883829

Violations: 1

100 Friday Center Dr, , Chapel Hill, NC 27517-9495, Phone: 919-962-1271

Contact: Attn Lawrence Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC246907 - PV - Manchester - 1988 - BLR RM - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 03/28/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 037. Glass missing.
CONDITION: 037. Pressure Gauges NCAC 13-13.0407: Glass missing.
REQUIREMENT: 037. Replace glass or install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper size in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: (UNC-CH) Research Resource Farm Hse-460C

Location #: 1838504

Violations: 1

1907 Orange Chapel Clover Garden Rd, , Chapel Hill, NC 27516-7317, Phone: 919-843-8771

Contact: Attn Lawrence Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC344935 - Boiler - Peerless - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 370. Pressure relieving devices not installed.
CONDITION: 370. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 370. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Location: (UNCC) Facilities Operations

Location #: 2550379

Violations: 1

9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-2199

Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC331573 - Boiler - Aerco - 2004 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/10/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. HX cracked. Unit tagged out. Awaiting parts.
REQUIREMENT: 363. Undefined Boiler Violations. Repair cracking. If welding is required a qualified 'R' certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WSSU) Albert Anderson Conference Center **Location #:** 1930965 **Violations:** 2
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC404281 - Boiler - Weil-McLain - 2015 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief Device (PRD) Leaking
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB Stamped PRD having a set pressure of 80 PSI or less and a relieving capacity of 3,709,00 BTU/Hour or more.

Location: (WSSU) Diggs Gallery **Location #:** 1838693 **Violations:** 1
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2877
Contact: Winston Salem State University, Phone: 336-750-2858

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC119413 - Boiler - Babcock & Wilcox - 1973 - Heating Plt Blr Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection low water cutoffs (LWCO) and pressure relief devices (PRD) could not be tested to verify proper operations.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the LWCO and PRD may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of the successful testing of these devices is also acceptable

Location: (WSSU) Wilson Residence Hall
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Location #: 1930987

Violations: 2

Object: NC263498 - Boiler - Peerless - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,748,000 BTU/Hour or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC374636 - Boiler - Weil-McLain - 2008 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/20/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,082,000 BTU/Hour or more.

Location: (WU) Bridges Hall

Location #: 1880967

Violations: 1

216 Cedar St, , Wingate, NC 28174-5495, Phone: 800-755-5550

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC222281 - Boiler - Peerless - 1986 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 11/15/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 13-Burners and Fuel Supply Systems

SUBCATEGORY 231. Leaking automatic gas valve.

CONDITION: 231. Burners and Fuel Supply Systems: Leaking automatic gas valve.

REQUIREMENT: 231. Repair or replace the leaking automatic gas valve.

Location: (WU) New Stadium Training Bldg

Location #: 1814520

Violations: 1

660 N Main St, , Wingate, NC 28174-6760, Phone: 704-233-8218

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC297025 - Boiler - Eafco - 1998 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 11/15/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

SUBCATEGORY 001. Low water cutoff device not installed.

CONDITION: 001. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device not installed.

REQUIREMENT: 001. Equip the boiler with a low water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: (YANCEY CS) South Toe Elem

Location #: 1830380

Violations: 1

166 S Toe School Rd, , Burnsville, NC 28714-8551, Phone: 828-675-4321

Contact: Attn Chris Howell, Yancey County Schools, Phone: 828-682-3066

Object: NC326313 - Boiler - Weil-McLain - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Bossong Hosiery Mills

Location #: 1769759

Violations: 2

840 W Salisbury St, , Asheboro, NC 27203-4327, Phone: 336-625-2175

Contact: Attn Sunimal Perera, Bossong Hosiery Mills Inc, Phone: 336-625-2175, Cell:336-897-9979

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC184038 - PV - Turbo - 1970 - Boarding 4 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/25/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Manufacturer's Data Report & Nameplate
SUBCATEGORY 431. Nameplate stamping is incorrect, missing, or illegible.
CONDITION: 431. Manufacturer's Data Report & Nameplate: Nameplate stamping is incorrect, missing, or illegible: ASME Data Plate Missing.
REQUIREMENT: 431. Obtain a replacement nameplate from the manufacturer or a replacement in accordance with the National Board Inspection Code.

Object: NC184041 - PV - Turbo - 1970 - Boarding 2 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/25/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Manufacturer's Data Report & Nameplate
SUBCATEGORY 431. Nameplate stamping is incorrect, missing, or illegible.
CONDITION: 431. Manufacturer's Data Report & Nameplate: ASME Data Plate Missing.
REQUIREMENT: 431. Obtain a replacement nameplate from the manufacturer or a replacement in accordance with the National Board Inspection Code.

Location: Carolina Packers Inc **Location #:** 1773944 **Violations:** 1
2999 S Brightleaf Blvd, , Smithfield, NC 27577-5251, Phone: 919-934-2181
Contact: Carolina Packers Inc, Phone: 919-934-2181

Object: NC106918 - Boiler - BE&S - 1971 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/24/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Chandler Foods **Location #:** 1775819 **Violations:** 1
2727 Immanuel Rd, , Greensboro, NC 27407-2515, Phone: 336-299-1934
Contact: Attn Mike McMasters, Chandler Foods Inc, Phone: 336-299-1934

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC244966 - Boiler - Ajax - 1989 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/09/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 277. Other component leaking.

CONDITION: 277. Boiler Components: Other component leaking: Leaking gaskets front and rear access covers.

REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Crystal Cleaners

Location #: 1781327

Violations: 1

202 S Main St Ste C, , Graham, NC 27253-3366, Phone: 336-570-3400

Contact: Attn Kyungdal Seo, Owner, Crystal Cleaners, Phone: 336-570-3400

Object: NC408262 - Boiler - Fulton - 2016 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Parker, Richard

OPENED: 04/12/2022

ENTERED BY: Parker, Richard

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Overdue for internal inspection.

REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341

Location: Dale Earnhardt Inc

Location #: 1781942

Violations: 1

1675 Dale Earnhardt Hwy Ste 3, , Mooresville, NC 28115-8330, Phone: 704-662-8000 X3311

Contact: Attn Bob Bauer, Shop Manager, Dale Earnhardt Inc, Phone: 704-662-8000 X3311, Cell:336-972-0393

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC282929 - Boiler - Raypak - 1997 - Blr Rm WC 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 01/11/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations: Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

Location: Deerfield Episcopal Retirement Community

Location #: 1765215

Violations: 1

1617 Hendersonville Rd, , Asheville, NC 28803-4129, Phone: 828-274-1531

Contact: Mark Sherron, Maintenance Supervisor, Deerfield Episcopal Retirement Community, Phone: 828-273-1835

Object: NC299533 - PV - LTC - 1998 - Skill Care Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/04/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 452. Set pressure too high.

CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.

REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer.

Location: Elevate Textile

Location #: 1771590

Violations: 11

1001 Turnpike Rd, , Raeford, NC 28376-8566, Phone: 910-875-3731

Contact: Attn David Limbacher, Maintenance Manager, Elevate Textile INC, Phone: 910-875-3731 X472, Cell:910-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC197933 - PV - Gcdmc - 1964 - Dye Kier #3 - Active

Violations This Object: 2

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Rudolph, Jay		
OPENED:	01/19/2022	ENTERED BY:	Keyes, Amanda
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	04-Installation of PRDs NCAC 13-13.0405		
SUBCATEGORY	457. Try lever not installed.		
CONDITION:	457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.		
REQUIREMENT:	457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.		
COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Rudolph, Jay		
OPENED:	01/19/2022	ENTERED BY:	Keyes, Amanda
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	05-Operation of PRDs NCAC 13-13.0405		
SUBCATEGORY	475. Valve leaking.		
CONDITION:	475. Operation of PRDs NCAC 13-13.0405: Valve leaking.		
REQUIREMENT:	475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.		

Object: NC197936 - PV - Gcdmc - 1964 - Dye Kier #6 Expansion Tank - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Rudolph, Jay		
OPENED:	01/19/2022	ENTERED BY:	Keyes, Amanda
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	05-Operation of PRDs NCAC 13-13.0405		
SUBCATEGORY	475. Valve leaking.		
CONDITION:	475. Operation of PRDs NCAC 13-13.0405: Valve leaking.		
REQUIREMENT:	475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC197938 - PV - Gcdmc - 1964 - Dye Kier #5 Expansion Tank - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC197940 - PV - Gcdmc - 1964 - Dye Kier #3 Expansion Tank - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC197942 - PV - Gcdmc - 1964 - Dye Kier #2 Expansion Tank - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Object: NC197943 - PV - Gcdmc - 1964 - Dye Kier #2 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Object: NC197944 - PV - Gcdmc - 1964 - Dye Kier #1 Expansion Tank - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC197946 - PV - Perry Products - 1970 - Dye Kier #4 Expansion Tank - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/19/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Object: NC366617 - PV - Gcdmc - 1995 - Jet #20 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/20/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Manufacturer's Data Report & Nameplate
SUBCATEGORY 431. Nameplate stamping is incorrect, missing, or illegible.
CONDITION: 431. Manufacturer's Data Report & Nameplate: Nameplate stamping is incorrect, missing, or illegible.
REQUIREMENT: 431. Obtain a replacement nameplate from the manufacturer or a replacement in accordance with the National Board Inspection Code.

Location: Ethan Allen Plt 2 **Location #:** 872083 **Violations:** 1
24 Salem Church Rd, , Maiden, NC 28650-8363, Phone: 828-428-9361
Contact: Ricky Brown, Maintenance Supervisor, Ethan Allen Plt 1, Phone: 828-428-9361 X108

Object: NC216908 - PV - Wormald - 1984 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/14/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Broken lock wire on Pressure Relief Device.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Four Seasons Dry Cleaners & Laundry **Location #:** 1790815 **Violations:** 1
7015 Market St, , Wilmington, NC 28411-9729, Phone: 910-297-0362

Contact: Attn Alvaro Cervants, Owner, Four Seasons Dry Cleaners & Laundry, Phone: 910-297-0362

Object: NC263815 - Boiler - Fulton - 1995 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/25/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

Location: Hangers Cleaners **Location #:** 1808675 **Violations:** 1
3803 N Church St, , Greensboro, NC 27405-2619, Phone: 336-375-3002

Contact: Attn Inok Kim, Owner, Hangers Cleaners, Phone: 336-375-3002

Object: NC427581 - Boiler - Fulton - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/29/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 019. Drain clogged.
CONDITION: 019. LWCO and Flow Sensing Devices NCAC 13-13.0409: Primary low water drain clogged.
REQUIREMENT: 019. Clean or replace drain pipe to reestablish full flow. Once complete test the Low water cut off to verify proper operation.

Location: Harris Regional Hospital **Location #:** 1795916 **Violations:** 1
68 Hospital Rd, , Sylva, NC 28779-2722, Phone: 828-586-7000

Contact: Attn Mark Huston, Maintenance Supervisor, Harris Regional Hospital, , Cell:828-768-2837

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC046098 - Boiler - Kewanee - 1958 - West Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 09/16/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Highlands Cashiers Hospital **Location #:** 1797433 **Violations:** 3
190 Hospital Dr, , Highlands, NC 28741-7600, Phone: 828-526-1200
Contact: Attn Terry Winn, Plant Operations Manager, Highlands Cashiers Hospital, Phone: 828-526-1417, Cell:828-

Object: NC339009 - Boiler - Steris Corp - 2002 - OR Central Processing - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC339010 - Boiler - Steris Corp - 2002 - OR Central Processing - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC365479 - Boiler - Steris Corp - 2002 - OR Sub Sterile - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Location: John Umstead Hospital **Location #:** 1802165 **Violations:** 1
1003 12th St, , Butner, NC 27509-1626, Phone: 919-575-7536
Contact: Attn Edd Lovette, John Umstead Hospital, Phone: 919-575-7971

Object: NC401217 - Boiler - Cleaver Brooks - 2014 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/14/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Jordan Lake State Recreation Area **Location #:** 1802545 **Violations:** 1
280 State Park Rd, , Apex, NC 27523-8008, Phone: 919-362-0586
Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC259066 - PV - Dixie - 1992 - New Hope Pump House - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Gunto III, Andrew
OPENED: 03/23/2022 **ENTERED BY:** Gunto III, Andrew
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 461. Incorrect pressure relieving device(s) for the application.
CONDITION: 461. Installation of PRDs NCAC 13-13.0405: Incorrect pressure relieving device(s) for the application.
REQUIREMENT: 461. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

- 1) The safety valve must be ASME and National Board certified.
- 2) The safety valve must be no less than ¾ inch pipe-size at its inlet.
- 3) The safety valve must be set to release at or below MAWP.
- 4) The safety valve must have a capacity rating in SCFM's.
- 5) All pipes, valves and fittings install between the safety valve inlet and the vessel must be no smaller than the safety valve inlet.
- 6) The safety valve must be installed at the top of the vessel.
- 7) If an isolation valve is installed between the safety valve inlet and the vessel. The isolation valve must be built in a way that allows it to be pad-locked in the open position. The lock shall be installed at the time of the follow-up inspection.
- 8) The safety valve must has means for a manual operational test.

All repairs must satisfy the requirements of the Uniform Boiler and Pressure Vessel Act of North Carolina.

Location: Longleaf Neuro Medical Treatment Center **Location #:** 1813141 **Violations:** 2
4761 Ward Blvd, , Wilson, NC 27893-4359, Phone: 252-399-2112
Contact: There is no contact information available for this location.

Object: NC220870 - Boiler - Cleaver Brooks - 1987 - Blr Rm 2 - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 04/04/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 04/04/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Boiler not operating
REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that safety devices can be tested verify proper operation.

Location: McCreary Modern Inc
2961 Rocky Rd, , Lenoir, NC 28645-8098, Phone: 828-758-7594
Location #: 3645840 **Violations:** 2
Contact: Ryan Coulter, Manager, McCreary Modern Inc, Phone: 828-244-9064

Object: NC084822 - Boiler - Kewanee - 1965 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 019. Drain clogged.
CONDITION: 019. LWCO and Flow Sensing Devices NCAC 13-13.0409: Drain clogged.
REQUIREMENT: 019. Clean or replace drain pipe to reestablish full flow.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 397. Try lever inoperative.
CONDITION: 397. Operation of PRDs NCAC 13-13.0405: Try lever inoperative.
REQUIREMENT: 397. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Medicago USA
7 Triangle Dr, , Durham, NC 27709-0005, Phone: 919-313-9670
Location #: 3005097 **Violations:** 1
Contact: Attn Tatyana Blankenship, Director, Medicago USA Inc, Phone: 919-313-9670

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC387341 - Boiler - Raypak - 2011 - Roof Terrace - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Richey, Paul D.
OPENED: 02/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: Minton Sales **Location #:** 1222925 **Violations:** 1
1540 Morganton Blvd SW, , Lenoir, NC 28645-5561, Phone: 828-850-3015
Contact: Bill Moore, Maintenance Supervisor, Minton Sales Inc, Phone: 828-850-7012

Object: NC409025 - Boiler - Industrial - 1971 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/14/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Bottom Blow and Drain Systems NCAC 13-13.0411
SUBCATEGORY 154. Leaking pipe/pipe joints.
CONDITION: 154. Bottom Blow and Drain Systems NCAC 13-13.0411: Leaking pipe/pipe joints:
Slow opening blow down valve leaking at outlet plumbing connection.
REQUIREMENT: 154. Repair or replace leaking piping/pipe joints.

Location: National Guard Armory **Location #:** 1813514 **Violations:** 1
700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512
Contact: National Guard Armory, Phone: 704-2835512

Object: NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 09/13/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control
inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure
proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: National Guard Armory **Location #:** 1813555 **Violations:** 1
890 Withrow Rd, , Forest City, NC 28043-9697, Phone: 828-287-0669
Contact: Attn Blane Boyd, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Object: NC279743 - Boiler - Weil-McLain - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/11/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: National Guard Joint Forces HQ **Location #:** 2910374 **Violations:** 1
4080 District Dr, , Raleigh, NC 27607-6470, Phone: 919-664-6094
Contact: Attn Blane Boyd, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Object: NC382700 - Boiler - Bryan - 2010 - Ground Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/06/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 379. Discharge piping too small.
CONDITION: 379. Installation of PRDs NCAC 13-13.0405: Discharge piping too small.
REQUIREMENT: 379. Repipe the discharge line full size to a safe point of discharge.

Location: NC School Of Science & Mathematics **Location #:** 1813129 **Violations:** 1
1219 Broad St, , Durham, NC 27705-3577, Phone: 919-416-2672
Contact: NC School Of Science & Mathematics, Phone: 919-416-2793

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC212851 - Boiler - Kewanee - 1984 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: NC Wesleyan College **Location #:** 1813234 **Violations:** 1
3400 N Wesleyan Blvd, , Rocky Mount, NC 27804-8699, Phone: 252-985-5222
Contact: Renee Bradley, Facility Administrator, NC Wesleyan College, Phone: 252-985-5574

Object: NC206070 - Boiler - Weil-McLain - 1982 - Nash Hall Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 04/07/2022 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Water leaking from bottom of the boiler.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report. Repair the leaking components or replace the boiler. Contact Danny Harrell @ 919-500-3098 when the repair or replacement is completed.

Location: River Landing At Sandy Ridge **Location #:** 1824609 **Violations:** 3
1575 John Knox Dr, , Colfax, NC 27235-9662, Phone: 336-668-4900
Contact: Eddie Hedrick, Manager, River Landing At Sandy Ridge, Phone: 336-668-4900

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC311181 - Boiler - PVI Industries - 2001 - Main Mech Rm M26 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 02/14/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak: Possible tube leak front tube sheet of boiler.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Object: NC367358 - Boiler - Lochinvar - 2007 - Mech Rm A 309 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 02/14/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints: Flow switch leaking.
REQUIREMENT: 020. Replace the leaking flow switch in order to correct this issue.

Object: NC367359 - Boiler - Lochinvar - 2007 - Mech Rm A 309 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 02/14/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints: Flow switch leaking
REQUIREMENT: 020. Replace the leaking flow switch in order to correct this issue.

Location: St Johns Lutheran Church **Location #:** 1832117 **Violations:** 1
2126 St Johns Church Rd NE, , Conover, NC 28613-8975, Phone: 828-464-4071
Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC333939 - Boiler - Weil-McLain - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/07/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 266,000 BTU/Hour or more.

Location: Swannanoa Cleaners

Location #: 1834154

Violations: 1

780 Hendersonville Rd Ste 4, , Asheville, NC 28803-2926, Phone: 828-253-3691

Contact: Marvin Thomas, Owner, Swannanoa Cleaners, Phone: 828-253-3691

Object: NC331902 - Boiler - Hurst - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Temple Emanuel

Location #: 1835077

Violations: 1

713 N Greene St, , Greensboro, NC 27401-2025, Phone: 336-292-7899 X305

Contact: Attn Laura Denhardt, Temple Emanuel, Phone: 336-292-7899 X305, Cell:336-508-8660

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC360688 - Boiler - Raypak - 2004 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/30/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief valve (PRD) leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 160 PSI or less and a relieving capacity of 327,000 BTU/Hour or more.

Location: UFP Salisbury LLC

Location #: 2158141

Violations: 1

2815 Woodtech Dr, , Newton, NC 28658-8967, Phone: 704-855-1600

Contact: UFPI Regulatory Compliance, Phone: 616-365-1526

Object: NC367821 - PV - Silvan - 2007 - SE Corner Bldg 3 - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Hutchens, Mark

OPENED: 02/23/2022

ENTERED BY: Hutchens, Mark

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 450. Pressure relieving devices not installed.

CONDITION: 450. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.

REQUIREMENT: 450. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Location: Wade Manufacturing Co

Location #: 1840985

Violations: 2

76 Mill St, , Wadesboro, NC 28170-2410, Phone: 704-694-2131

Contact: Wade Manufacturing Co, Phone: 704-694-2131

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC252818 - PV - Niles Steel - 1980 - Comp Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/18/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 06-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.

CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.

REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/18/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 06-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.

CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.

REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

Violations This Report: 93

Locations This Report: 62