

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (CABARRUS CS) Beverly Hills Elem **Location #:** 1768208 **Violations:** 1
87 Palaside Dr NE, , Concord, NC 28025-3056, Phone: 704-782-0115
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC291622 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 02/17/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 396. Missing nameplate.
CONDITION: 396. Operation of PRDs NCAC 13-13.0405: PRD nameplate unreadable
REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (CABARRUS CS) Cabarrus County Opportunity School **Location #:** 1792956 **Violations:** 1
120 Marsh Ave NW, , Concord, NC 28025-4889, Phone: 704-793-1736
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC291623 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 02/17/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 394. Valve inoperative.
CONDITION: 394. Operation of PRDs NCAC 13-13.0405: Valve inoperative: PRD was leaking at base and from weephole
REQUIREMENT: 394. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (CABARRUS CS) Carl A Furr Elem **Location #:** 2002374 **Violations:** 1
2725 Clover Rd NW, , Concord, NC 28027-3804, Phone: 704-788-4300
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC364598 - Boiler - Weil-McLain - 2006 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 02/15/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. The installer put the wrong ASME nameplate on.

REQUIREMENT: 363. Undefined Boiler Violations. Customer is to obtain and fill out the needed form and have the manufacturer send the correct AMSE nameplate for attachment.

Location: (COLUMBUS CS) Acme Delco Elem

Location #: 1761932

Violations: 1

16337 Old Lake Rd, , Riegelwood, NC 28456-7077, Phone: 910-655-2957

Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Object: NC252134 - Boiler - Weil-McLain - 1990 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 11/04/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (DPS-C) Alexander CI - 4870

Location #: 1762873

Violations: 2

633 Old Landfill Rd, , Taylorsville, NC 28681-8420, Phone: 828-632-1331

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC414237 - Boiler - Cleveland Range - 2017 - Kitchen - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408

SUBCATEGORY 058. Leaking.

CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.

REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 271. Handhole plug leaks.
CONDITION: 271. Boiler Components: Handhole plug leaks.
REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Catawba CC - 4555
1347 Prison Camp Rd, , Newton, NC 28658-9307, Phone: 828-466-5521
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Location #: 1774912 **Violations:** 1

Object: NC394358 - PV - WPC - 2012 - E & F Dorm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 03/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Pressure relieving device too small for this application.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Location: (DPS-C) Lanesboro CI - 4865
552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Location #: 1805021 **Violations:** 1

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 11/01/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler can not run due to faulty modulating motor. Part is on order with C&C Boiler but is currently not available to nation wide parts shortage. Boiler is not in use and tagged out.

REQUIREMENT: 363. Undefined Boiler Violations. Repair boiler as required. Part needed to repair is on backorder.

Location: (DPS-C) Lanesboro Minimum CI - 3510

Location #: 1770840

Violations: 1

248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622

Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Object: NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 07/19/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 24-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 378. Discharge opening directed improperly.

CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.

REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (ECU) Life Science & Biotechnology Bldg

Location #: 4054490

Violations: 1

700 E 14th St, , Greenville, NC 27858-3503, Phone: 252-328-2040

Contact: Michael Deyoc, Steam Operations Manager, Life Science & Biotechnology Bldg, Phone: 252-328-2040,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC432375 - Boiler - Cleaver Brooks - 2020 - Penthouse - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 396. Missing nameplate.
CONDITION: 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.
REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (GREENE) Health Dept **Location #:** 1794007 **Violations:** 2
227 Kingold Blvd Ste B, , Snow Hill, NC 28580-1303, Phone: 252-747-8183
Contact: Greene County Government, Phone: 252-747-5720

Object: NC275963 - Boiler - H B Smith - 1994 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/02/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/02/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. BOILER NOT OPERATING
REQUIREMENT: 363. Rescheduled inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (HAYWOOD CS) Canton Middle **Location #:** 1772761 **Violations:** 2
60 Penland St, , Canton, NC 28716-4704, Phone: 828-646-3467
Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC228431 - Boiler - Weil-McLain - 1987 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service however it has not been properly disconnected from all sources of potential energy.

REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

Object: NC352595 - Boiler - Weil-McLain - 2004 - A Bldg - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 26-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.

CONDITION: 399. Undefined Pressure Relieving Devices Violations: The boiler could not be started for the inspection. The controls could not be tested.

REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: schedule a follow up inspection for a day and time when the boiler can be started.

Location: (HAYWOOD CS) Meadowbrook Elem

Location #: 1809629

Violations: 1

85 Morning Star Rd, , Canton, NC 28716-9459, Phone: 828-646-3445

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Object: NC355116 - Boiler - Weil-McLain - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HENDERSON) County Courthouse **Location #:** 1796551 **Violations:** 1

200 N Grove St Ste 163, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Chris Hill, Maintenance Supervisor, Henderson County Courthouse, Phone: 828 458 4882

Object: NC270732 - Boiler - PVI Industries - 1994 - Court Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (HENDERSON) County Detention Center **Location #:** 1796552 **Violations:** 2

200 N Grove St Ste 223, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Thad Ninnemann, Maintenance Director, Henderson County Detention Center, Phone: 828-808-9701,

Object: NC324687 - Boiler - PVI Industries - 2000 - Courthouse Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HOKE) Health Dept **Location #:** 1797834 **Violations:** 1
683 E Palmer St, , Raeford, NC 28376-6648, Phone: 910-875-3717
Contact: James Tetter, Mgr, Health Dept, , Cell:910-309-7559

Object: NC360057 - Boiler - Raypak - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	04/11/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler not operating	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.	

Location: (LENOIR CS) North Lenoir High **Location #:** 1815064 **Violations:** 1
2400 Institute Rd, , La Grange, NC 28551-6716, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC287096 - Boiler - Lochinvar - 1997 - Kitchen Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	03/08/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler not operating.	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.	

Location: (LENOIR CS) Northwest Elem **Location #:** 1815337 **Violations:** 1
1701 Old Well Rd, , Kinston, NC 28504-2600, Phone: 252-527-1407
Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC041545 - Boiler - NRC - 1957 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/07/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Boiler Not operating

REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that system safety devises can be verified to operate properly.

Location: (LENOIR CS) Rochelle Middle

Location #: 1825083

Violations: 2

301 N Rochelle Blvd, , Kinston, NC 28501-5240, Phone: 252-527-1407

Contact: Attn R Jones, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC065774 - Boiler - Fitzgibbon - 1962 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (MARTIN CS) Rodgers Elem

Location #: 1825274

Violations: 1

2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637

Contact: Martin County Schools, Phone: 252-792-1575

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 10/19/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MH UNIV) Pittman Dining Hall

Location #: 1930566

Violations: 1

121 Cascade St, , Mars Hill, NC 28754-9135, Phone: 828-689-1201

Contact: Attn David May, Director Of Facilities, Mars Hill University, Phone: 828-689-1172, Cell:864-653-0230

Object: NC262677 - Boiler - Fulton - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (NC A&T) Band Bldg

Location #: 1776866

Violations: 1

1120 E Bessemer Ave, , Greensboro, NC 27405-7106, Phone: 336-334-7025

Contact: NC A & T State University, Phone: 336-334-3806

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC007630 - Boiler - Atlantic - 1948 - Blr Rm 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 11/01/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 275. Tube/tube ends leak.

CONDITION: 275. Boiler Components: Tube/tube ends leak: Leak of unknown origin. Possible tube or tube sheet leakage, but exact source could not be verified.

REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (UNC-CH) Ambulatory Care Ctr-241

Location #: 1883838

Violations: 2

102 Mason Farm Rd, , Chapel Hill, NC 27514-4617, Phone: 919-962-1271

Contact: Attn Lawrence Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC398891 - PV - Steris Corp - 2010 - OR 5 Sub Sterile Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 04/01/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 07-Undefined Pressure Vessels Violations

SUBCATEGORY 479. Undefined Pressure Vessels Violations.

CONDITION: 479. Pressure vessel has not operated and can not be tested while not in operation.

REQUIREMENT: 479. Operate this pressure vessel for testing or remove it from service.

Object: NC398892 - PV - Steris Corp - 2010 - OR 7 Sub Sterile Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 04/01/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 07-Undefined Pressure Vessels Violations

SUBCATEGORY 479. Undefined Pressure Vessels Violations.

CONDITION: 479. Pressure vessels has not operated and can not be tested while not in operation.

REQUIREMENT: 479. Operate this pressure vessel or remove it from service.

Location: (UNC-CH) Friday Continuing Ed Ctr-369

Location #: 1883829

Violations: 1

100 Friday Center Dr, , Chapel Hill, NC 27517-9495, Phone: 919-962-1271

Contact: Attn Lawrence Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC246907 - PV - Manchester - 1988 - BLR RM - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 03/28/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 037. Glass missing.
CONDITION: 037. Pressure Gauges NCAC 13-13.0407: Glass missing.
REQUIREMENT: 037. Replace glass or install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper size in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: (UNC-CH) Research Resource Farm Hse-460C

Location #: 1838504

Violations: 1

1907 Orange Chapel Clover Garden Rd, , Chapel Hill, NC 27516-7317, Phone: 919-843-8771

Contact: Attn Lawrence Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC344935 - Boiler - Peerless - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 370. Pressure relieving devices not installed.
CONDITION: 370. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 370. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Location: (UNCC) Facilities Operations

Location #: 2550379

Violations: 1

9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-2199

Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC331573 - Boiler - Aerco - 2004 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/10/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. HX cracked. Unit tagged out. Awaiting parts.
REQUIREMENT: 363. Undefined Boiler Violations. Repair cracking. If welding is required a qualified 'R' certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (UNCG) Central Heating Plt **Location #:** 1930865 **Violations:** 2
800 Oakland Ave, , Greensboro, NC 27412-5059, Phone: 336-334-5684
Contact: Attn Jon Soter, UNC Greensboro, Phone: 336-256-0434, Cell:336-587-1440

Object: NC350743 - Boiler - English - 2004 - Power House Blr Rm Blr 4 - **Violations This Object:** 2
Active

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	04/26/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations: Boiler overdue for required external inspection non-certificate inspection.	
REQUIREMENT:	363. Undefined Boiler Violations: Schedule a re-inspection of this boiler at a time when it operating so that the required external non-certificate inspection may be completed.	
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	04/26/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations: Boiler overdue for required external inspection non-certificate inspection.	
REQUIREMENT:	363. Undefined Boiler Violations: Schedule a re-inspection of this boiler at a time when it operating so that the required external non-certificate inspection may be completed.	

Location: (UNCH) James T Hedrick Bldg **Location #:** 1801348 **Violations:** 1
211 Friday Center Dr Ste 2047, , Chapel Hill, NC 27517-9499, Phone: 919-966-4484
Contact: Attn Charles Scott, Manager, UNC Hospitals Plant Engineering, Phone: 919-966-5211, Cell:919-201-9343

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC382979 - Boiler - Bock Energy - 2010 - Bsmt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/17/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: Pressure relief device (PRD) inlet plumbing connection corroded/leaking.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: Replace the corroded/leaking PRD inlet plumbing connection in order to correct this condition.

Location: (WSSU) Albert Anderson Conference Center

Location #: 1930965

Violations: 2

601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858

Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC404281 - Boiler - Weil-McLain - 2015 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief Device (PRD) Leaking
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB Stamped PRD having a set pressure of 80 PSI or less and a relieving capacity of 3,709,00 BTU/Hour or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WSSU) Physical Plant **Location #:** 1930976 **Violations:** 1
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC229631 - Boiler - Kewanee - 1988 - Heating Plt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/23/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (WSSU) Wilson Residence Hall **Location #:** 1930987 **Violations:** 2
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC263498 - Boiler - Peerless - 1993 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,748,000 BTU/Hour or more.

Object: NC374636 - Boiler - Weil-McLain - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,082,000 BTU/Hour or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WU) Bridges Hall **Location #:** 1880967 **Violations:** 1
216 Cedar St, , Wingate, NC 28174-5495, Phone: 800-755-5550

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC222281 - Boiler - Peerless - 1986 - Mech Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	11/15/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	13-Burners and Fuel Supply Systems	
SUBCATEGORY	231. Leaking automatic gas valve.	
CONDITION:	231. Burners and Fuel Supply Systems: Leaking automatic gas valve.	
REQUIREMENT:	231. Repair or replace the leaking automatic gas valve.	

Location: (WU) New Stadium Training Bldg **Location #:** 1814520 **Violations:** 1
660 N Main St, , Wingate, NC 28174-6760, Phone: 704-233-8218

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC297025 - Boiler - Eafco - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	11/15/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	01-LWCO and Flow Sensing Devices NCAC 13-13.0409	
SUBCATEGORY	001. Low water cutoff device not installed.	
CONDITION:	001. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device not installed.	
REQUIREMENT:	001. Equip the boiler with a low water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.	

Location: (YANCEY CS) South Toe Elem **Location #:** 1830380 **Violations:** 1
166 S Toe School Rd, , Burnsville, NC 28714-8551, Phone: 828-675-4321

Contact: Attn Chris Howell, Yancey County Schools, Phone: 828-682-3066

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC326313 - Boiler - Weil-McLain - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Accu Fab Inc

Location #: 1761862

Violations: 1

801 Beacon Lake Dr, , Raleigh, NC 27610-1377, Phone: 919-390-4921

Contact: Attn Billy Creech, Facilities Mgr, Accu Fab Inc, Phone: 919-390-4921

Object: NC426245 - PV - Manchester - 2018 - Outside Right Side - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/23/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 030. Pressure gauge not installed.

CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not inoperable.

REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Dale Earnhardt Inc

Location #: 1781942

Violations: 1

1675 Dale Earnhardt Hwy Ste 3, , Mooresville, NC 28115-8330, Phone: 704-662-8000 X3311

Contact: Attn Bob Bauer, Shop Manager, Dale Earnhardt Inc, Phone: 704-662-8000 X3311, Cell:336-972-0393

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC282929 - Boiler - Raypak - 1997 - Blr Rm WC 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 01/11/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations: Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

Location: Deerfield Episcopal Retirement Community

Location #: 1765215

Violations: 1

1617 Hendersonville Rd, , Asheville, NC 28803-4129, Phone: 828-274-1531

Contact: Mark Sherron, Maintenance Supervisor, Deerfield Episcopal Retirement Community, Phone: 828-273-1835

Object: NC299533 - PV - LTC - 1998 - Skill Care Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/04/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 452. Set pressure too high.

CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.

REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer.

Location: Ethan Allen Plt 2

Location #: 872083

Violations: 1

24 Salem Church Rd, , Maiden, NC 28650-8363, Phone: 828-428-9361

Contact: Ricky Brown, Maintenance Supervisor, Ethan Allen Plt 1, Phone: 828-428-9361 X108

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC216908 - PV - Wormald - 1984 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Broken lock wire on Pressure Relief Device.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Front Street Brewery

Location #: 1791347

Violations: 2

9 N Front St, , Wilmington, NC 28401-4436, Phone: 910-251-1935

Contact: Attn Tom Harris, Owner, Front Street Brewery, Phone: 910-251-1935, Cell:336-816-3288

Object: NC425592 - Boiler - Weil-McLain - 2019 - Bsmt SE Side - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 04/19/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 04/19/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: Graham Dyeing & Finishing **Location #:** 1793692 **Violations:** 3
240 Hawkins St, , Burlington, NC 27217-3926, Phone: 336-228-9981
Contact: Graham Dyeing & Finishing Inc, Phone: 336-228-9981

Object: NC079212 - Boiler - Cleaver Brooks - 1966 - Blr Rm - Active **Violations This Object:** 3

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	05/09/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	03-Water Gauge Glass NCAC 13-13.0408	
SUBCATEGORY	058. Leaking.	
CONDITION:	058. Water Gauge Glass NCAC 13-13.0408: Leaking.	
REQUIREMENT:	058. Repair or replace the leaking gauge and test to ensure proper operation.	
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	05/09/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	25-Operation of PRDs NCAC 13-13.0405	
SUBCATEGORY	395. Valve leaking.	
CONDITION:	395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Both pressure relief devices (PRD) leaking.	
REQUIREMENT:	395. Replace both leaking PRD's with ASME/NB stamped PRD's each having a set pressure of 150 PSI or less. The sum of the relieving capacities for the two replacement PRD's must be equal to 8,375 pounds of steam per hour or more.	
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	05/09/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	25-Operation of PRDs NCAC 13-13.0405	
SUBCATEGORY	395. Valve leaking.	
CONDITION:	395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Both pressure relief devices (PRD) leaking.	
REQUIREMENT:	395. Replace both leaking PRD's with ASME/NB stamped PRD's each having a set pressure of 150 PSI or less. The sum of the relieving capacities for the two replacement PRD's must be equal to 8,375 pounds of steam per hour or more.	

Location: Harrells Christian Academy **Location #:** 1795838 **Violations:** 1
360 Tomahawk Hwy, , Harrells, NC 28444-0088, Phone: 910-532-4575
Contact: Attn Andy Well, Asst Headmaster, Harrells Christian Academy, Phone: 910-532-4575

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC386994 - Boiler - Weil-McLain - 2011 - Rear Newkirk Auditorium **Violations This Object:** 1
- Active

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	04/27/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	270. Water Leaks.	
CONDITION:	270. Boiler Components: Water Leaks.	
REQUIREMENT:	270. Repair the water leaks identified on the inspection report.	

Location: Harris Regional Hospital **Location #:** 1795916 **Violations:** 1
68 Hospital Rd, , Sylva, NC 28779-2722, Phone: 828-586-7000
Contact: Attn Mark Huston, Maintenance Supervisor, Harris Regional Hospital, , Cell:828-768-2837

Object: NC046098 - Boiler - Kewanee - 1958 - West Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Possidente, James	
OPENED:	09/16/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	275. Tube/tube ends leak.	
CONDITION:	275. Boiler Components: Tube/tube ends leak.	
REQUIREMENT:	275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	

Location: Haymore Memorial Baptist Church **Location #:** 1165178 **Violations:** 1
319 Rockford St, , Mount Airy, NC 27030-4663, Phone: 336-786-7435
Contact: Attn Nancy McPeak, Secretary, Haymore Memorial Baptist Church, Phone: 336-786-7435

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC396684 - Boiler - Crown - 2013 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/25/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations Boiler not operating at time of inspection Low Water Cutoffs (LWCO) and Pressure Relief Device (PRD) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection of this boiler at a time when it is operating so that the LWCO controls and PRD may be tested to verify proper operation. As an alternative a detailed service report or boiler log that includes documentation of the successful testing of these devices is also acceptable.

Location: Hickory Yarns Inc

Location #: 1797141

Violations: 1

1025 10th St NE, , Hickory, NC 28601-4037, Phone: 828-322-1550

Contact: Hickory Dyeing & Winding Co, Phone: 828-322-1550

Object: NC240405 - Boiler - Abco - 1989 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 05/02/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.

CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.

REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: Highlands Cashiers Hospital

Location #: 1797433

Violations: 3

190 Hospital Dr, , Highlands, NC 28741-7600, Phone: 828-526-1200

Contact: Attn Terry Winn, Plant Operations Manager, Highlands Cashiers Hospital, Phone: 828-526-1417, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC339009 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC339010 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC365479 - Boiler - Steris Corp - 2002 - OR Sub Sterile - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Location: House Of Raeford Farms **Location #:** 1776925 **Violations:** 1
253 Butterball Rd, , Teachey, NC 28464-9638, Phone: 910-271-4892
Contact: Attn John Wojcuich, Manager, House Of Raeford Farms Inc, Phone: 910-271-4892

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC302334 - PV - Steel Fab - 1995 - Waste Plt Air Comp - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/20/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 030. Pressure gauge not installed.
CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge inoperable.
REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: John Umstead Hospital **Location #:** 1802165 **Violations:** 1
1003 12th St, , Butner, NC 27509-1626, Phone: 919-575-7536
Contact: Attn Edd Lovette, John Umstead Hospital, Phone: 919-575-7971

Object: NC401217 - Boiler - Cleaver Brooks - 2014 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/14/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Medicago USA **Location #:** 3005097 **Violations:** 1
7 Triangle Dr, , Durham, NC 27709-0005, Phone: 919-313-9670
Contact: Attn Tatyana Blankenship, Director, Medicago USA Inc, Phone: 919-313-9670

Object: NC387341 - Boiler - Raypak - 2011 - Roof Terrace - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Richey, Paul D.
OPENED: 02/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Minton Sales **Location #:** 1222925 **Violations:** 1

1540 Morganton Blvd SW, , Lenoir, NC 28645-5561, Phone: 828-850-3015

Contact: Bill Moore, Maintenance Supervisor, Minton Sales Inc, Phone: 828-850-7012

Object: NC409025 - Boiler - Industrial - 1971 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Bottom Blow and Drain Systems NCAC 13-13.0411

SUBCATEGORY 154. Leaking pipe/pipe joints.

CONDITION: 154. Bottom Blow and Drain Systems NCAC 13-13.0411: Leaking pipe/pipe joints: Slow opening blow down valve leaking at outlet plumbing connection.

REQUIREMENT: 154. Repair or replace leaking piping/pipe joints.

Location: National Guard Armory **Location #:** 1813514 **Violations:** 1

700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512

Contact: National Guard Armory, Phone: 704-2835512

Object: NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 09/13/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 05-Temperature Controls NCAC 13-13.0406

SUBCATEGORY 093. High limit temperature control inoperative.

CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.

REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Location: National Guard Joint Forces HQ **Location #:** 2910374 **Violations:** 1

4080 District Dr, , Raleigh, NC 27607-6470, Phone: 919-664-6094

Contact: Attn Blane Boyd, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC382700 - Boiler - Bryan - 2010 - Ground Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/06/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 379. Discharge piping too small.
CONDITION: 379. Installation of PRDs NCAC 13-13.0405: Discharge piping too small.
REQUIREMENT: 379. Repipe the discharge line full size to a safe point of discharge.

Location: NC Aquarium Dare Marine Research Ctr **Location #:** 1812958 **Violations:** 1
374 Airport Rd, , Manteo, NC 27954-9485, Phone: 252-473-3494
Contact: NC Aquarium Dare Marine Research Ctr, Phone: 252-473-3494

Object: NC320865 - Boiler - State Industries - 1998 - Top Large Tank - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 05/12/2022 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 11-Exp Tanks & Htng Sys Piping NCAC 13-13.0412
SUBCATEGORY 193. Leaking pipe/pipe joints.
CONDITION: 193. Exp Tanks & Htng Sys Piping NCAC 13-13.0412: Leaking pipe/pipe joints. Nipple between pressure relief valve and the vessel is leaking and has excessive corrosion visible.
REQUIREMENT: 193. Repair or replace leaking piping/pipe joints. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: NC School Of Science & Mathematics **Location #:** 1813129 **Violations:** 1
1219 Broad St, , Durham, NC 27705-3577, Phone: 919-416-2672
Contact: NC School Of Science & Mathematics, Phone: 919-416-2793

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC212851 - Boiler - Kewanee - 1984 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: NC Wesleyan College **Location #:** 1813234 **Violations:** 1
3400 N Wesleyan Blvd, , Rocky Mount, NC 27804-8699, Phone: 252-985-5222
Contact: Renee Bradley, Facility Administrator, NC Wesleyan College, Phone: 252-985-5574

Object: NC206070 - Boiler - Weil-McLain - 1982 - Nash Hall Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 04/07/2022 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Water leaking from bottom of the boiler.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report. Repair the leaking components or replace the boiler. Contact Danny Harrell @ 919-500-3098 when the repair or replacement is completed.

Location: Siloam Cleaners **Location #:** 1829224 **Violations:** 1
1415 Emerywood Dr, , Charlotte, NC 28210-4105, Phone: 704-553-1769
Contact: Attn Yong Chol Lee, Owner, Siloam Cleaners, Phone: 704-553-1769

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC341562 - PV - Trinity - 2001 - Outside Rear - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 05/18/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 452. Set pressure too high.

CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.

REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: St Johns Lutheran Church

Location #: 1832117

Violations: 1

2126 St Johns Church Rd NE, , Conover, NC 28613-8975, Phone: 828-464-4071

Contact: There is no contact information available for this location.

Object: NC333939 - Boiler - Weil-McLain - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/07/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 266,000 BTU/Hour or more.

Location: Swannanoa Cleaners

Location #: 1834154

Violations: 1

780 Hendersonville Rd Ste 4, , Asheville, NC 28803-2926, Phone: 828-253-3691

Contact: Marvin Thomas, Owner, Swannanoa Cleaners, Phone: 828-253-3691

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC331902 - Boiler - Hurst - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Temple Emanuel

Location #: 1835077

Violations: 1

713 N Greene St, , Greensboro, NC 27401-2025, Phone: 336-292-7899 X305

Contact: Attn Laura Denhardt, Temple Emanuel, Phone: 336-292-7899 X305, Cell:336-508-8660

Object: NC360688 - Boiler - Raypak - 2004 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/30/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief valve (PRD) leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 160 PSI or less and a relieving capacity of 327,000 BTU/Hour or more.

Location: The Club At Oak Branch

Location #: 1821668

Violations: 1

21 Oak Branch Dr Ste A, , Greensboro, NC 27407-2145, Phone: 336-478-2660

Contact: Attn Josh Hughes, Manager, The Club At Oak Branch, Phone: 336-478-2660

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC299239 - PV - A O Smith - 1999 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 473. Valve stem distorted/bent.
CONDITION: 473. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent: Pressure relief device (PRD) valve steam bent.
REQUIREMENT: 473. Replace the damaged PRD with ASME/NB stamped temperature and pressure relieving type PRD having a set pressure of 160 PSI or less and a relieving capacity of 1,100,000 BTU/Hour. This PRD must also be designed to lift and relieve temperature and pressure at 210 degrees Fahrenheit.

Location: UFP Salisbury LLC

Location #: 2158141

Violations: 1

2815 Woodtech Dr, , Newton, NC 28658-8967, Phone: 704-855-1600

Contact: UFPI Regulatory Compliance, Phone: 616-365-1526

Object: NC367821 - PV - Silvan - 2007 - SE Corner Bldg 3 - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/23/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 450. Pressure relieving devices not installed.
CONDITION: 450. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 450. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Location: Viewmont Baptist Church

Location #: 1840292

Violations: 1

1246 2nd St NE, , Hickory, NC 28601-2661, Phone: 828-322-6732

Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC397353 - Boiler - Weil-McLain - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/02/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative a detailed service report or boiler log that includes documentation of the successful testing of this devices is also acceptable.

Location: Wade Manufacturing Co

Location #: 1840985

Violations: 2

76 Mill St, , Wadesboro, NC 28170-2410, Phone: 704-694-2131

Contact: Wade Manufacturing Co, Phone: 704-694-2131

Object: NC252818 - PV - Niles Steel - 1980 - Comp Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Windstream Communications **Location #:** 1779309 **Violations:** 2
68 Cabarrus Ave E, , Concord, NC 28025-3452, Phone: 704-722-2000
Contact: Danny Craig, Group Leader, Windstream Communications, Phone: 704-722-2000

Object: NC348334 - Boiler - Peerless - 2003 - Bsmt Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/22/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule for another inspection when boiler is running.

Object: NC405385 - Boiler - Peerless - 2015 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/22/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations: Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule for another inspection when boiler is running.

Location: Winston Salem Dental Care **Location #:** 1844813 **Violations:** 3
201 Charlois Blvd, , Winston Salem, NC 27103-1507, Phone: 336-331-3500
Contact: David Brown, Biomedical Equipment Tech, Winston Salem Dental Care, Phone: 336-331-3547, Cell:336-

Object: NC176916 - Boiler - Kewanee - 1977 - Bsmt Blr Rm - Active **Violations This Object:** 3

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 05/10/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 057. Drain inoperative.
CONDITION: 057. Water Gauge Glass NCAC 13-13.0408: Drain inoperative.
REQUIREMENT: 057. Repair or replace the inoperable drain valve on the gauge and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 05/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

contact Richard Parker @ 336-202-8341

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 05/10/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 09-Bottom Blow and Drain Systems NCAC 13-13.0411
SUBCATEGORY 156. Piping installation incorrect.
CONDITION: 156. Bottom Blow and Drain Systems NCAC 13-13.0411: Piping installation incorrect.
REQUIREMENT: 156. Reinstall piping to be in accordance with the ASME Boiler and Pressure Vessel Code. Pipe blowdown to safe location.

contact Richard Parker @ 336-202-8341

Violations This Report: 81

Locations This Report: 63