

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: (CABARRUS CS) Carl A Furr Elem **Location #:** 2002374 **Violations:** 1
2725 Clover Rd NW, , Concord, NC 28027-3804, Phone: 704-788-4300
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC364598 - Boiler - Weil-McLain - 2006 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	02/15/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. The installer put the wrong ASME nameplate on.	
REQUIREMENT:	363. Undefined Boiler Violations. Customer is to obtain and fill out the needed form and have the manufacturer send the correct AMSE nameplate for attachment.	

Location: (COLUMBUS CS) Acme Delco Elem **Location #:** 1761932 **Violations:** 1
16337 Old Lake Rd, , Riegelwood, NC 28456-7077, Phone: 910-655-2957
Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Object: NC252134 - Boiler - Weil-McLain - 1990 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	11/04/2021	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	12-Casing, Stack Breeching and Flue	
SUBCATEGORY	211. Combustion gas leaks.	
CONDITION:	211. Casing, Stack Breeching and Flue: Combustion gas leaks.	
REQUIREMENT:	211. Repair all combustion gas leaks in the casing, stack breeching, or flue.	

Location: (DPS-C) Alexander CI - 4870 **Location #:** 1762873 **Violations:** 2
633 Old Landfill Rd, , Taylorsville, NC 28681-8420, Phone: 828-632-1331
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414237 - Boiler - Cleveland Range - 2017 - Kitchen - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 271. Handhole plug leaks.
CONDITION: 271. Boiler Components: Handhole plug leaks.
REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Catawba CC - 4555 **Location #:** 1774912 **Violations:** 1
1347 Prison Camp Rd, , Newton, NC 28658-9307, Phone: 828-466-5521
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC394358 - PV - WPC - 2012 - E & F Dorm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 03/22/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Pressure relieving device too small for this application.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Location: (DPS-C) Franklin CC - 4215 **Location #:** 1790986 **Violations:** 1
5918 NC 39 Hwy S, , Bunn, NC 27508-6106, Phone: 919-496-6119
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC368959 - Boiler - Smith Cast Iron - 2006 - Dorm 4 Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 06/17/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

ENTERED BY: Keyes, Amanda
CLOSED BY:

Location: (DPS-C) Lanesboro CI - 4865

Location #: 1805021

Violations: 1

552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/01/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler can not run due to faulty modulating motor. Part is on order with C&C Boiler but is currently not available to nation wide parts shortage. Boiler is not in use and tagged out.
REQUIREMENT: 363. Undefined Boiler Violations. Repair boiler as required. Part needed to repair is on backorder.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: (DPS-C) Lanesboro Minimum CI - 3510

Location #: 1770840

Violations: 1

248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622

Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 07/19/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 24-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 378. Discharge opening directed improperly.

CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.

REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (GREENE) Health Dept

Location #: 1794007

Violations: 2

227 Kingold Blvd Ste B, , Snow Hill, NC 28580-1303, Phone: 252-747-8183

Contact: Greene County Government, Phone: 252-747-5720

Object: NC275963 - Boiler - H B Smith - 1994 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/02/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/02/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. BOILER NOT OPERATING

REQUIREMENT: 363. Rescheduled inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (HAYWOOD CS) Canton Middle

Location #: 1772761

Violations: 2

60 Penland St, , Canton, NC 28716-4704, Phone: 828-646-3467

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC228431 - Boiler - Weil-McLain - 1987 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service however it has not been properly disconnected from all sources of potential energy.

REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

Object: NC352595 - Boiler - Weil-McLain - 2004 - A Bldg - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 26-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.

CONDITION: 399. Undefined Pressure Relieving Devices Violations: The boiler could not be started for the inspection. The controls could not be tested.

REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: schedule a follow up inspection for a day and time when the boiler can be started.

Location: (HAYWOOD CS) Meadowbrook Elem

Location #: 1809629

Violations: 1

85 Morning Star Rd, , Canton, NC 28716-9459, Phone: 828-646-3445

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Object: NC355116 - Boiler - Weil-McLain - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HENDERSON) County Courthouse **Location #:** 1796551 **Violations:** 1

200 N Grove St Ste 163, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Chris Hill, Maintenance Supervisor, Henderson County Courthouse, Phone: 828 458 4882

Object: NC270732 - Boiler - PVI Industries - 1994 - Court Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (HENDERSON) County Detention Center **Location #:** 1796552 **Violations:** 2

200 N Grove St Ste 223, , Hendersonville, NC 28792-5027, Phone: 828-808-9701

Contact: Thad Ninnemann, Maintenance Director, Henderson County Detention Center, Phone: 828-808-9701,

Object: NC324687 - Boiler - PVI Industries - 2000 - Courthouse Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 01/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HOKE) Health Dept **Location #:** 1797834 **Violations:** 1
683 E Palmer St, , Raeford, NC 28376-6648, Phone: 910-875-3717
Contact: James Tetter, Mgr, Health Dept, , Cell:910-309-7559

Object: NC360057 - Boiler - Raypak - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	04/11/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler not operating	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.	

Location: (LENOIR CS) North Lenoir High **Location #:** 1815064 **Violations:** 1
2400 Institute Rd, , La Grange, NC 28551-6716, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC287096 - Boiler - Lochinvar - 1997 - Kitchen Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	03/08/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler not operating.	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.	

Location: (LENOIR CS) Northwest Elem **Location #:** 1815337 **Violations:** 1
1701 Old Well Rd, , Kinston, NC 28504-2600, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC041545 - Boiler - NRC - 1957 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/07/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Boiler Not operating

REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that system safety devises can be verified to operate properly.

Location: (LENOIR CS) Rochelle Middle

Location #: 1825083

Violations: 2

301 N Rochelle Blvd, , Kinston, NC 28501-5240, Phone: 252-527-1407

Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC065774 - Boiler - Fitzgibbon - 1962 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (MADISON CS) Brush Creek Elem

Location #: 1771008

Violations: 1

265 Upper Brush Creek Rd, , Marshall, NC 28753-9599, Phone: 828-649-1547

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Object: NC333137 - Boiler - Peerless - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 05/25/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks at rear sigh glass
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MADISON CS) Madison High

Location #: 1807561

Violations: 2

5740 US 25/70 Hwy, , Marshall, NC 28753-6364, Phone: 828-649-2876

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Object: NC262641 - Boiler - Weil-McLain - 1993 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 05/25/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks. Combustion gas leaking from rear sight glass.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 05/25/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 380. Seals broken/missing.
CONDITION: 380. Installation of PRDs NCAC 13-13.0405: Seals broken/missing. Safety Valve tag missing.
REQUIREMENT: 380. Replace the relief valve with one with an ASME/NB certified valve.

Location: (MADISON CS) Madison Middle

Location #: 1807566

Violations: 1

95 Upper Brush Creek Rd, , Marshall, NC 28753-4067, Phone: 828-649-2269

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC262640 - Boiler - Weil-McLain - 1992 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 05/25/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 396. Missing nameplate.
CONDITION: 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.
REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (MARTIN CS) Rodgers Elem **Location #:** 1825274 **Violations:** 1
2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637
Contact: Martin County Schools, Phone: 252-792-1575

Object: NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 10/19/2021 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MH UNIV) Pittman Dining Hall **Location #:** 1930566 **Violations:** 1
121 Cascade St, , Mars Hill, NC 28754-9135, Phone: 828-689-1201
Contact: Attn David May, Director Of Facilities, Mars Hill University, Phone: 828-689-1172, Cell:864-653-0230

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC262677 - Boiler - Fulton - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (NC A&T) Band Bldg

Location #: 1776866

Violations: 1

1120 E Bessemer Ave, , Greensboro, NC 27405-7106, Phone: 336-334-7025

Contact: NC A & T State University, Phone: 336-334-3806

Object: NC007630 - Boiler - Atlantic - 1948 - Blr Rm 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 11/01/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 275. Tube/tube ends leak.

CONDITION: 275. Boiler Components: Tube/tube ends leak: Leak of unknown origin. Possible tube or tube sheet leakage, but exact source could not be verified.

REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (UNC-CH) Ambulatory Care Ctr-241

Location #: 1883838

Violations: 2

102 Mason Farm Rd, , Chapel Hill, NC 27514-4617, Phone: 919-962-1271

Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC398891 - PV - Steris Corp - 2010 - OR 5 Sub Sterile Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Pressure vessel has not operated and can not be tested while not in operation.
REQUIREMENT: 479. Operate this pressure vessel for testing or remove it from service.

Object: NC398892 - PV - Steris Corp - 2010 - OR 7 Sub Sterile Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Pressure vessels has not operated and can not be tested while not in operation.
REQUIREMENT: 479. Operate this pressure vessel or remove it from service.

Location: (UNC-CH) Research Resource Farm Hse-460C **Location #:** 1838504 **Violations:** 1
1907 Orange Chapel Clover Garden Rd, , Chapel Hill, NC 27516-7317, Phone: 919-843-8771
Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC344935 - Boiler - Peerless - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/12/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 370. Pressure relieving devices not installed.
CONDITION: 370. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 370. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Location: (UNCC) Facilities Operations **Location #:** 2550379 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-2199
Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC331573 - Boiler - Aerco - 2004 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 11/10/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. HX cracked. Unit tagged out. Awaiting parts.

REQUIREMENT: 363. Undefined Boiler Violations. Repair cracking. If welding is required a qualified 'R' certificate holder is necessary to perform the work.

Location: (UNCC) Regional Utility Plt 5

Location #: 3968972

Violations: 1

9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-0564

Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC423477 - Boiler - Hurst - 2019 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 06/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Forced fan impeller cracked and broken/awaiting repair parts

REQUIREMENT: 363. Undefined Boiler Violations. Replace cracked and broken impeller on main forced air fan. Upon completion of repairs schedule a follow up inspection.

Location: (UNCH) James T Hedrick Bldg

Location #: 1801348

Violations: 1

211 Friday Center Dr Ste 2047, , Chapel Hill, NC 27517-9499, Phone: 919-966-4484

Contact: Attn Charles Scott, Manager, UNC Hospitals Plant Engineering, Phone: 919-966-5211, Cell:919-201-9343

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC382979 - Boiler - Bock Energy - 2010 - Bsmt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/17/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations: Pressure relief device (PRD) inlet plumbing connection corroded/leaking.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: Replace the corroded/leaking PRD inlet plumbing connection in order to correct this condition.

Location: (WSSU) Albert Anderson Conference Center

Location #: 1930965

Violations: 2

601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858

Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC404281 - Boiler - Weil-McLain - 2015 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief Device (PRD) Leaking
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB Stamped PRD having a set pressure of 80 PSI or less and a relieving capacity of 3,709,00 BTU/Hour or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WSSU) Physical Plant **Location #:** 1930976 **Violations:** 1
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC229631 - Boiler - Kewanee - 1988 - Heating Plt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/23/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (WSSU) Wilson Residence Hall **Location #:** 1930987 **Violations:** 2
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC263498 - Boiler - Peerless - 1993 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,748,000 BTU/Hour or more.

Object: NC374636 - Boiler - Weil-McLain - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,082,000 BTU/Hour or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WU) Bridges Hall **Location #:** 1880967 **Violations:** 1
216 Cedar St, , Wingate, NC 28174-5495, Phone: 800-755-5550
Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC222281 - Boiler - Peerless - 1986 - Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 231. Leaking automatic gas valve.
CONDITION: 231. Burners and Fuel Supply Systems: Leaking automatic gas valve.
REQUIREMENT: 231. Repair or replace the leaking automatic gas valve.

Location: (WU) New Stadium Training Bldg **Location #:** 1814520 **Violations:** 1
660 N Main St, , Wingate, NC 28174-6760, Phone: 704-233-8218
Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC297025 - Boiler - Eafco - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 001. Low water cutoff device not installed.
CONDITION: 001. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device not installed.
REQUIREMENT: 001. Equip the boiler with a low water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: (YANCEY CS) South Toe Elem **Location #:** 1830380 **Violations:** 1
166 S Toe School Rd, , Burnsville, NC 28714-8551, Phone: 828-675-4321
Contact: Attn Chris Howell, Yancey County Schools, Phone: 828-682-3066

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC326313 - Boiler - Weil-McLain - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: A Cleaner World #107

Location #: 1761441

Violations: 1

1009 2nd St NE, , Hickory, NC 28601-3843, Phone: 828-328-5900

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Object: NC391085 - Boiler - Parker - 2012 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Hutchens, Mark

OPENED: 06/15/2022

ENTERED BY: Hutchens, Mark

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Pressure Controls NCAC 13-13.0406

SUBCATEGORY 073. High limit pressure control inoperative.

CONDITION: 073. Pressure Controls NCAC 13-13.0406: High limit pressure control inoperative.

REQUIREMENT: 073. Repair or replace the inoperative high limit pressure control. Test to ensure proper operation.

Location: Accu Fab Inc

Location #: 1761862

Violations: 1

801 Beacon Lake Dr, , Raleigh, NC 27610-1377, Phone: 919-390-4921

Contact: Attn Billy Creech, Facilities Mgr, Accu Fab Inc, Phone: 919-390-4921

Object: NC426245 - PV - Manchester - 2018 - Outside Right Side - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/23/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 030. Pressure gauge not installed.

CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not inoperable.

REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Ashe Memorial Hospital **Location #:** 1764977 **Violations:** 1
200 Hospital Ave, , Jefferson, NC 28640-9244, Phone: 336-246-0720

Contact: Attn Gary Carter, Lead Fac Maintenance, Ashe Memorial Hospital, Phone: 336-846-0720

Object: NC113606 - Boiler - Kewanee - 1970 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/31/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler overdue for required internal certificate inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an internal inspection as soon as possible in order to correct this issue.

Location: Candlewood Suites **Location #:** 1772649 **Violations:** 4
4433 Lead Mine Rd, , Raleigh, NC 27612-3324, Phone: 919-789-4840

Contact: Attn Kelvin Lee, Maint Eng, Candlewood Suites, Phone: 919-789-4840

Object: NC328040 - Boiler - Lochinvar - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Temperature & Pressure Gauge Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC328041 - Boiler - Lochinvar - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Temperature and Pressure Gauge Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

ENTERED BY: Fish, Emily

CLOSED BY:

Object: NC381477 - PV - Lochinvar - 2010 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 10-Thermometer NCAC 13-13.0410
SUBCATEGORY 111. Thermometer inoperative.
CONDITION: 111. Thermometer NCAC 13-13.0410: Thermometer inoperative.
REQUIREMENT: 111. Replace inoperative thermometer at/in the vessel outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

ENTERED BY: Fish, Emily

CLOSED BY:

Object: NC381478 - PV - Lochinvar - 2010 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 10-Thermometer NCAC 13-13.0410
SUBCATEGORY 111. Thermometer inoperative.
CONDITION: 111. Thermometer NCAC 13-13.0410: Thermometer inoperative.
REQUIREMENT: 111. Replace inoperative thermometer at/in the vessel outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

ENTERED BY: Fish, Emily

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: Carolina Meadows Retirement Community **Location #:** 1773851 **Violations:** 1
100 Whippoorwill Ln, , Chapel Hill, NC 27517-8566, Phone: 919-942-4014
Contact: Carolina Meadows Retirement Community, Phone: 919-942-4014

Object: NC389631 - Boiler - Lochinvar - 2011 - Laundry - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	SORRENTINO, SEAN	
OPENED:	06/16/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	277. Other component leaking.	
CONDITION:	277. Boiler Components: Other component leaking.	
REQUIREMENT:	277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	

Location: Dale Earnhardt Inc **Location #:** 1781942 **Violations:** 1
1675 Dale Earnhardt Hwy Ste 3, , Mooresville, NC 28115-8330, Phone: 704-662-8000 X3311
Contact: Attn Bob Bauer, Shop Manager, Dale Earnhardt Inc, Phone: 704-662-8000 X3311, Cell:336-972-0393

Object: NC282929 - Boiler - Raypak - 1997 - Blr Rm WC 1 - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	01/11/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations: Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.	

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

Location: Drakes Fresh Pasta Co **Location #:** 2685411 **Violations:** 1
636 Southwest St, , High Point, NC 27260-8107, Phone: 336-861-5454
Contact: Attn Drew Weaver, Maintenance, Drakes Fresh Pasta Co, Phone: 336-862-7284 x-1, Cell:336-210-7478

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC416655 - Boiler - Hurst - 2018 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 06/06/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 271. Handhole plug leaks.

CONDITION: 271. Boiler Components: Handhole plug leaks: Three hand-hole gaskets leaking.

REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Ethan Allen Plt 2

Location #: 872083

Violations: 1

24 Salem Church Rd, , Maiden, NC 28650-8363, Phone: 828-428-9361

Contact: Ricky Brown, Maintenance Supervisor, Ethan Allen Plt 1, Phone: 828-428-9361 X108

Object: NC216908 - PV - Wormald - 1984 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/14/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 06-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.

CONDITION: 478. Undefined Pressure Relieving Devices Violations: Broken lock wire on Pressure Relief Device.

REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: First Citizens Bank

Location #: 1789027

Violations: 2

117 4th St NW, , Hickory, NC 28601-6144, Phone: 828-326-1100

Contact: Attn Derek Gooch, Facilities Manager, First Citizens Bank, Phone: 828-326-1184

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC385797 - Boiler - Weil-McLain - 2011 - 2nd Flr Blr Rm - Active **Violations This Object:** 2

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Clay, Steven D.		
OPENED:	06/13/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	13-Burners and Fuel Supply Systems		
SUBCATEGORY	235. No emergency fuel shut off switch.		
CONDITION:	235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.		
REQUIREMENT:	235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.		
COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Clay, Steven D.		
OPENED:	06/13/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. Boiler not running for inspection.		
REQUIREMENT:	363. Undefined Boiler Violations. Place boiler in operation. Contact inspector for follow up inspection.		

Location: Forest Heights Senior Living Community **Location #:** 1815735 **Violations:** 2
2500 Polo Ridge Ct, , Winston Salem, NC 27106-3950, Phone: 336-722-7181
Contact: Attn Keith Gandolfo, Forest Heights Senior Living Community,

Object: NC435410 - Boiler - Lochinvar - 2021 - boiler room - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	06/06/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	12-Casing, Stack Breeching and Flue		
SUBCATEGORY	212. Damper inoperative.		
CONDITION:	212. Casing, Stack Breeching and Flue: Damper inoperative.		
REQUIREMENT:	212. Repair or replace the damper.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC435411 - PV - Lochinvar - 2021 - Boiler Room - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 471. Discharge piping not properly supported.
CONDITION: 471. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 471. Support the relief valve discharge piping so it may not impose excessive stress on the valve.

ENTERED BY: Parker, Richard

CLOSED BY:

contact Richard Parker @ 336-202-8341

Location: Front Street Brewery

Location #: 1791347

Violations: 2

9 N Front St, , Wilmington, NC 28401-4436, Phone: 910-251-1935

Contact: Attn Tom Harris, Owner, Front Street Brewery, Phone: 910-251-1935, Cell:336-816-3288

Object: NC425592 - Boiler - Weil-McLain - 2019 - Bsmt SE Side - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 04/19/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

ENTERED BY: Keyes, Amanda

CLOSED BY:

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 04/19/2022

CLOSED:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

ENTERED BY: Keyes, Amanda

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Fulchers Point Pride Seafood II **Location #:** 3637472 **Violations:** 1
114 Gatlin Rd, , Alliance, NC 28509 , Phone: 252-745-7711

Contact: Chaz Fulcher, Manager, Fulchers Point Pride Seafood Co II, Phone: 252-745-7711

Object: NC423770 - PV - Buckeye - 1986 - Outside Bldg - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 06/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 032. Incorrect range or insufficient pointer travel.
CONDITION: 032. Pressure Gauges NCAC 13-13.0407: Incorrect range or insufficient pointer travel.
REQUIREMENT: 032. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Graham Dyeing & Finishing **Location #:** 1793692 **Violations:** 3
240 Hawkins St, , Burlington, NC 27217-3926, Phone: 336-228-9981

Contact: Graham Dyeing & Finishing Inc, Phone: 336-228-9981

Object: NC079212 - Boiler - Cleaver Brooks - 1966 - Blr Rm - Active **Violations This Object:** 3

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/09/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	05/09/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	25-Operation of PRDs NCAC 13-13.0405		
SUBCATEGORY	395. Valve leaking.		
CONDITION:	395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Both pressure relief devices (PRD) leaking.		
REQUIREMENT:	395. Replace both leaking PRD's with ASME/NB stamped PRD's each having a set pressure of 150 PSI or less. The sum of the relieving capacities for the two replacement PRD's must be equal to 8,375 pounds of steam per hour or more.		

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	05/09/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	25-Operation of PRDs NCAC 13-13.0405		
SUBCATEGORY	395. Valve leaking.		
CONDITION:	395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Both pressure relief devices (PRD) leaking.		
REQUIREMENT:	395. Replace both leaking PRD's with ASME/NB stamped PRD's each having a set pressure of 150 PSI or less. The sum of the relieving capacities for the two replacement PRD's must be equal to 8,375 pounds of steam per hour or more.		

Location: Harrells Christian Academy **Location #:** 1795838 **Violations:** 1
360 Tomahawk Hwy, , Harrells, NC 28444-0088, Phone: 910-532-4575
Contact: Attn Andy Well, Asst Headmaster, Harrells Christian Academy, Phone: 910-532-4575

Object: NC386994 - Boiler - Weil-McLain - 2011 - Rear Newkirk Auditorium **Violations This Object:** 1
- Active

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Rudolph, Jay		
OPENED:	04/27/2022	ENTERED BY:	Keyes, Amanda
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	16-Boiler Components		
SUBCATEGORY	270. Water Leaks.		
CONDITION:	270. Boiler Components: Water Leaks.		
REQUIREMENT:	270. Repair the water leaks identified on the inspection report.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Harris Regional Hospital **Location #:** 1795916 **Violations:** 1
68 Hospital Rd, , Sylva, NC 28779-2722, Phone: 828-586-7000

Contact: Attn Mark Huston, Maintenance Supervisor, Harris Regional Hospital, , Cell:828-768-2837

Object: NC046098 - Boiler - Kewanee - 1958 - West Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Possidente, James	
OPENED:	09/16/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	275. Tube/tube ends leak.	
CONDITION:	275. Boiler Components: Tube/tube ends leak.	
REQUIREMENT:	275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	

Location: Hickory Chair Furniture Co Plt 7 **Location #:** 1222973 **Violations:** 1
37 9th Street Pl SE, , Hickory, NC 28602-1215, Phone: 828-679-2690

Contact: Attn Steve Brittain, Hickory Chair Furniture Co Plt 7, Phone: 828-679-2690

Object: NC089458 - Boiler - Cleaver Brooks - 1968 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	06/01/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	275. Tube/tube ends leak.	
CONDITION:	275. Boiler Components: Tube/tube ends leak.	
REQUIREMENT:	275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	

Location: Highlands Cashiers Hospital **Location #:** 1797433 **Violations:** 3
190 Hospital Dr, , Highlands, NC 28741-7600, Phone: 828-526-1200

Contact: Attn Terry Winn, Plant Operations Manager, Highlands Cashiers Hospital, Phone: 828-526-1417, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC339009 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC339010 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC365479 - Boiler - Steris Corp - 2002 - OR Sub Sterile - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Location: HSM Solutions **Location #:** 4133910 **Violations:** 1
1505 13th St SW, , Hickory, NC 28602-4942, Phone: 828-328-2201
Contact: Attn: Shawn Huffman, Head of Maintenance, HSM Solutions, Phone: 828-328-2201 ext 4645

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC343180 - PV - Silvan - 2002 - Comp Shed - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 06/22/2022 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 453. Inlet pipe too small.
CONDITION: 453. Installation of PRDs NCAC 13-13.0405: Inlet pipe too small.
REQUIREMENT: 453. Replace the inlet line to provide for full size to the relief device.

Location: John Umstead Hospital **Location #:** 1802165 **Violations:** 1
1003 12th St, , Butner, NC 27509-1626, Phone: 919-575-7536
Contact: Attn Edd Lovette, John Umstead Hospital, Phone: 919-575-7971

Object: NC401217 - Boiler - Cleaver Brooks - 2014 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/14/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Medicago USA **Location #:** 3005097 **Violations:** 1
7 Triangle Dr, , Durham, NC 27709-0005, Phone: 919-313-9670
Contact: Medicago USA Inc, Phone: 919-532-0325 ext 1591

Object: NC387341 - Boiler - Raypak - 2011 - Roof Terrace - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Richey, Paul D.
OPENED: 02/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: National Guard Armory **Location #:** 1813514 **Violations:** 1
700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512
Contact: National Guard Armory, Phone: 704-2835512

Object: NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 09/13/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Location: NC Aquarium Dare Marine Research Ctr **Location #:** 1812958 **Violations:** 1
374 Airport Rd, , Manteo, NC 27954-9485, Phone: 252-473-3494
Contact: NC Aquarium Dare Marine Research Ctr, Phone: 252-473-3494

Object: NC320865 - Boiler - State Industries - 1998 - Top Large Tank - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 05/12/2022 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 11-Exp Tanks & Htng Sys Piping NCAC 13-13.0412
SUBCATEGORY 193. Leaking pipe/pipe joints.
CONDITION: 193. Exp Tanks & Htng Sys Piping NCAC 13-13.0412: Leaking pipe/pipe joints. Nipple between pressure relief valve and the vessel is leaking and has excessive corrosion visible.
REQUIREMENT: 193. Repair or replace leaking piping/pipe joints. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: NC School Of Science & Mathematics **Location #:** 1813129 **Violations:** 1
1219 Broad St, , Durham, NC 27705-3577, Phone: 919-416-2672
Contact: NC School Of Science & Mathematics, Phone: 919-416-2793

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC212851 - Boiler - Kewanee - 1984 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: NC Wesleyan College **Location #:** 1813234 **Violations:** 1
3400 N Wesleyan Blvd, , Rocky Mount, NC 27804-8699, Phone: 252-985-5222
Contact: Renee Bradley, Facility Administrator, NC Wesleyan College, Phone: 252-985-5574

Object: NC206070 - Boiler - Weil-McLain - 1982 - Nash Hall Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 04/07/2022 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Water leaking from bottom of the boiler.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report. Repair the leaking components or replace the boiler. Contact Danny Harrell @ 919-500-3098 when the repair or replacement is completed.

Location: NCRC NC Research Campus **Location #:** 2385708 **Violations:** 1
600 Laureate Way, , Kannapolis, NC 28081-3374, Phone: 704-250-5017
Contact: Randall Keller, Facilities Technician, NCRC NC Research Campus, Phone: 704-250-5420, Cell:704-785-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC372891 - Boiler - Bryan - 2008 - Penthouse - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Coley, Oscar

OPENED: 06/01/2022

ENTERED BY: Coley, Oscar

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)

REQUIREMENT: 363. Undefined Boiler Violations. Boiler has to be running to perform a safety check of controls.

Location: NCRC UNC Nutrition Research Institute

Location #: 2212698

Violations: 1

500 Laureate Way, , Kannapolis, NC 28081-3379, Phone: 704-250-5017

Contact: Charles Kraus, Facilities Operations/Zone 7 Supervisor, UNC Charlotte, Phone: 704-250-5017, Cell:980-

Object: NC371947 - Boiler - Bryan - 2007 - Penthouse - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Coley, Oscar

OPENED: 06/01/2022

ENTERED BY: Coley, Oscar

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)

REQUIREMENT: 363. Undefined Boiler Violations. Required yearly running inspection has to be performed with the boiler running.

Location: Scrub Board

Location #: 1827775

Violations: 1

104 Turner Dr, , Reidsville, NC 27320-5700, Phone: 336-623-3347

Contact: Attn Bob Nickelston, Bobs Enterprises, Phone: 276-634-7131, Cell:276-634-7131

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC263537 - Boiler - Weben Jarco - 1989 - Rear Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/16/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Overdue for inspection.
REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341

Location: Siloam Cleaners **Location #:** 1829224 **Violations:** 1
1415 Emerywood Dr, , Charlotte, NC 28210-4105, Phone: 704-553-1769
Contact: Attn Yong Chol Lee, Owner, Siloam Cleaners, Phone: 704-553-1769

Object: NC341562 - PV - Trinity - 2001 - Outside Rear - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 05/18/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 452. Set pressure too high.
CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.
REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Temple Emanuel **Location #:** 1835077 **Violations:** 1
713 N Greene St, , Greensboro, NC 27401-2025, Phone: 336-292-7899 X305
Contact: Attn Laura Denhardt, Temple Emanuel, Phone: 336-292-7899 X305, Cell:336-508-8660

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC360688 - Boiler - Raypak - 2004 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/30/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief valve (PRD) leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 160 PSI or less and a relieving capacity of 327,000 BTU/Hour or more.

Location: The Club At Oak Branch

Location #: 1821668

Violations: 1

21 Oak Branch Dr Ste A, , Greensboro, NC 27407-2145, Phone: 336-478-2660

Contact: Attn Josh Hughes, Manager, The Club At Oak Branch, Phone: 336-478-2660

Object: NC299239 - PV - A O Smith - 1999 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 05/12/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 05-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 473. Valve stem distorted/bent.

CONDITION: 473. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent: Pressure relief device (PRD) valve stem bent.

REQUIREMENT: 473. Replace the damaged PRD with ASME/NB stamped temperature and pressure relieving type PRD having a set pressure of 160 PSI or less and a relieving capacity of 1,100,000 BTU/Hour. This PRD must also be designed to lift and relieve temperature and pressure at 210 degrees Fahrenheit.

Location: Viewmont Baptist Church

Location #: 1840292

Violations: 1

1246 2nd St NE, , Hickory, NC 28601-2661, Phone: 828-322-6732

Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC397353 - Boiler - Weil-McLain - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/02/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative a detailed service report or boiler log that includes documentation of the successful testing of this devices is also acceptable.

Location: Wade Manufacturing Co

Location #: 1840985

Violations: 2

76 Mill St, , Wadesboro, NC 28170-2410, Phone: 704-694-2131

Contact: Wade Manufacturing Co, Phone: 704-694-2131

Object: NC252818 - PV - Niles Steel - 1980 - Comp Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations: Lockwire broken on Pressure Relief Valve (PRD) and reducer installed in discharge.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations: Remove reducer and re-pipe discharge full size to point of discharge. Replace PRD with a new ASME/NB certified PRD set at MAWP and sufficient capacity.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Walter B Jones Alcohol & Drug Treatment Ctr **Location #:** 1841494 **Violations:** 2
2577 W 5th St, , Greenville, NC 27834-7813, Phone: 252-830-3426
Contact: Walter B Jones Alcohol & Drug Treatment Ctr, Phone: 252-707-5035

Object: NC370307 - Boiler - Weil-McLain - 2007 - Blr Rm Bldg 4 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 06/02/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC400181 - Boiler - Bradford White - 2009 - Cafeteria Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 06/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 393. Valve stem distorted/bent.
CONDITION: 393. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent.
REQUIREMENT: 393. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Windstream Communications **Location #:** 1779309 **Violations:** 2
68 Cabarrus Ave E, , Concord, NC 28025-3452, Phone: 704-722-2000
Contact: Attn Danny Craig, Group Leader, Windstream Communications, Phone: 704-722-2000

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC348334 - Boiler - Peerless - 2003 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/22/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.

REQUIREMENT: 363. Undefined Boiler Violations. Reschedule for another inspection when boiler is running.

Object: NC405385 - Boiler - Peerless - 2015 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/22/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations: Boiler not running for inspection.

REQUIREMENT: 363. Undefined Boiler Violations: Reschedule for another inspection when boiler is running.

Violations This Report: 89

Locations This Report: 67