

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: (CABARRUS CS) Carl A Furr Elem **Location #:** 2002374 **Violations:** 1
2725 Clover Rd NW, , Concord, NC 28027-3804, Phone: 704-788-4300
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC364598 - Boiler - Weil-McLain - 2006 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	02/15/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. The installer put the wrong ASME nameplate on.	
REQUIREMENT:	363. Undefined Boiler Violations. Customer is to obtain and fill out the needed form and have the manufacturer send the correct AMSE nameplate for attachment.	

Location: (COLUMBUS CS) Acme Delco Elem **Location #:** 1761932 **Violations:** 1
16337 Old Lake Rd, , Riegelwood, NC 28456-7077, Phone: 910-655-2957
Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Object: NC252134 - Boiler - Weil-McLain - 1990 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	11/04/2021	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	12-Casing, Stack Breeching and Flue	
SUBCATEGORY	211. Combustion gas leaks.	
CONDITION:	211. Casing, Stack Breeching and Flue: Combustion gas leaks.	
REQUIREMENT:	211. Repair all combustion gas leaks in the casing, stack breeching, or flue.	

Location: (DPS-C) Alexander CI - 4870 **Location #:** 1762873 **Violations:** 2
633 Old Landfill Rd, , Taylorsville, NC 28681-8420, Phone: 828-632-1331
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414237 - Boiler - Cleveland Range - 2017 - Kitchen - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 271. Handhole plug leaks.
CONDITION: 271. Boiler Components: Handhole plug leaks.
REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Franklin CC - 4215 **Location #:** 1790986 **Violations:** 1
5918 NC 39 Hwy S, , Bunn, NC 27508-6106, Phone: 919-496-6119
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC368959 - Boiler - Smith Cast Iron - 2006 - Dorm 4 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 06/17/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Lanesboro CI - 4865 **Location #:** 1805021 **Violations:** 1
552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 11/01/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler can not run due to faulty modulating motor. Part is on order with C&C Boiler but is currently not available to nation wide parts shortage. Boiler is not in use and tagged out.

REQUIREMENT: 363. Undefined Boiler Violations. Repair boiler as required. Part needed to repair is on backorder.

Location: (DPS-C) Lanesboro Minimum CI - 3510

Location #: 1770840

Violations: 1

248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622

Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Object: NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 07/19/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 24-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 378. Discharge opening directed improperly.

CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.

REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (ECU) Fleming Residence Hall

Location #: 3487320

Violations: 1

1001 E 5th St, , Greenville, NC 27858-2500, Phone: 252-328-6594

Contact: East Carolina University, Phone: 252-328-6594, Cell:252-328-2041

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC342389 - PV - Aerco - 2002 - Bsmt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 06/28/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 477. Try lever inoperative.
CONDITION: 477. Operation of PRDs NCAC 13-13.0405: Try lever inoperative.
REQUIREMENT: 477. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (ELON UNIV) Mosely Hall

Location #: 3012209

Violations: 2

100 Campus Dr, , Elon, NC 27244-9423, Phone: 336-278-5457

Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Object: NC386797 - Boiler - Raypak - 2011 - Blr Rm Loading Dock - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection so that safety devices could be tested for proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so that safety devices can be tested to verify proper operation.

Object: NC388034 - Boiler - Raypak - 2011 - Blr Rm Loading Dock - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation so that safety devices could be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is in operation so that safety devices can be tested to verify proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (ELON UNIV) Schar Center **Location #:** 3851053 **Violations:** 6
542 N Williamson Ave, , Elon, NC 27244-9157, Phone: 336-675-9403
Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Object: NC415449 - Boiler - AIC Gdynia - 2017 - Blr #2 Blr Rm - Active **Violations This Object:** 2

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/27/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Overdue for inspection.
REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation so that safety devices could be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

Object: NC415450 - Boiler - AIC Gdynia - 2015 - Blr #3 Blr Rm - Active **Violations This Object:** 2

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/27/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Overdue for inspection.
REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection to verify proper operation of safety devices.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Object: NC415451 - Boiler - AIC Gdynia - 2016 - Blr #1 Blr Rm - Active

Violations This Object: 2

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/27/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Overdue for inspection.
REQUIREMENT: 363. Contact inspector and schedule inspection.

ENTERED BY: Parker, Richard
CLOSED BY:

contact Richard Parker @ 336-202-8341

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operation at time of inspection to verify proper operation of safety devices.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is in operation so that safety devices can be tested for proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: (ELON UNIV) University Advancement

Location #: 3676747

Violations: 1

216 S Antioch Ave, , Elon, NC 27244-0215, Phone: 336-278-5457

Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC406378 - Boiler - Lochinvar - 2015 - Crawl Space - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/21/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not operating so that safety devices can be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is operating so that safety devices can be tested to verify proper operation.

Location: (GREENE) Health Dept

Location #: 1794007

Violations: 2

227 Kingold Blvd Ste B, , Snow Hill, NC 28580-1303, Phone: 252-747-8183

Contact: Greene County Government, Phone: 252-747-5720

Object: NC275963 - Boiler - H B Smith - 1994 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/02/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 05/02/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. BOILER NOT OPERATING

REQUIREMENT: 363. Rescheduled inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (HAYWOOD CS) Canton Middle

Location #: 1772761

Violations: 2

60 Penland St, , Canton, NC 28716-4704, Phone: 828-646-3467

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC228431 - Boiler - Weil-McLain - 1987 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service however it has not been properly disconnected from all sources of potential energy.

REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

Object: NC352595 - Boiler - Weil-McLain - 2004 - A Bldg - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 26-Undefined Pressure Relieving Devices Violations

SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.

CONDITION: 399. Undefined Pressure Relieving Devices Violations: The boiler could not be started for the inspection. The controls could not be tested.

REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations: schedule a follow up inspection for a day and time when the boiler can be started.

Location: (HAYWOOD CS) Meadowbrook Elem

Location #: 1809629

Violations: 1

85 Morning Star Rd, , Canton, NC 28716-9459, Phone: 828-646-3445

Contact: Joe Buchanan, Maintenance Director, Haywood County Schools, Phone: 828-456-2402 X2302, Cell:828-

Object: NC355116 - Boiler - Weil-McLain - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/01/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (LENOIR CS) North Lenoir High **Location #:** 1815064 **Violations:** 1
2400 Institute Rd, , La Grange, NC 28551-6716, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC287096 - Boiler - Lochinvar - 1997 - Kitchen Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	03/08/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler not operating.	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.	

Location: (LENOIR CS) Northwest Elem **Location #:** 1815337 **Violations:** 1
1701 Old Well Rd, , Kinston, NC 28504-2600, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC041545 - Boiler - NRC - 1957 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	03/07/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Boiler Not operating	
REQUIREMENT:	363. Reschedule inspection for a time when the boiler is operating so that system safety devises can be verified to operate properly.	

Location: (LENOIR CS) Rochelle Middle **Location #:** 1825083 **Violations:** 2
301 N Rochelle Blvd, , Kinston, NC 28501-5240, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC065774 - Boiler - Fitzgibbon - 1962 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 03/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (MADISON CS) Brush Creek Elem

Location #: 1771008

Violations: 1

265 Upper Brush Creek Rd, , Marshall, NC 28753-9599, Phone: 828-649-1547

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Object: NC333137 - Boiler - Peerless - 2001 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 05/25/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks at rear sigh glass

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MADISON CS) Madison High

Location #: 1807561

Violations: 2

5740 US 25/70 Hwy, , Marshall, NC 28753-6364, Phone: 828-649-2876

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC262641 - Boiler - Weil-McLain - 1993 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 05/25/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks. Combustion gas leaking from rear sight glass.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 05/25/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 24-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 380. Seals broken/missing.

CONDITION: 380. Installation of PRDs NCAC 13-13.0405: Seals broken/missing. Safety Valve tag missing.

REQUIREMENT: 380. Replace the relief valve with one with an ASME/NB certified valve.

Location: (MADISON CS) Madison Middle

Location #: 1807566

Violations: 1

95 Upper Brush Creek Rd, , Marshall, NC 28753-4067, Phone: 828-649-2269

Contact: Andy Gregg, Maintenance Supervisor, Madison County Public Schools, Phone: 828-649-2434, Cell:828 206

Object: NC262640 - Boiler - Weil-McLain - 1992 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 05/25/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 396. Missing nameplate.

CONDITION: 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.

REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (MARTIN CS) Rodgers Elem

Location #: 1825274

Violations: 1

2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637

Contact: Martin County Schools, Phone: 252-792-1575

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 10/19/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (MH UNIV) Pittman Dining Hall

Location #: 1930566

Violations: 1

121 Cascade St, , Mars Hill, NC 28754-9135, Phone: 828-689-1201

Contact: Attn David May, Director Of Facilities, Mars Hill University, Phone: 828-689-1172, Cell:864-653-0230

Object: NC262677 - Boiler - Fulton - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 04/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (NC A&T) T E Neal Heating Plt

Location #: 1834439

Violations: 3

1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025

Contact: Ricky Richmond, Facilities Manager, NC A & T State University, Phone: 336-285-4583, Cell:336-906-9620

Object: NC014569 - Boiler - Combustion Engineering - 1951 - Steam Plt Blr Rm Blr 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/20/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for internal inspection.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an internal inspection as soon as possible.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC292405 - Boiler - Nebraska - 1998 - Power House Blr Rm - Active

Violations This Object: 2

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/20/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	16-Boiler Components		
SUBCATEGORY	275. Tube/tube ends leak.		
CONDITION:	275. Boiler Components: Tube/tube ends leak. Evidence of tube leakage in furnace area.		
REQUIREMENT:	275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.		
COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/20/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. Boiler overdue for required external inspection.		
REQUIREMENT:	363. Undefined Boiler Violations. Schedule an external operating inspection as soon as possible.		

Location: (UNC-CH) Ambulatory Care Ctr-241

Location #: 1883838

Violations: 2

102 Mason Farm Rd, , Chapel Hill, NC 27514-4617, Phone: 919-962-1271

Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC398891 - PV - Steris Corp - 2010 - OR 5 Sub Sterile Rm - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	SORRENTINO, SEAN		
OPENED:	04/01/2022	ENTERED BY:	Keyes, Amanda
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	07-Undefined Pressure Vessels Violations		
SUBCATEGORY	479. Undefined Pressure Vessels Violations.		
CONDITION:	479. Pressure vessel has not operated and can not be tested while not in operation.		
REQUIREMENT:	479. Operate this pressure vessel for testing or remove it from service.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC398892 - PV - Steris Corp - 2010 - OR 7 Sub Sterile Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Pressure vessels has not operated and can not be tested while not in operation.
REQUIREMENT: 479. Operate this pressure vessel or remove it from service.

Location: (UNC-CH) Manning Drive Steam Plant **Location #:** 2363861 **Violations:** 1
210 Manning Dr, , Chapel Hill, NC 27599-6121, Phone: 919-962-0953
Contact: Attn Glenn Hahn, Maintenance Supervisor, UNC Energy Services, Phone: 919-201-4495

Object: NC373075 - Boiler - Babcock & Wilcox - 2006 - Blr #9 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 06/28/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (UNC-CH) Research Resource Farm Hse-460C **Location #:** 1838504 **Violations:** 1
1907 Orange Chapel Clover Garden Rd, , Chapel Hill, NC 27516-7317, Phone: 919-843-8771
Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC344935 - Boiler - Peerless - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/12/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 370. Pressure relieving devices not installed.
CONDITION: 370. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 370. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (UNCC) Facilities Operations **Location #:** 2550379 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-2199
Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC331573 - Boiler - Aerco - 2004 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	11/10/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. HX cracked. Unit tagged out. Awaiting parts.	
REQUIREMENT:	363. Undefined Boiler Violations. Repair cracking. If welding is required a qualified 'R' certificate holder is necessary to perform the work.	

Location: (UNCC) Regional Utility Plt 5 **Location #:** 3968972 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-0564
Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC423477 - Boiler - Hurst - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	06/14/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. Forced fan impeller cracked and broken/awaiting repair parts	
REQUIREMENT:	363. Undefined Boiler Violations. Replace cracked and broken impeller on main forced air fan. Upon completion of repairs schedule a follow up inspection.	

Location: (WSSU) Albert Anderson Conference Center **Location #:** 1930965 **Violations:** 2
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC404281 - Boiler - Weil-McLain - 2015 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/20/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.

CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.

REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 04/20/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief Device (PRD) Leaking

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB Stamped PRD having a set pressure of 80 PSI or less and a relieving capacity of 3,709,00 BTU/Hour or more.

Location: (WSSU) Physical Plant

Location #: 1930976

Violations: 1

601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858

Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC229631 - Boiler - Kewanee - 1988 - Heating Plt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 05/23/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 275. Tube/tube ends leak.

CONDITION: 275. Boiler Components: Tube/tube ends leak.

REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (WSSU) Wilson Residence Hall

Location #: 1930987

Violations: 2

601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858

Contact: Winston Salem State University, Phone: 336-750-2858

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC263498 - Boiler - Peerless - 1993 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,748,000 BTU/Hour or more.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC374636 - Boiler - Weil-McLain - 2008 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,082,000 BTU/Hour or more.

ENTERED BY: Judd, Janie

CLOSED BY:

Location: (WU) Bridges Hall

Location #: 1880967

Violations: 1

216 Cedar St, , Wingate, NC 28174-5495, Phone: 800-755-5550

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC222281 - Boiler - Peerless - 1986 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 231. Leaking automatic gas valve.
CONDITION: 231. Burners and Fuel Supply Systems: Leaking automatic gas valve.
REQUIREMENT: 231. Repair or replace the leaking automatic gas valve.

ENTERED BY: Putek, Terry

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WU) New Stadium Training Bldg **Location #:** 1814520 **Violations:** 1
660 N Main St, , Wingate, NC 28174-6760, Phone: 704-233-8218
Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC297025 - Boiler - Eafco - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 001. Low water cutoff device not installed.
CONDITION: 001. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device not installed.
REQUIREMENT: 001. Equip the boiler with a low water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: (YANCEY CS) South Toe Elem **Location #:** 1830380 **Violations:** 1
166 S Toe School Rd, , Burnsville, NC 28714-8551, Phone: 828-675-4321
Contact: Attn Chris Howell, Yancey County Schools, Phone: 828-682-3066

Object: NC326313 - Boiler - Weil-McLain - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/10/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 273. Shell leaks.
CONDITION: 273. Boiler Components: Shell leaks.
REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: 3M Scott Fire & Safety **Location #:** 944950 **Violations:** 6
4320 Goldmine Rd, , Monroe, NC 28110-7355, Phone: 704-291-8300
Contact: Mike Elliott, 3M Scott Fire & Safety, Phone: 704-291-8300

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC384582 - PV - CP Industries - 2011 - Outside Bldg Near Comp - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Object: NC384583 - PV - CPC - 2011 - Outside - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD. There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Object: NC384584 - PV - CPC - 2011 - Outside - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 450. Pressure relieving devices not installed.
CONDITION: 450. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 450. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC384585 - PV - CPC - 2011 - Outside - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC384586 - PV - CPC - 2011 - Outside - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has not way to test the pressure relief device. No procedure in place to test or replace the pressure relief device.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has not way to test the pressure relief device. No procedure in place to test or replace the pressure relief device.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

Location: A Cleaner World #107

Location #: 1761441

Violations: 1

1009 2nd St NE, , Hickory, NC 28601-3843, Phone: 828-328-5900

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC391085 - Boiler - Parker - 2012 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Pressure Controls NCAC 13-13.0406
SUBCATEGORY 073. High limit pressure control inoperative.
CONDITION: 073. Pressure Controls NCAC 13-13.0406: High limit pressure control inoperative.
REQUIREMENT: 073. Repair or replace the inoperative high limit pressure control. Test to ensure proper operation.

Location: Abernathy United Methodist Church

Location #: 205930

Violations: 1

1418 Patton Ave, , Asheville, NC 28806-1722, Phone: 828-254-2612

Contact: Roy Richardson, Abernathy United Methodist Church, Phone: 828-713-6016

Object: NC358791 - Boiler - Weil-McLain - 2005 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 07/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler could not be started due to temperature.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when someone will be able to start boiler.

Location: Accu Fab Inc

Location #: 1761862

Violations: 1

801 Beacon Lake Dr, , Raleigh, NC 27610-1377, Phone: 919-390-4921

Contact: Attn Billy Creech, Facilities Mgr, Accu Fab Inc, Phone: 919-390-4921

Object: NC426245 - PV - Manchester - 2018 - Outside Right Side - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/23/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 030. Pressure gauge not installed.
CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not inoperable.
REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: BeoCare Group Inc **Location #:** 1772189 **Violations:** 1
1905 International Blvd, , Hudson, NC 28638-2734, Phone: 828-728-7300
Contact: There is no contact information available for this location.

Object: NC434653 - PV - Greenville - 1996 - Maintenance Shop - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 06/27/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 452. Set pressure too high.
CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.
REQUIREMENT: 452. Install a new ASME/NB stamped PRD having a set pressure of 73 PSI or less and a relieving capacity sufficient to fully relieve pressure on the steam cans should over-pressurization occur. Object must remain unpressurized until a new properly rated PRD is installed.

Location: Blue Ridge Tissue Corp **Location #:** 1163526 **Violations:** 1
1427 Yadkin River Rd, , Lenoir, NC 28645-9041, Phone: 828-757-7505
Contact: Attn Chad Shuford, Maintenance Supervisor, Blue Ridge Tissue Corp, Phone: 828-757-7505

Object: NC089494 - Boiler - Cleaver Brooks - 1969 - Blr House - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/06/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations: Boiler not operating at time of inspection; could not test low water cutoff (LWCO) and pressure relief device (PRD) to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the LWCO and PRD may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of the successful testing of these devices is also acceptable.

Location: Broughton Hospital New Hospital **Location #:** 3904479 **Violations:** 2
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: Bruce Elder, Maintenance Supervisor, Broughton Hospital New Hospital, Phone: 828 -608-4503

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414259 - Boiler - Cleaver Brooks - 2014 - NBH M-4 Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Object: NC414260 - Boiler - Cleaver Brooks - 2014 - NBH M-4 Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when safety devices can be tested to verify proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: Broughton Hospital Old Hospital
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: There is no contact information available for this location.

Location #: 1770791

Violations: 5

Object: NC038591 - PV - ADS - 1954 - Blr House Steam Plt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Manway gasket leaking.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace leaking manway gasket.

ENTERED BY: Putek, Terry
CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC039707 - PV - ADS - 1952 - Bsmt Service Bldg - Active

Violations This Object: 2

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	07-Undefined Pressure Vessels Violations		
SUBCATEGORY	479. Undefined Pressure Vessels Violations.		
CONDITION:	479. Undefined Pressure Vessels Violations. Manway gasket leaking.		
REQUIREMENT:	479. Undefined Pressure Vessels Violations. Replace leaking manway gasket.		
COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	07-Undefined Pressure Vessels Violations		
SUBCATEGORY	479. Undefined Pressure Vessels Violations.		
CONDITION:	479. Undefined Pressure Vessels Violations. Corrosion and leakage on vessel shell near tube bundle flange connection.		
REQUIREMENT:	479. Undefined Pressure Vessels Violations. Remove corrosion on vessel shell and make repairs as necessary to stop leakage.		

Object: NC387482 - Boiler - Peerless - 2011 - Gym Blr Rm - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.		
REQUIREMENT:	363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so that safety devices can be tested to verify proper operation.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC387483 - Boiler - Rbi - 2011 - Outside Chapel Bldg - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Candlewood Suites **Location #:** 1772649 **Violations:** 4
4433 Lead Mine Rd, , Raleigh, NC 27612-3324, Phone: 919-789-4840
Contact: Attn Kelvin Lee, Maint Eng, Candlewood Suites, Phone: 919-789-4840

Object: NC328040 - Boiler - Lochinvar - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Temperature & Pressure Gauge Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Object: NC328041 - Boiler - Lochinvar - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Temperature and Pressure Gauge Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC381477 - PV - Lochinvar - 2010 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 10-Thermometer NCAC 13-13.0410
SUBCATEGORY 111. Thermometer inoperative.
CONDITION: 111. Thermometer NCAC 13-13.0410: Thermometer inoperative.
REQUIREMENT: 111. Replace inoperative thermometer at/in the vessel outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

ENTERED BY: Fish, Emily

CLOSED BY:

Object: NC381478 - PV - Lochinvar - 2010 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 06/22/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 10-Thermometer NCAC 13-13.0410
SUBCATEGORY 111. Thermometer inoperative.
CONDITION: 111. Thermometer NCAC 13-13.0410: Thermometer inoperative.
REQUIREMENT: 111. Replace inoperative thermometer at/in the vessel outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

ENTERED BY: Fish, Emily

CLOSED BY:

Location: Carolina Meadows Retirement Community

Location #: 1773851

Violations: 1

100 Whippoorwill Ln, , Chapel Hill, NC 27517-8566, Phone: 919-942-4014

Contact: Carolina Meadows Retirement Community, Phone: 919-942-4014

Object: NC389631 - Boiler - Lochinvar - 2011 - Laundry - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 06/16/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

ENTERED BY: Keyes, Amanda

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Carolina Specialty Fabrics Plts 3 & 4
28 N Caldwell Ave, , Newton, NC 28658-2300, Phone: 828-464-1901
Contact: Billy Stallings, Maintenance Supervisor, Carolina Specialty Fabrics Plts 3 & 4, Phone: 828-464-1901

Location #: 1222959

Violations: 1

Object: NC249466 - PV - Wormald - 1989 - Plt 3 Comp Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 07/20/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Nameplate not attached to PRD.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Replace relief device with one set at pressure not exceeding MAWP.

Location: Dale Earnhardt Inc
1675 Dale Earnhardt Hwy Ste 3, , Mooresville, NC 28115-8330, Phone: 704-662-8000 X3311
Contact: Attn Bob Bauer, Shop Manager, Dale Earnhardt Inc, Phone: 704-662-8000 X3311, Cell:336-972-0393

Location #: 1781942

Violations: 1

Object: NC282929 - Boiler - Raypak - 1997 - Blr Rm WC 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 01/11/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations: Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

Location: Drakes Fresh Pasta Co
636 Southwest St, , High Point, NC 27260-8107, Phone: 336-861-5454
Contact: Attn Drew Weaver, Maintenance, Drakes Fresh Pasta Co, Phone: 336-862-7284 x-1, Cell:336-210-7478

Location #: 2685411

Violations: 1

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC416655 - Boiler - Hurst - 2018 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 06/06/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 271. Handhole plug leaks.
CONDITION: 271. Boiler Components: Handhole plug leaks: Three hand-hole gaskets leaking.
REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: First Citizens Bank

Location #: 1789027

Violations: 2

117 4th St NW, , Hickory, NC 28601-6144, Phone: 828-326-1100

Contact: Attn Derek Gooch, Facilities Manager, First Citizens Bank, Phone: 828-326-1184

Object: NC385797 - Boiler - Weil-McLain - 2011 - 2nd Flr Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/13/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/13/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Place boiler in operation. Contact inspector for follow up inspection.

Location: First Citizens Bank

Location #: 1789026

Violations: 1

4004 N Roxboro St, , Durham, NC 27704-2120, Phone: 919-471-8442

Contact: Attn Tricia Nunn, Attn Branch Facilities - DAC 41, First Citizens Bank, Phone: 919-716-7102

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC397250 - Boiler - Raypak - 2013 - Outside - Active

Violations This Object: 1

COMPANY: Travelers

INSPECTOR: Ford, Richard C.

OPENED: 03/24/2022

ENTERED BY: Ford, Richard C.

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Tube leaking on Boiler Heat Exchanger

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: First Citizens Bank

Location #: 2975699

Violations: 1

409 E Market St, , Smithfield, NC 27577-3921, Phone: 919-989-3200

Contact: Attn Tricia Nunn, Attn Branch Facilities - DAC 41, First Citizens Bank, Phone: 919-716-7102

Object: NC385255 - Boiler - Raypak - 2009 - Outside - Active

Violations This Object: 1

COMPANY: Travelers

INSPECTOR: Ford, Richard C.

OPENED: 09/03/2021

ENTERED BY: Ford, Richard C.

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 07-Undefined Controls Violations

SUBCATEGORY 112. Undefined Controls Violations.

CONDITION: 112. Undefined Controls Violations. Boiler not operating at time of inspection; Pressure Relief Device (PRD), flow switch and High Temperature Reset could not be tested to ensure proper operation.

REQUIREMENT: 112. Undefined Controls Violations. Schedule a follow up inspection at a time when the boiler is operating so that the Flow Switch, High Temperature switch and PRD may be tested to ensure proper operation. Richard Ford 919-901-9457

Location: Forest Heights Senior Living Community

Location #: 1815735

Violations: 2

2500 Polo Ridge Ct, , Winston Salem, NC 27106-3950, Phone: 336-722-7181

Contact: Attn Keith Gandolfo, Forest Heights Senior Living Community,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC435410 - Boiler - Lochinvar - 2021 - boiler room - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 06/06/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 212. Damper inoperative.
CONDITION: 212. Casing, Stack Breeching and Flue: Damper inoperative.
REQUIREMENT: 212. Repair or replace the damper.

Object: NC435411 - PV - Lochinvar - 2021 - Boiler Room - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 06/15/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 471. Discharge piping not properly supported.
CONDITION: 471. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 471. Support the relief valve discharge piping so it may not impose excessive stress on the valve.

contact Richard Parker @ 336-202-8341

Location: GE Global Nuclear Fuels America (Hartford) **Location #:** 176064 **Violations:** 1
3901 Castle Hayne Rd, Wilmington, NC 28402-1810, Phone: 910-675-5445
Contact: Attn David Thompson, Manager GNF-A Maintenance, GE Global Nuclear Fuels America, Phone: 910-675-

Object: NC262438 - Boiler - Chromalox - 1994 - FCO Pit - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 07/13/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule inspection when boiler is operating so safety devices can be verified to operate properly or disconnect power and water from boiler to render it inoperable.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: GemSeal Pavement Products **Location #:** 1792160 **Violations:** 3
139 S Walnut Cir, , Greensboro, NC 27409-2624, Phone: 336-854-8200
Contact: Attn Paul Nowlin, Maintenance, GemSeal Pavement Products, Phone: 336-854-8200

Object: NC214190 - Boiler - Industrial - 1986 - Blr Rm - Active **Violations This Object:** 3

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	07/08/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	272. Heads leak.	
CONDITION:	272. Boiler Components: Heads leak: hand hole plug leaking.	
REQUIREMENT:	272. Repair the leaking head. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	07/08/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	272. Heads leak.	
CONDITION:	272. Boiler Components: Heads leak: hand hole plug leaking.	
REQUIREMENT:	272. Repair the leaking head. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Leonard, Shannon D.	
OPENED:	07/08/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	272. Heads leak.	
CONDITION:	272. Boiler Components: Heads leak: hand hole plug leaking.	
REQUIREMENT:	272. Repair the leaking head. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.	

Location: Grace Lower Stone Church **Location #:** 1793630 **Violations:** 1
2410 Lower Stone Church Rd, , Rockwell, NC 28138-9487, Phone: 704-279-4176
Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC271413 - Boiler - Peerless - 1994 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 07/19/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

SUBCATEGORY 022. Faulty electrical wiring.

CONDITION: 022. LWCO and Flow Sensing Devices NCAC 13-13.0409: Faulty electrical wiring. LWCO failed to operate. Boiler shut down and secured.

REQUIREMENT: 022. Repair or replace the faulty electrical wiring and test control to ensure proper operation.

Location: Harrells Christian Academy

Location #: 1795838

Violations: 1

360 Tomahawk Hwy, , Harrells, NC 28444-0088, Phone: 910-532-4575

Contact: Attn Andy Well, Asst Headmaster, Harrells Christian Academy, Phone: 910-532-4575

Object: NC386994 - Boiler - Weil-McLain - 2011 - Rear Newkirk Auditorium
- Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 04/27/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: Hickory Chair Furniture Co Plt 7

Location #: 1222973

Violations: 3

37 9th Street Pl SE, , Hickory, NC 28602-1215, Phone: 828-679-2690

Contact: Attn Steve Brittain, Hickory Chair Furniture Co Plt 7, Phone: 828-679-2690

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC005523 - Boiler - Bigelow - 1957 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/07/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 003. Required manual reset low water cutoff device not installed.
CONDITION: 003. LWCO and Flow Sensing Devices NCAC 13-13.0409: Required manual reset low water cutoff device not installed.
REQUIREMENT: 003. Install a low-water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset; or install a manual reset on the existing low water fuel cutoff if appropriate. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC211121 - PV - Reco - 1964 - Outside Maintenance Shop - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/07/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 451. Inadequate relieving capacity.
CONDITION: 451. Installation of PRDs NCAC 13-13.0405: Inadequate relieving capacity.
REQUIREMENT: 451. Replace the pressure relieving device with one with a capacity adequate for the intended use.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/07/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 030. Pressure gauge not installed.
CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not installed.
REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

ENTERED BY: Judd, Janie

CLOSED BY:

ENTERED BY: Judd, Janie

CLOSED BY:

Location: Highlands Cashiers Hospital

Location #: 1797433

Violations: 3

190 Hospital Dr, , Highlands, NC 28741-7600, Phone: 828-526-1200

Contact: Attn Terry Winn, Plant Operations Manager, Highlands Cashiers Hospital, Phone: 828-526-1417, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC339009 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC339010 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC365479 - Boiler - Steris Corp - 2002 - OR Sub Sterile - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Location: HSM Solutions **Location #:** 4133910 **Violations:** 1
1505 13th St SW, , Hickory, NC 28602-4942, Phone: 828-328-2201
Contact: Attn Shawn Huffman, Head of Maintenance, HSM Solutions, Phone: 828-328-2201 ext 4645

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC343180 - PV - Silvan - 2002 - Comp Shed - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Hutchens, Mark

OPENED: 06/22/2022

ENTERED BY: Hutchens, Mark

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 453. Inlet pipe too small.

CONDITION: 453. Installation of PRDs NCAC 13-13.0405: Inlet pipe too small.

REQUIREMENT: 453. Replace the inlet line to provide for full size to the relief device.

Location: Import Auto Pro

Location #: 1930497

Violations: 1

826 S Main St, , Wake Forest, NC 27587-2808, Phone: 919-554-2400

Contact: Attn Rodney King, Owner, Import Auto Pro, Phone: 919-554-2400

Object: NC362963 - PV - Manchester - 2004 - Shop - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 07/06/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 037. Glass missing.

CONDITION: 037. Pressure Gauges NCAC 13-13.0407: Glass missing.

REQUIREMENT: 037. Replace glass or install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper size in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Innofa USA

Location #: 1813896

Violations: 1

716 Commerce Dr, , Eden, NC 27288-3681, Phone: 336-635-2911

Contact: Attn Eddie Wilson, Innofa USA, Phone: 336-394-8865

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC367251 - Boiler - Miura - 2007 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Parker, Richard

OPENED: 07/21/2022

ENTERED BY: Parker, Richard

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Overdue for internal inspection.

REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341

Location: John Umstead Hospital

Location #: 1802165

Violations: 1

1003 12th St, , Butner, NC 27509-1626, Phone: 919-575-7536

Contact: Attn Edd Lovette, John Umstead Hospital, Phone: 919-575-7971

Object: NC401217 - Boiler - Cleaver Brooks - 2014 - New Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 02/14/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 275. Tube/tube ends leak.

CONDITION: 275. Boiler Components: Tube/tube ends leak.

REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: McCarthy Tire Service

Location #: 1791610

Violations: 1

6853 Ward Blvd, , Wilson, NC 27893-5967, Phone: 252-243-0444

Contact: Attn Scott Littleton, Manager, McCarthy Tire Service, Phone: 252-243-0444

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC426232 - PV - Manchester - 2004 - Rear - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 07/15/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 07-Undefined Pressure Vessels Violations

SUBCATEGORY 479. Undefined Pressure Vessels Violations.

CONDITION: 479. Undefined Pressure Vessels Violations. Glass missing.

REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace glass or install a pressure gauge that is visible to the operator from floor or work platform. Gauge must be proper size in accordance with NC Administrative Code.

Location: Medicago USA

Location #: 3005097

Violations: 1

7 Triangle Dr, , Durham, NC 27709-0005, Phone: 919-313-9670

Contact: Medicago USA Inc, Phone: 919-532-0325 ext 1591

Object: NC387341 - Boiler - Raypak - 2011 - Roof Terrace - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Richey, Paul D.

OPENED: 02/08/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: National Guard Armory

Location #: 1813514

Violations: 1

700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512

Contact: National Guard Armory, Phone: 704-2835512

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 09/13/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 05-Temperature Controls NCAC 13-13.0406

SUBCATEGORY 093. High limit temperature control inoperative.

CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.

REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Location: NC Aquarium Dare Marine Research Ctr

Location #: 1812958

Violations: 1

374 Airport Rd, , Manteo, NC 27954-9485, Phone: 252-473-3494

Contact: NC Aquarium Dare Marine Research Ctr, Phone: 252-473-3494

Object: NC320865 - Boiler - State Industries - 1998 - Top Large Tank - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Harrell, Danny

OPENED: 05/12/2022

ENTERED BY: Harrell, Danny

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 11-Exp Tanks & Htng Sys Piping NCAC 13-13.0412

SUBCATEGORY 193. Leaking pipe/pipe joints.

CONDITION: 193. Exp Tanks & Htng Sys Piping NCAC 13-13.0412: Leaking pipe/pipe joints. Nipple between pressure relief valve and the vessel is leaking and has excessive corrosion visible.

REQUIREMENT: 193. Repair or replace leaking piping/pipe joints. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: NC School Of Science & Mathematics

Location #: 1813129

Violations: 1

1219 Broad St, , Durham, NC 27705-3577, Phone: 919-416-2672

Contact: NC School Of Science & Mathematics, Phone: 919-416-2793

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC212851 - Boiler - Kewanee - 1984 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 02/09/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: NCRC NC Research Campus **Location #:** 2385708 **Violations:** 1
600 Laureate Way, , Kannapolis, NC 28081-3374, Phone: 704-250-5017
Contact: Randall Keller, Facilities Technician, NCRC NC Research Campus, Phone: 704-250-5420, Cell:704-785-

Object: NC372891 - Boiler - Bryan - 2008 - Penthouse - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Coley, Oscar
OPENED: 06/01/2022 **ENTERED BY:** Coley, Oscar
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)
REQUIREMENT: 363. Undefined Boiler Violations. Boiler has to be running to perform a safety check of controls.

Location: NCRC UNC Nutrition Research Institute **Location #:** 2212698 **Violations:** 1
500 Laureate Way, , Kannapolis, NC 28081-3379, Phone: 704-250-5017
Contact: Charles Kraus, Facilities Operations/Zone 7 Supervisor, UNC Charlotte, Phone: 704-250-5017, Cell:980-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC371947 - Boiler - Bryan - 2007 - Penthouse - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Coley, Oscar

OPENED: 06/01/2022

ENTERED BY: Coley, Oscar

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)

REQUIREMENT: 363. Undefined Boiler Violations. Required yearly running inspection has to be performed with the boiler running.

Location: One Hour Klean

Location #: 1816368

Violations: 1

1785 W Webb Ave, , Burlington, NC 27217-1141, Phone: 336-228-8013

Contact: Attn Jeff Bowland, Manager, One Hour Klean Inc, Phone: 336-228-8013

Object: NC296883 - Boiler - Hurst - 1999 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Parker, Richard

OPENED: 07/13/2022

ENTERED BY: Parker, Richard

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.

CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.

REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

contact Richard Parker @ 336-202-8341

Location: Prestige Green Cleaners

Location #: 1820120

Violations: 1

1821 Hillandale Rd Ste 18, , Durham, NC 27705-2671, Phone: 919-309-4400

Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC390740 - PV - Manchester - 2004 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 07/06/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 037. Glass missing.

CONDITION: 037. Pressure Gauges NCAC 13-13.0407: Glass missing.

REQUIREMENT: 037. Replace glass or install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper size in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Scrub Board

Location #: 1827775

Violations: 1

104 Turner Dr, , Reidsville, NC 27320-5700, Phone: 336-623-3347

Contact: Attn Bob Nickelston, Bobs Enterprises, Phone: 276-634-7131, Cell:276-634-7131

Object: NC263537 - Boiler - Weben Jarco - 1989 - Rear Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Parker, Richard

OPENED: 07/08/2022

ENTERED BY: Parker, Richard

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 391. Discharge piping not properly supported.

CONDITION: 391. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.

REQUIREMENT: 391. Support the relief valve discharge piping so it may not impose excessive stress on the relief valve.

contact Richard Parker @ 336-202-8341

Location: Shores Fine Dry Cleaning

Location #: 1761480

Violations: 2

3918 Battleground Ave, , Greensboro, NC 27410-8499, Phone: 336-288-2400

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC383277 - Boiler - Parker - 2010 - Blr Rm - Active

Violations This Object: 2

COMPANY:	State of North Carolina		
INSPECTOR:	Johnson, Dean		
OPENED:	07/20/2022	ENTERED BY:	Johnson, Dean
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. This boiler is past due for an internal inspection.		
REQUIREMENT:	363. Undefined Boiler Violations. Contact your Insurer or this Inspector to schedule an internal boiler inspection.		
COMPANY:	State of North Carolina		
INSPECTOR:	Johnson, Dean		
OPENED:	07/20/2022	ENTERED BY:	Johnson, Dean
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	25-Operation of PRDs NCAC 13-13.0405		
SUBCATEGORY	391. Discharge piping not properly supported.		
CONDITION:	391. Operation of PRDs NCAC 13-13.0405: Safety valve discharge piping is not properly supported.		
REQUIREMENT:	391. Support the safety valve discharge piping so it may not impose excessive stress on the valve.		

Location: Siloam Cleaners

Location #: 1829224

Violations: 1

1415 Emerywood Dr, , Charlotte, NC 28210-4105, Phone: 704-553-1769

Contact: Attn Yong Chol Lee, Owner, Siloam Cleaners, Phone: 704-553-1769

Object: NC341562 - PV - Trinity - 2001 - Outside Rear - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Clay, Steven D.		
OPENED:	05/18/2022	ENTERED BY:	Judd, Janie
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	04-Installation of PRDs NCAC 13-13.0405		
SUBCATEGORY	452. Set pressure too high.		
CONDITION:	452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.		
REQUIREMENT:	452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer. The replacement valve must be ASME/NB certified.		

Location: Southern Resin

Location #: 1831002

Violations: 2

3440 Denton Rd, , Thomasville, NC 27360-6168, Phone: 336-475-1348

Contact: Attn Bill Hill, Manager, Southern Resin Inc, Phone: 336-475-1348

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC153039 - Boiler - Kewanee - 1976 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 271. Handhole plug leaks.

CONDITION: 271. Boiler Components: Handhole plug leaks.

REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/08/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Star America

Location #: 1832559

Violations: 1

190 Cabarrus Ave W, , Concord, NC 28025-5151, Phone: 704-788-4700

Contact: Star America Inc, Phone: 704-788-4700

Object: NC235426 - Boiler - Cleaver Brooks - 1979 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 07/06/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 18-Furnace and Fireside

SUBCATEGORY 302. Combustion chamber cracking.

CONDITION: 302. Furnace and Fireside: Combustion chamber cracking.

REQUIREMENT: 302. Repair the crack in the combustion chamber. If welding is required, a qualified "R" certificate holder is necessary to perform the work.

Location: Stephenson Millwork Co

Location #: 1832873

Violations: 1

210 Harper St NE, , Wilson, NC 27893-3307, Phone: 252-237-1141

Contact: Stephenson Millwork Co Inc, Phone: 252-237-1141

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC260903 - PV - John Wood - 1972 - Bldg 3 - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Harrell, Danny

OPENED: 07/15/2022

ENTERED BY: Harrell, Danny

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 030. Pressure gauge not installed.

CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not installed.

REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407. Install a 300 psi. pressure gauge. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: Temple Emanuel

Location #: 1835077

Violations: 1

713 N Greene St, , Greensboro, NC 27401-2025, Phone: 336-292-7899 X305

Contact: Attn Laura Denhardt, Temple Emanuel, Phone: 336-292-7899 X305, Cell:336-508-8660

Object: NC360688 - Boiler - Raypak - 2004 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/30/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Pressure Relief valve (PRD) leaking.

REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 160 PSI or less and a relieving capacity of 327,000 BTU/Hour or more.

Location: The Club At Oak Branch

Location #: 1821668

Violations: 1

21 Oak Branch Dr Ste A, , Greensboro, NC 27407-2145, Phone: 336-478-2660

Contact: Attn Josh Hughes, Manager, The Club At Oak Branch, Phone: 336-478-2660

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC299239 - PV - A O Smith - 1999 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 05/12/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 473. Valve stem distorted/bent.
CONDITION: 473. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent: Pressure relief device (PRD) valve steam bent.
REQUIREMENT: 473. Replace the damaged PRD with ASME/NB stamped temperature and pressure relieving type PRD having a set pressure of 160 PSI or less and a relieving capacity of 1,100,000 BTU/Hour. This PRD must also be designed to lift and relieve temperature and pressure at 210 degrees Fahrenheit.

Location: Time Financing Services

Location #: 1836465

Violations: 1

123 S Lamar St, , Roxboro, NC 27573-5205, Phone: 336-597-4444

Contact: Attn Allison Phelps, Manager, Time Financing Services, Phone: 336-597-4444

Object: NC215605 - Boiler - Teledynen Laars - 1986 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 07/07/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Boiler not operating
REQUIREMENT: 363. Operate boilers to allow testing of PRD

Location: Viewmont Baptist Church

Location #: 1840292

Violations: 1

1246 2nd St NE, , Hickory, NC 28601-2661, Phone: 828-322-6732

Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC397353 - Boiler - Weil-McLain - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 05/02/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative a detailed service report or boiler log that includes documentation of the successful testing of this devices is also acceptable.

Location: Walter B Jones Alcohol & Drug Treatment Ctr

Location #: 1841494

Violations: 2

2577 W 5th St, , Greenville, NC 27834-7813, Phone: 252-830-3426

Contact: Walter B Jones Alcohol & Drug Treatment Ctr, Phone: 252-707-5035

Object: NC370307 - Boiler - Weil-McLain - 2007 - Blr Rm Bldg 4 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 06/02/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC400181 - Boiler - Bradford White - 2009 - Cafeteria Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 06/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 393. Valve stem distorted/bent.
CONDITION: 393. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent.
REQUIREMENT: 393. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Windstream Communications **Location #:** 1779309 **Violations:** 2
68 Cabarrus Ave E, , Concord, NC 28025-3452, Phone: 704-722-2000
Contact: Attn Danny Craig, Group Leader, Windstream Communications, Phone: 704-722-2000

Object: NC348334 - Boiler - Peerless - 2003 - Bsmt Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/22/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule for another inspection when boiler is running.

Object: NC405385 - Boiler - Peerless - 2015 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 04/22/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations: Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule for another inspection when boiler is running.

Violations This Report: 122

Locations This Report: 81