

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: (BELMONT ABB) The Haid **Location #:** 1063340 **Violations:** 1
100 Belmont Mount Holly Rd, , Belmont, NC 28012-2702, Phone: 704-820-0726
Contact: Belmont Abbey College, Phone: 704-461-6466

Object: NC354064 - Boiler - Hurst - 2004 - Blr Shed Outside - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 09/13/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 018. Drain valve inoperative.
CONDITION: 018. LWCO and Flow Sensing Devices NCAC 13-13.0409: Drain valve inoperative.
Drain valve was stuck and would not open to allow testing.
REQUIREMENT: 018. Repair or replace the inoperable drain valve on the low water fuel cutoff control
and test to ensure proper operation.

Location: (CABARRUS CS) Carl A Furr Elem **Location #:** 2002374 **Violations:** 1
2725 Clover Rd NW, , Concord, NC 28027-3804, Phone: 704-788-4300
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC364598 - Boiler - Weil-McLain - 2006 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 02/15/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. The installer put the wrong ASME nameplate on.
REQUIREMENT: 363. Undefined Boiler Violations. Customer is to obtain and fill out the needed form
and have the manufacturer send the correct AMSE nameplate for attachment.

Location: (COLUMBUS CS) Acme Delco Elem **Location #:** 1761932 **Violations:** 1
16337 Old Lake Rd, , Riegelwood, NC 28456-7077, Phone: 910-655-2957
Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC252134 - Boiler - Weil-McLain - 1990 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 11/04/2021

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (DPS-C) Alexander CI - 4870

Location #: 1762873

Violations: 2

633 Old Landfill Rd, , Taylorsville, NC 28681-8420, Phone: 828-632-1331

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC414237 - Boiler - Cleveland Range - 2017 - Kitchen - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408

SUBCATEGORY 058. Leaking.

CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.

REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation.

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 271. Handhole plug leaks.

CONDITION: 271. Boiler Components: Handhole plug leaks.

REQUIREMENT: 271. Replace the leaking gasket. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Craven CI - 3085

Location #: 1780808

Violations: 1

600 Alligator Rd, , Vanceboro, NC 28586-7788, Phone: 252-244-3337

Contact: Steve Delisle, Maint Manager, Craven CI - 3085, Phone: 252-244-8360

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC407733 - Boiler - Cleveland Range - 2014 - Kitchen - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/22/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so safety devices can be tested for proper operation.

Location: (DPS-C) Franklin CC - 4215 **Location #:** 1790986 **Violations:** 1
5918 NC 39 Hwy S, , Bunn, NC 27508-6106, Phone: 919-496-6119
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC368959 - Boiler - Smith Cast Iron - 2006 - Dorm 4 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 06/17/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (DPS-C) Greene CI - 4140 **Location #:** 1794097 **Violations:** 1
2699 Hwy 903 N, , Snow Hill, NC 28580-7639, Phone: 252-747-3676
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC393589 - Boiler - Cleveland Range - 2012 - Kitchen - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/23/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so safety devices can be tested for proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (DPS-C) Lanesboro CI - 4865 **Location #:** 1805021 **Violations:** 1
552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Object: NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/01/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler can not run due to faulty modulating motor. Part is on order with C&C Boiler but is currently not available to nation wide parts shortage. Boiler is not in use and tagged out.
REQUIREMENT: 363. Undefined Boiler Violations. Repair boiler as required. Part needed to repair is on backorder.

Location: (DPS-C) Lanesboro Minimum CI - 3510 **Location #:** 1770840 **Violations:** 1
248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622
Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Object: NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 07/19/2021 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 378. Discharge opening directed improperly.
CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.
REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (DPS-C) Morrison CI - 3930 **Location #:** 1811980 **Violations:** 2
1573 McDonald Church Rd, , Hoffman, NC 28347-9011, Phone: 910-281-3161
Contact: Lee Snell, Maintenance, Morrison CI - 3930, Phone: 910-281-3161 X275

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC373350 - PV - Rbi - 2006 - Chance 208 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 08/30/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. PRD did not reseal after testing.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Replace PRD with one set at pressure not exceeding MAWP determined by manufacturer. The replacement valve must be ASME/NB certified.

ENTERED BY: Putek, Terry

CLOSED BY:

Object: NC373352 - PV - Rbi - 2006 - Sills 208 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 08/30/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Leak noted at top.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Repair corrosion. if welding is required, a qualified 'R' certificate holder is necessary to perform work.

ENTERED BY: Putek, Terry

CLOSED BY:

Location: (DPS-C) Swannanoa CCW - 4635

Location #: 2329543

Violations: 7

55 Lake Eden Rd, , Black Mountain, NC 28711-8706, Phone: 828-499-1137

Contact: David Lawing, Maintenance Supervisor, Swannanoa CCW - 4635, Phone: 828 259 6020

Object: NC113069 - Boiler - Kewanee - 1970 - Cafeteria Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Leaking at McDonnell Miller gasket.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

ENTERED BY: Putek, Terry

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC117313 - Boiler - Kewanee - 1970 - Frye Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC380987 - Boiler - Lochinvar - 2008 - Gill Dorm Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC435596 - Boiler - A O Smith - 2021 - Greenwood - Active **Violations This Object:** 4

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 030. Pressure gauge not installed.
CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not installed.
REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 08-Main Steam System NCAC 13-13.0411
SUBCATEGORY 121. Required stop valve(s) not installed on heating boiler.
CONDITION: 121. Main Steam System NCAC 13-13.0411: Required stop valve(s) not installed on heating boiler.
REQUIREMENT: 121. Install stop valves that meet the requirements of the ASME Boiler and Pressure Vessel Code, Section IV.

ENTERED BY: Judd, Janie
CLOSED BY:

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

ENTERED BY: Judd, Janie
CLOSED BY:

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Hot water inlet/outlet backward/reversed.
REQUIREMENT: 363. Undefined Boiler Violations. Arrange the water flow of the boiler so the water is flowing in the proper direction - into the inlet and out of the outlet as marked on the boiler.

ENTERED BY: Judd, Janie
CLOSED BY:

Location: (DPS-C) Tyrrell PWF - 3070

Location #: 1838377

Violations: 1

620 Snell Rd, , Columbia, NC 27925-8211, Phone: 252-796-1085

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414550 - Boiler - A O Smith - 2015 - Visitation - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 09/21/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 270. Water Leaks.

CONDITION: 270. Boiler Components: Water Leaks.

REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (ECU) Facility Steam Plt

Location #: 1838951

Violations: 1

700 E 14th St, , Greenville, NC 27858-3503, Phone: 252-328-4046

Contact: East Carolina University, Phone: 252-328-6594, Cell:252-328-2041

Object: NC349781 - Boiler - Babcock & Wilcox - 2002 - Blr Rm 14th St - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Smith, Jeremy

OPENED: 09/21/2022

ENTERED BY: Smith, Jeremy

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 3/12/2021.

REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: (ECU) Rawl Bldg

Location #: 2157395

Violations: 1

1001 E 5th St, , Greenville, NC 27858-2500, Phone: 252-328-6594

Contact: East Carolina University, Phone: 252-328-6594, Cell:252-328-2041

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC334299 - PV - Trane - 1996 - Mech Rm 147 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 08/22/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 460. Seals broken/ missing.

CONDITION: 460. Installation of PRDs NCAC 13-13.0405: Seals broken/ missing. PRD tamper seal missing.

REQUIREMENT: 460. Replace the relief valve with one with an ASME/NB certified valve.

Location: (ELON UNIV) Mosely Hall

Location #: 3012209

Violations: 1

100 Campus Dr, , Elon, NC 27244-9423, Phone: 336-278-5457

Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Object: NC386797 - Boiler - Raypak - 2011 - Blr Rm Loading Dock - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/21/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection so that safety devices could be tested for proper operation.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so that safety devices can be tested to verify proper operation.

Location: (ELON UNIV) Schar Center

Location #: 3851053

Violations: 2

542 N Williamson Ave, , Elon, NC 27244-9157, Phone: 336-675-9403

Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC415449 - Boiler - AIC Gdynia - 2017 - Blr #2 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation so that safety devices could be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

Object: NC415450 - Boiler - AIC Gdynia - 2015 - Blr #3 Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/21/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection to verify proper operation of safety devices.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

Location: (GREENE) Health Dept **Location #:** 1794007 **Violations:** 2
227 Kingold Blvd Ste B, , Snow Hill, NC 28580-1303, Phone: 252-747-8183
Contact: Greene County Government, Phone: 252-747-5720

Object: NC275963 - Boiler - H B Smith - 1994 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/02/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 05/02/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. BOILER NOT OPERATING
REQUIREMENT: 363. Rescheduled inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (LENOIR CS) North Lenoir High **Location #:** 1815064 **Violations:** 1
2400 Institute Rd, , La Grange, NC 28551-6716, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC287096 - Boiler - Lochinvar - 1997 - Kitchen Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/08/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Boiler not operating.
REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that boiler safety devices can be verified to operate properly.

Location: (LENOIR CS) Northwest Elem **Location #:** 1815337 **Violations:** 1
1701 Old Well Rd, , Kinston, NC 28504-2600, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC041545 - Boiler - NRC - 1957 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/07/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Boiler Not operating
REQUIREMENT: 363. Reschedule inspection for a time when the boiler is operating so that system safety devises can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (LENOIR CS) Rochelle Middle **Location #:** 1825083 **Violations:** 2
301 N Rochelle Blvd, , Kinston, NC 28501-5240, Phone: 252-527-1407
Contact: Attn Larry Modlin, Lenoir County Public Schools, Phone: 252-527-1407

Object: NC065774 - Boiler - Fitzgibbon - 1962 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/08/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (MARTIN CS) Rodgers Elem **Location #:** 1825274 **Violations:** 1
2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637
Contact: Martin County Schools, Phone: 252-792-1575

Object: NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 10/19/2021 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (UNC-CH) Ambulatory Care Ctr-241 **Location #:** 1883838 **Violations:** 2
102 Mason Farm Rd, , Chapel Hill, NC 27514-4617, Phone: 919-962-1271
Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC398891 - PV - Steris Corp - 2010 - OR 5 Sub Sterile Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Pressure vessel has not operated and can not be tested while not in operation.
REQUIREMENT: 479. Operate this pressure vessel for testing or remove it from service.

Object: NC398892 - PV - Steris Corp - 2010 - OR 7 Sub Sterile Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/01/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Pressure vessels has not operated and can not be tested while not in operation.
REQUIREMENT: 479. Operate this pressure vessel or remove it from service.

Location: (UNC-CH) Research Resource Farm Hse-460C **Location #:** 1838504 **Violations:** 1
1907 Orange Chapel Clover Garden Rd, , Chapel Hill, NC 27516-7317, Phone: 919-843-8771
Contact: Attn Larry Peoples, Manager, UNC Chapel Hill - Giles Horney Bldg 168, Phone: 919-843-8771

Object: NC344935 - Boiler - Peerless - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 04/12/2022 **ENTERED BY:** Keyes, Amanda
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 370. Pressure relieving devices not installed.
CONDITION: 370. Installation of PRDs NCAC 13-13.0405: Pressure relieving devices not installed.
REQUIREMENT: 370. Install a pressure relieving device in accordance with NCAC 13-13.0405.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (UNCC) Facilities Operations **Location #:** 2550379 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-2199
Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC331573 - Boiler - Aerco - 2004 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	11/10/2021	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. HX cracked. Unit tagged out. Awaiting parts.	
REQUIREMENT:	363. Undefined Boiler Violations. Repair cracking. If welding is required a qualified 'R' certificate holder is necessary to perform the work.	

Location: (UNCC) Regional Utility Plt 5 **Location #:** 3968972 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-0564
Contact: Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

Object: NC423477 - Boiler - Hurst - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	06/14/2022	ENTERED BY: Judd, Janie
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. Forced fan impeller cracked and broken/awaiting repair parts	
REQUIREMENT:	363. Undefined Boiler Violations. Replace cracked and broken impeller on main forced air fan. Upon completion of repairs schedule a follow up inspection.	

Location: (UNCP) Jones Health & Physical Ed Center **Location #:** 1931134 **Violations:** 1
1 University Rd, , Pembroke, NC 28372-8699, Phone: 910-521-6000
Contact: Attn Dean Jacobs P0079486, Facilities Operations Supervisor, UNC Pembroke, Phone: 910-775-4658,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC399031 - Boiler - Lochinvar - 2012 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 08/31/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not operating.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is in operation so the safety devices can be tested for proper operation.

Location: (UNCP) Moore Hall

Location #: 1931139

Violations: 1

1 University Rd, , Pembroke, NC 28372-8699, Phone: 910-521-6000

Contact: Attn Dean Jacobs P0079486, Facilities Operations Supervisor, UNC Pembroke, Phone: 910-775-4658,

Object: NC358389 - Boiler - Lochinvar - 2005 - Mech Rm #115 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Rudolph, Jay

OPENED: 09/01/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (UNCSA) C-D Residence Hall

Location #: 1931225

Violations: 1

1533 S Main St, , Winston Salem, NC 27127-2738, Phone: 336-770-3323

Contact: Attn Chris Bowman, Facilities Manager, UNC School Of The Arts, Phone: 336-345-9857

Object: NC309013 - Boiler - Raypak - 1998 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 07/27/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 277. Other component leaking.

CONDITION: 277. Boiler Components: Other component leaking. Boiler heat exchanger leaking.

REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: (UNCSA) Watson Chamber Music Hall **Location #:** 1931236 **Violations:** 2
1533 S Main St, , Winston Salem, NC 27127-2738, Phone: 336-770-3323
Contact: Attn Chris Bowman, Facilities Manager, UNC School Of The Arts, Phone: 336-345-9857

Object: NC347938 - Boiler - Bryan - 2002 - Mech Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/27/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 003. Required manual reset low water cutoff device not installed.
CONDITION: 003. LWCO and Flow Sensing Devices NCAC 13-13.0409: Required manual reset low water cutoff device not installed. LWCO not equipped with manual reset switch.
REQUIREMENT: 003. Install a low-water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset; or install a manual reset on the existing low water fuel cutoff if appropriate. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/27/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 393. Valve stem distorted/bent.
CONDITION: 393. Operation of PRDs NCAC 13-13.0405: Valve stem distorted/bent. Try lever broken on one of boilers PRDs.
REQUIREMENT: 393. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (WCU) Steam Plant **Location #:** 1832783 **Violations:** 5
111 Central Dr, , Cullowhee, NC 28723-9500, Phone: 828-227-3583
Contact: Mike Hoyle, Plant Supervisor, WCU Steam Plant, Phone: 828-227-3583

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC085790 - Boiler - Babcock & Wilcox - 1966 - Blr Rm Blr 2 - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Kirkman, Sam
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler internal inspection not performed per 13 NCAC 13 .0211 (b). An internal inspection must be performed on each high pressure boiler annually.

ENTERED BY: Kirkman, Sam
CLOSED BY:

REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the internal inspection. You may also contact the Boiler Safety Bureau for assistance.

Object: NC093989 - Boiler - Babcock & Wilcox - 1969 - Power House - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Kirkman, Sam
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler internal inspection not performed per 13 NCAC 13 .0211 (b). An internal inspection must be performed on each high pressure boiler annually.

ENTERED BY: Kirkman, Sam
CLOSED BY:

REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the internal inspection. You may also contact the Boiler Safety Bureau for assistance.

Object: NC410731 - Boiler - Bryan - 2016 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Kirkman, Sam
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler internal inspection not performed per 13 NCAC 13 .0211 (b). An internal inspection must be performed on each high pressure boiler annually.

ENTERED BY: Kirkman, Sam
CLOSED BY:

REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the internal inspection. You may also contact the Boiler Safety Bureau for assistance.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC410732 - Boiler - Bryan - 2016 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Kirkman, Sam
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler internal inspection not performed per 13 NCAC 13 .0211 (b). An internal inspection must be performed on each high pressure boiler annually.
REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the internal inspection. You may also contact the Boiler Safety Bureau for assistance.

ENTERED BY: Kirkman, Sam

CLOSED BY:

Object: NC410733 - Boiler - Bryan - 2016 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Kirkman, Sam
OPENED: 08/18/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler internal inspection not performed per 13 NCAC 13 .0211 (b). An internal inspection must be performed on each high pressure boiler annually.
REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the internal inspection. You may also contact the Boiler Safety Bureau for assistance.

ENTERED BY: Kirkman, Sam

CLOSED BY:

Location: (WFU) Worrell Professional Center

Location #: 1900171

Violations: 1

1834 Wake Forest Rd, , Winston Salem, NC 27109-6000, Phone: 336-758-3488

Contact: Attn Jimmy Nifong, Utilities Manager, Wake Forest University, Phone: 336-758-3332, Cell:336-757-6628

Object: NC258712 - Boiler - Superior Boiler Works - 1991 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/08/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed. Secondary LWCO inoperative.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

ENTERED BY: Putek, Terry

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WSSU) Albert Anderson Conference Center **Location #:** 1930965 **Violations:** 1
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC404281 - Boiler - Weil-McLain - 2015 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/28/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 005. No provision to test low water cutoff device.
CONDITION: 005. LWCO and Flow Sensing Devices NCAC 13-13.0409: No provision to test low water cutoff device.
REQUIREMENT: 005. Equip the low water fuel cutoff device on the boiler with a vertical drain and blow-off valve assembly of not less than 3/4-inch nominal pipe size to allow for flushing and testing of the low water cutoff while the boiler is in operation.

Location: (WSSU) Wilson Residence Hall **Location #:** 1930987 **Violations:** 1
601 S Martin Luther King Jr Dr, , Winston Salem, NC 27110-0003, Phone: 336-750-2858
Contact: Winston Salem State University, Phone: 336-750-2858

Object: NC263498 - Boiler - Peerless - 1993 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 04/20/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure Relief Device (PRD) Leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 PSI or less and a relieving capacity of 1,748,000 BTU/Hour or more.

Location: (WU) Bridges Hall **Location #:** 1880967 **Violations:** 1
216 Cedar St, , Wingate, NC 28174-5495, Phone: 800-755-5550
Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC222281 - Boiler - Peerless - 1986 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 231. Leaking automatic gas valve.
CONDITION: 231. Burners and Fuel Supply Systems: Leaking automatic gas valve.
REQUIREMENT: 231. Repair or replace the leaking automatic gas valve.

Location: (WU) New Stadium Training Bldg

Location #: 1814520

Violations: 1

660 N Main St, , Wingate, NC 28174-6760, Phone: 704-233-8218

Contact: Attn Richard Helms, Manager, Wingate University, Phone: 800-755-5550, Cell:704-507-1962

Object: NC297025 - Boiler - Eafco - 1998 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 11/15/2021
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 001. Low water cutoff device not installed.
CONDITION: 001. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device not installed.
REQUIREMENT: 001. Equip the boiler with a low water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: (YANCEY CS) South Toe Elem

Location #: 1830380

Violations: 1

166 S Toe School Rd, , Burnsville, NC 28714-8551, Phone: 828-675-4321

Contact: Attn Chris Howell, Yancey County Schools, Phone: 828-682-3066

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC326313 - Boiler - Weil-McLain - 2000 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Possidente, James

OPENED: 03/10/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 273. Shell leaks.

CONDITION: 273. Boiler Components: Shell leaks.

REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: 2001 Cleaners

Location #: 1760995

Violations: 1

1900 E 7th St, , Charlotte, NC 28204-2418, Phone: 704-332-2360

Contact: Attn Cooki Patel, Owner, 2001 Cleaners Inc, Phone: 704-332-2360, Cell:704-564-8782

Object: NC274245 - Boiler - P M Lattner - 1997 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Smith, Jeremy

OPENED: 09/21/2022

ENTERED BY: Smith, Jeremy

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 12/30/2020.

REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: 3M Scott Fire & Safety

Location #: 944950

Violations: 6

4320 Goldmine Rd, , Monroe, NC 28110-7355, Phone: 704-291-8300

Contact: Mike Elliott, 3M Scott Fire & Safety, Phone: 704-291-8300

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC384582 - PV - CP Industries - 2011 - Outside Bldg Near Comp - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie
CLOSED BY:

Object: NC384583 - PV - CPC - 2011 - Outside - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD. There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie
CLOSED BY:

Object: NC384584 - PV - CPC - 2011 - Outside - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 450. Pressure relieving devices not installed.
CONDITION: 450. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 450. Install a pressure relieving device in accordance with NCAC 13-13.0405.

ENTERED BY: Judd, Janie
CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC384585 - PV - CPC - 2011 - Outside - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has no way to test the Pressure Relief Device (PRD). There is no procedure in place to test or replace the PRD.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

Object: NC384586 - PV - CPC - 2011 - Outside - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has not way to test the pressure relief device. No procedure in place to test or replace the pressure relief device.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: This vessel has not way to test the pressure relief device. No procedure in place to test or replace the pressure relief device.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

ENTERED BY: Judd, Janie

CLOSED BY:

Location: A Cleaner World #107

Location #: 1761441

Violations: 1

1009 2nd St NE, , Hickory, NC 28601-3843, Phone: 828-328-5900

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC391085 - Boiler - Parker - 2012 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 06/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Pressure Controls NCAC 13-13.0406
SUBCATEGORY 073. High limit pressure control inoperative.
CONDITION: 073. Pressure Controls NCAC 13-13.0406: High limit pressure control inoperative.
REQUIREMENT: 073. Repair or replace the inoperative high limit pressure control. Test to ensure proper operation.

Location: A Cleaner World #108

Location #: 1761442

Violations: 1

130 New Market Blvd, , Boone, NC 28607-3989, Phone: 828-265-1888

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Object: NC384866 - Boiler - Parker - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 09/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler over due for a internal inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Boiler required a internal inspection ASAP .

Location: A Cleaner World #168

Location #: 1761459

Violations: 2

1949 Battleground Ave, , Greensboro, NC 27408-7123, Phone: 336-288-5312

Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031

Object: NC373476 - Boiler - Parker - 2008 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 08/19/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints. Probe type LWCO water column leaking at lower water gauge glass valve connection.
REQUIREMENT: 020. Replace gaskets as necessary and tighten mechanical joints to stop leakage.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 08/19/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 391. Discharge piping not properly supported.
CONDITION: 391. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 391. Support the relief valve discharge piping so it may not impose excessive stress on the relief valve.

Location: Abernathy United Methodist Church
1418 Patton Ave, , Asheville, NC 28806-1722, Phone: 828-254-2612
Contact: Roy Richardson, Abernathy United Methodist Church, Phone: 828-713-6016

Location #: 205930 **Violations:** 1

Object: NC358791 - Boiler - Weil-McLain - 2005 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 07/15/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler could not be started due to temperature.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when someone will be able to start boiler.

Location: American Cleaners
28 Penland St, , Canton, NC 28716-4312, Phone: 828-648-2817
Contact: Attn Tom Wilson, American Cleaners, Phone: 828-648-2817

Location #: 1763509 **Violations:** 1

Object: NC363636 - Boiler - Parker - 2006 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/03/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Waterside was not able to be opened during inspection. Owner did not have the proper wrench to remove plugs.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an internal inspection when waterside plugs can be removed.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: Bassett Upholstery Div Plt 2 **Location #:** 1766978 **Violations:** 2
1111 E 20th St, , Newton, NC 28658-1955, Phone: 828-465-7850
Contact: Richard Reese, Maintenance Supervisor, Bassett Upholstery Div Plt 2, Phone: 828-465-7850

Object: NC068459 - Boiler - Bigelow - 1964 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022 **ENTERED BY:** Smith, Jeremy
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 12/30/2020.
REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Object: NC224010 - Boiler - Superior Boiler Works - 1987 - Blr Rm 2 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022 **ENTERED BY:** Smith, Jeremy
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 12/30/2020.
REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: BeoCare Group Inc **Location #:** 1772189 **Violations:** 1
1905 International Blvd, , Hudson, NC 28638-2734, Phone: 828-728-7300
Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC434653 - PV - Greenville - 1996 - Maintenance Shop - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 08/16/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Black Mountain Neuro Medical Treatment Center **Location #:** 1768699 **Violations:** 1
932 Old US Hwy 70 W, , Black Mountain, NC 28711-2547, Phone: 828-259-6700
Contact: James Ayers, Boiler Rm Supervisor, Black Mountain Neuro Medical Treatment Center, Phone: 828-259-

Object: NC215734 - PV - Old Dominion - 1986 - Bldg 1 - Active **Violations This Object:** 1

COMPANY: Travelers
INSPECTOR: Johnson, Robert E.
OPENED: 06/24/2022 **ENTERED BY:** Johnson, Robert E.
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-Installation
SUBCATEGORY 415. Corrosion.
CONDITION: 415. Installation: Corrosion. Tank leaking due to age and corrosion.
REQUIREMENT: 415. Repair the corrosion if feasible. If welding is required, a qualified "R" certificate holder is necessary to perform the work. Replace tank if necessary.

Location: BP #9613 **Location #:** 1769945 **Violations:** 1
3611 Hillsborough St, , Raleigh, NC 27607-5408, Phone: 919-833-1100
Contact: BP Oil Inc, Phone: 910-592-3177

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC409802 - PV - Steel Fab - 2015 - Dumpster Area - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 09/12/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Inoperative pressure gauge.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Install a pressure gauge visible to the operator from the floor or work platform. Gauge must be proper range IAW NC Admin Code Title 13 Chapter 13 Section .0407.

Location: Brookdale Union Park **Location #:** 1839212 **Violations:** 1
1316 Patterson St, , Monroe, NC 28112-4348, Phone: 704-282-0530
Contact: There is no contact information available for this location.

Object: NC280130 - Boiler - Raypak - 1997 - Outside - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 09/14/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 394. Valve inoperative.
CONDITION: 394. Operation of PRDs NCAC 13-13.0405: Valve inoperative. PRD difficult to shut after testing.
REQUIREMENT: 394. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Broughton Hospital New Hospital **Location #:** 3904479 **Violations:** 2
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: Bruce Elder, Maintenance Supervisor, Broughton Hospital New Hospital, Phone: 828 -608-4503

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414259 - Boiler - Cleaver Brooks - 2014 - NBH M-4 Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection so that safety devices can be tested to verify proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Object: NC414260 - Boiler - Cleaver Brooks - 2014 - NBH M-4 Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when safety devices can be tested to verify proper operation.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: Broughton Hospital Old Hospital
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: There is no contact information available for this location.

Location #: 1770791

Violations: 5

Object: NC038591 - PV - ADS - 1954 - Blr House Steam Plt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Manway gasket leaking.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace leaking manway gasket.

ENTERED BY: Putek, Terry
CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC039707 - PV - ADS - 1952 - Bsmt Service Bldg - Active

Violations This Object: 2

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	07-Undefined Pressure Vessels Violations		
SUBCATEGORY	479. Undefined Pressure Vessels Violations.		
CONDITION:	479. Undefined Pressure Vessels Violations. Manway gasket leaking.		
REQUIREMENT:	479. Undefined Pressure Vessels Violations. Replace leaking manway gasket.		
COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	07-Undefined Pressure Vessels Violations		
SUBCATEGORY	479. Undefined Pressure Vessels Violations.		
CONDITION:	479. Undefined Pressure Vessels Violations. Corrosion and leakage on vessel shell near tube bundle flange connection.		
REQUIREMENT:	479. Undefined Pressure Vessels Violations. Remove corrosion on vessel shell and make repairs as necessary to stop leakage.		

Object: NC387482 - Boiler - Peerless - 2011 - Gym Blr Rm - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	Leonard, Shannon D.		
OPENED:	07/14/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.		
REQUIREMENT:	363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so that safety devices can be tested to verify proper operation.		

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC387483 - Boiler - Rbi - 2011 - Outside Chapel Bldg - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 07/14/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: C V Cleaners & Alterations **Location #:** 1772069 **Violations:** 1
508 10th St NW Ste I, , Conover, NC 28613-2339, Phone: 828-464-4337
Contact: Attn Chay Vue, Owner, C V Cleaners & Alterations Inc, Phone: 828-464-4337

Object: NC394376 - Boiler - Fulton - 2012 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/12/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 056. Gauge glass not provided with a drain.
CONDITION: 056. Water Gauge Glass NCAC 13-13.0408: Gauge glass not provided with a drain.
REQUIREMENT: 056. Provide a drain valve or cock and discharge outlet to the bottom most connection of the gauge glass and extend the gauge glass drain line to a point where its discharge will not endanger personnel.

Location: Carolina Specialty Fabrics Plts 3 & 4 **Location #:** 1222959 **Violations:** 1
28 N Caldwell Ave, , Newton, NC 28658-2300, Phone: 828-464-1901
Contact: Billy Stallings, Maintenance Supervisor, Carolina Specialty Fabrics Plts 3 & 4, Phone: 828-464-1901

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC249466 - PV - Wormald - 1989 - Plt 3 Comp Rm - Active		Violations This Object: 1
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	07/20/2022	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	06-Undefined Pressure Relieving Devices Violations	
SUBCATEGORY	478. Undefined Pressure Relieving Devices Violations.	
CONDITION:	478. Undefined Pressure Relieving Devices Violations. Nameplate not attached to PRD.	
REQUIREMENT:	478. Undefined Pressure Relieving Devices Violations. Replace relief device with one set at pressure not exceeding MAWP.	

Location: Cary Family YMCA **Location #:** 1774714 **Violations:** 1
101 Ymca Dr, , Cary, NC 27513-4871, Phone: 919-389-8666
Contact: Attn Brad Emory, Operations Director, Cary Family YMCA, Phone: 919-389-8666

Object: NC252955 - Boiler - Teledyne Laars - 1991 - Blr Rm - Active		Violations This Object: 1
COMPANY:	Hartford Steam Boiler	
INSPECTOR:	SORRENTINO, SEAN	
OPENED:	08/23/2022	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	24-Installation of PRDs NCAC 13-13.0405	
SUBCATEGORY	377. Try lever not installed.	
CONDITION:	377. Installation of PRDs NCAC 13-13.0405: Try lever not installed.	
REQUIREMENT:	377. Replace the relief valve with one with a try lever. The replacement valve must be ASME/NB certified.	

Location: Center For Marine Sciences & Technology **Location #:** 1775235 **Violations:** 1
303 College Cir, , Morehead City, NC 28557-2941, Phone: 252-222-6324
Contact: Attn Earnest Yeager, Facility Maintenance, Center For Marine Sciences & Technology, Phone: 252-222-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC320422 - Boiler - Bryan - 1999 - 1st Flr Blr Rm 138 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 08/23/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: Century Furniture Industries Plt 3 **Location #:** 1775642 **Violations:** 4
3086 Main Ave NW, , Hickory, NC 28601-5663, Phone: 828-326-8486
Contact: Attn Howard Martin, Manufacturing Engineer, Century Furniture Llc, Phone: 704-498-6880

Object: NC089455 - Boiler - Cleaver Brooks - 1968 - Blr Rm 1 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/21/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 17-Baffles and/or Refractory
SUBCATEGORY 292. Deteriorated.
CONDITION: 292. Baffles and/or Refractory: Deteriorated. Shelf baffle refractory on rear door deteriorated.
REQUIREMENT: 292. Repair or replace baffles or refractory.

Object: NC218594 - Boiler - Weil-McLain - 1986 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/21/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. Could not test LWCO and PRD.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so LWCO and PRD may be tested to verify proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 378. Discharge opening directed improperly.
CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. PRD installed in horizontal position.
REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405. Pipe PRD above boiler room floor and properly support discharge piping to prevent stress on PRD. Reinstall PRD in vertical position.

Object: NC337994 - PV - La Grange Products - 1990 - Comp Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Location: Clean Laundry Services **Location #:** 1879873 **Violations:** 1
2103 Sullivan St, , Greensboro, NC 27405-7331, Phone: 336-897-0008
Contact: Andrew Trauschke, Clean Laundry Services, Phone: 336-210-1255

Object: NC351212 - Boiler - Superior Boiler Works - 2003 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 08/31/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler overdue for internal inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an internal inspection as soon as possible.

Location: Dale Earnhardt Inc **Location #:** 1781942 **Violations:** 1
1675 Dale Earnhardt Hwy Ste 3, , Mooresville, NC 28115-8330, Phone: 704-662-8000 X3311
Contact: Attn Bob Bauer, Shop Manager, Dale Earnhardt Inc, Phone: 704-662-8000 X3311, Cell:336-972-0393

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC282929 - Boiler - Raypak - 1997 - Blr Rm WC 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 01/11/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations: Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

Location: Drury Inn & Suites Charlotte University Place

Location #: 1784354

Violations: 1

415 W W T Harris Blvd, , Charlotte, NC 28262-3343, Phone: 704-593-0700

Contact: Attn Doug Uzelac, General Manager, Drury Inn & Suites Charlotte University Place, Phone: 704-593-0700

Object: NC397051 - Boiler - Lochinvar - 2012 - Roof Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 08/31/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 394. Valve inoperative.

CONDITION: 394. Operation of PRDs NCAC 13-13.0405: Valve inoperative. PRD installed is too small capacity for this boiler.

REQUIREMENT: 394. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Dry Clean City

Location #: 1784363

Violations: 1

10911 Raven Ridge Rd Ste 101, , Raleigh, NC 27614-8363, Phone: 919-676-6020

Contact: Daxa Amin, Mgr, Dry Clean City, Phone: 919-676-6020

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC353680 - Boiler - Fulton - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 7/6/2020.
REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Dry Cleaning By Wayne

Location #: 1784383

Violations: 2

107 W Church St, , Tarboro, NC 27886-4308, Phone: 252-823-2361

Contact: There is no contact information available for this location.

Object: NC369159 - Boiler - Columbia - 2007 - Blr Rm - Active

Violations This Object: 2

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 08/04/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 08/04/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: First Citizens Bank **Location #:** 1789027 **Violations:** 1
117 4th St NW, , Hickory, NC 28601-6144, Phone: 828-326-1100

Contact: Attn Derek Gooch, Facilities Manager, First Citizens Bank, Phone: 828-326-1184

Object: NC385797 - Boiler - Weil-McLain - 2011 - 2nd Flr Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 06/13/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Place boiler in operation. Contact inspector for follow up inspection.

Location: First Citizens Bank **Location #:** 1789026 **Violations:** 1
4004 N Roxboro St, , Durham, NC 27704-2120, Phone: 919-471-8442

Contact: Attn Tricia Nunn, Attn Branch Facilities - DAC 41, First Citizens Bank, Phone: 919-716-7102

Object: NC397250 - Boiler - Raypak - 2013 - Outside - Active **Violations This Object:** 1

COMPANY: Travelers
INSPECTOR: Ford, Richard C.
OPENED: 03/24/2022 **ENTERED BY:** Ford, Richard C.
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Tube leaking on Boiler Heat Exchanger
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: First Citizens Bank **Location #:** 2975699 **Violations:** 1
409 E Market St, , Smithfield, NC 27577-3921, Phone: 919-989-3200

Contact: Attn Tricia Nunn, Attn Branch Facilities - DAC 41, First Citizens Bank, Phone: 919-716-7102

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC385255 - Boiler - Raypak - 2009 - Outside - Active

Violations This Object: 1

COMPANY: Travelers

INSPECTOR: Ford, Richard C.

OPENED: 09/03/2021

ENTERED BY: Ford, Richard C.

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 07-Undefined Controls Violations

SUBCATEGORY 112. Undefined Controls Violations.

CONDITION: 112. Undefined Controls Violations. Boiler not operating at time of inspection; Pressure Relief Device (PRD), flow switch and High Temperature Reset could not be tested to ensure proper operation.

REQUIREMENT: 112. Undefined Controls Violations. Schedule a follow up inspection at a time when the boiler is operating so that the Flow Switch, High Temperature switch and PRD may be tested to ensure proper operation. Richard Ford 919-901-9457

Location: First United Methodist Church

Location #: 1789445

Violations: 2

311 3rd Ave NE, , Hickory, NC 28601-5130, Phone: 828-324-2609

Contact: Fred Owens, Maintenance, First United Methodist Church, Phone: 828-324-2609

Object: NC385798 - Boiler - Weil-McLain - 2012 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 08/29/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not in operation due to warm weather and control system installed.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection during cooler weather.

Object: NC405415 - Boiler - Weil-McLain - 2015 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 08/29/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not in operation due to warm weather and control system installed.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection during cooler weather.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Governor Moorehead School **Location #:** 1793578 **Violations:** 1
301 Ashe Ave, , Raleigh, NC 27606-2102, Phone: 919-733-5535
Contact: Burt Young, Maintenance, Governor Moorehead School, Phone: 919-733-5535

Object: NC279480 - Boiler - Superior Boiler Works - 1996 - Blr House - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022 **ENTERED BY:** Smith, Jeremy
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 10/8/2020.
REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Grace Lower Stone Church **Location #:** 1793630 **Violations:** 1
2410 Lower Stone Church Rd, , Rockwell, NC 28138-9487, Phone: 704-279-4176
Contact: There is no contact information available for this location.

Object: NC271413 - Boiler - Peerless - 1994 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven D.
OPENED: 07/19/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 022. Faulty electrical wiring.
CONDITION: 022. LWCO and Flow Sensing Devices NCAC 13-13.0409: Faulty electrical wiring. LWCO failed to operate. Boiler shut down and secured.
REQUIREMENT: 022. Repair or replace the faulty electrical wiring and test control to ensure proper operation.

Location: Harrells Christian Academy **Location #:** 1795838 **Violations:** 1
360 Tomahawk Hwy, , Harrells, NC 28444-0088, Phone: 910-532-4575
Contact: Attn Andy Well, Asst Headmaster, Harrells Christian Academy, Phone: 910-532-4575

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Object: NC386994 - Boiler - Weil-McLain - 2011 - Rear Newkirk Auditorium - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Rudolph, Jay	
OPENED:	04/27/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	270. Water Leaks.	
CONDITION:	270. Boiler Components: Water Leaks.	
REQUIREMENT:	270. Repair the water leaks identified on the inspection report.	

Location: Hebron United Methodist Church **Location #:** 1796468 **Violations:** 1
2325 Mebane Oaks Rd, , Mebane, NC 27302-8616, Phone: 919-563-3375
Contact: Attn Jay Wilson, Maintenance, Hebron United Methodist Church, Phone: 336-213-3750

Object: NC065083 - Boiler - American Radiator - 1966 - Bsmt Blr Rm - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler		
INSPECTOR:	SORRENTINO, SEAN		
OPENED:	09/15/2022	ENTERED BY:	Putek, Terry
CLOSED:		CLOSED BY:	
TYPE:	Certificate Blocking		
CATEGORY:	23-Undefined Boiler Violations		
SUBCATEGORY	363. Undefined Boiler Violations.		
CONDITION:	363. Undefined Boiler Violations. Boiler not running during summer.		
REQUIREMENT:	363. Undefined Boiler Violations. Operate boiler for inspection.		

Location: Highlands Cashiers Hospital **Location #:** 1797433 **Violations:** 3
190 Hospital Dr, , Highlands, NC 28741-7600, Phone: 828-526-1200
Contact: Attn Terry Winn, Plant Operations Manager, Highlands Cashiers Hospital, Phone: 828-526-1417, Cell:828-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC339009 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC339010 - Boiler - Steris Corp - 2002 - OR Central Processing - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection
REQUIREMENT: 363. Undefined Boiler Violations. Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Object: NC365479 - Boiler - Steris Corp - 2002 - OR Sub Sterile - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/30/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was shut down and empty during external inspection.
REQUIREMENT: 363. Undefined Boiler Violations: Reschedule the boiler inspection for a day and time when the boiler can be started and pressurized.

Location: J Iverson Riddle Developmental Center **Location #:** 1843125 **Violations:** 1
300 Enola Rd, , Morganton, NC 28655-4608, Phone: 828-433-2771
Contact: Richie Mays, J Iverson Riddle Developmental Center, Phone: 828-433-2771

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC269223 - Boiler - Raypak - 1994 - Cedar Bldg Outside - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/19/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints. Flow switch leaking past protective baffles.
REQUIREMENT: 020. Replace gaskets as necessary and tighten mechanical joints to stop leakage. Replace flow switch and test for proper operation.

Location: Mabry Industries **Location #:** 1808920 **Violations:** 1
2903 Gibsonville Ossipee Rd, , Elon, NC 27244-9706, Phone: 336-584-1311
Contact: Mabry Industries Inc, Phone: 336-584-1311

Object: NC427389 - Boiler - Electro-Steam - 2007 - Plt Flr - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 08/25/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 055. Sediments/sludge in glass.
CONDITION: 055. Water Gauge Glass NCAC 13-13.0408: Sediments/sludge in glass.
REQUIREMENT: 055. Clean or replace gauge glass with material designed for temperature and service.

Location: Master Kleen Dry Cleaners **Location #:** 1808706 **Violations:** 1
119 Oakwood Dr, , Winston Salem, NC 27103-1903, Phone: 336-725-8402
Contact: Attn Todd Breedlove, Owner, Master Kleen Dry Cleaners, Phone: 336-725-8402

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC301483 - Boiler - Fulton - 1995 - Blr Rm - Active

Violations This Object: 1

COMPANY:	State of North Carolina	
INSPECTOR:	Parker, Richard	
OPENED:	08/18/2022	ENTERED BY: Parker, Richard
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Overdue for inspection.	
REQUIREMENT:	363. Contact inspector and schedule inspection	

contact Richard Parker @ 336-202-8341

Location: McMurray Fabrics Inc

Location #: 1809073

Violations: 2

1140 N Flint St, , Lincolnton, NC 28092-5238, Phone: 704-732-9613

Contact: Attn Mike Mills, Plant Engineer, McMurray Fabrics Inc, Phone: 704-732-9613 ext. 235, Cell:704-662-4527

Object: NC331553 - PV - Sclavos - 1997 - J12 - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	07/26/2022	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	06-Undefined Pressure Relieving Devices Violations	
SUBCATEGORY	478. Undefined Pressure Relieving Devices Violations.	
CONDITION:	478. Undefined Pressure Relieving Devices Violations. PRD is rated in cubic feet of air not PPH of steam.	
REQUIREMENT:	478. Undefined Pressure Relieving Devices Violations. Replace PRD with one set at a pressure not exceeding Mawp determined by manufacturer.	

Object: NC343167 - PV - Gcdmc - 1991 - M1 - Active

Violations This Object: 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Clay, Steven D.	
OPENED:	07/26/2022	ENTERED BY: Putek, Terry
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	06-Undefined Pressure Relieving Devices Violations	
SUBCATEGORY	478. Undefined Pressure Relieving Devices Violations.	
CONDITION:	478. Undefined Pressure Relieving Devices Violations. Lockwire on PRD broken.	
REQUIREMENT:	478. Undefined Pressure Relieving Devices Violations. Replace PRD with one set at pressure not exceeding Mawp determined by manufacturer.	

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:
Active; Order Results by: Location Name; Then Order by: Address;

Location: Medicago USA **Location #:** 3005097 **Violations:** 1
7 Triangle Dr, , Durham, NC 27709-0005, Phone: 919-313-9670
Contact: Medicago USA Inc, Phone: 919-532-0325 ext 1591

Object: NC387341 - Boiler - Raypak - 2011 - Roof Terrace - Active **Violations This Object:** 1

COMPANY:	Hartford Steam Boiler	
INSPECTOR:	Richey, Paul D.	
OPENED:	02/08/2022	ENTERED BY: Keyes, Amanda
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	16-Boiler Components	
SUBCATEGORY	270. Water Leaks.	
CONDITION:	270. Boiler Components: Water Leaks.	
REQUIREMENT:	270. Repair the water leaks identified on the inspection report.	

Location: Mills Cleaners **Location #:** 1816425 **Violations:** 1
1305 Skyway Dr, , Monroe, NC 28110-3003, Phone: 704-283-4384
Contact: Parker Mill, Mills Cleaners, Phone: 704-289-6426

Object: NC372098 - Boiler - Fulton - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY:	State of North Carolina	
INSPECTOR:	Smith, Jeremy	
OPENED:	09/21/2022	ENTERED BY: Smith, Jeremy
CLOSED:		CLOSED BY:
TYPE:	Certificate Blocking	
CATEGORY:	23-Undefined Boiler Violations	
SUBCATEGORY	363. Undefined Boiler Violations.	
CONDITION:	363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 2/24/2020.	
REQUIREMENT:	363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.	

Location: Mt Tabor United Methodist Church **Location #:** 1812531 **Violations:** 2
3543 Robinhood Rd, , Winston Salem, NC 27106-4703, Phone: 336-473-8484
Contact: Attn Steve Dyson, Facilities Manager, Mt Tabor United Methodist Church, Phone: 336-406-3573

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC267122 - Boiler - Weil-McLain - 1993 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon D.
OPENED: 09/07/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints.
REQUIREMENT: 020. Replace gaskets as necessary and tighten mechanical joints to stop leakage.

Object: NC435466 - Boiler - Bradford White - 2019 - Boiler Room - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 09/13/2022 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 210. Improper installation.
CONDITION: 210. Casing, Stack Breeching and Flue: Improper installation. Flue unsupported
REQUIREMENT: 210. Support flue and contact inspector for re-inspection.

contact Richard Parker @ 336-202-8341

Location: National Guard Armory **Location #:** 1813569 **Violations:** 1
500 E Morganton Rd, , Southern Pines, NC 28387-6528, Phone: 910-629-8747
Contact: Attn Blane Boyd, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Object: NC286714 - Boiler - Weil-McLain - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 08/15/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was not operating at time of inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler can be operated so safety devices can be verified to operate properly.

Location: National Guard Armory **Location #:** 1813514 **Violations:** 1
700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512
Contact: National Guard Armory, Phone: 704-2835512

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 09/13/2021

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 05-Temperature Controls NCAC 13-13.0406

SUBCATEGORY 093. High limit temperature control inoperative.

CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.

REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Location: NC School Of Science & Mathematics

Location #: 1813129

Violations: 1

1219 Broad St, , Durham, NC 27705-3577, Phone: 919-416-2672

Contact: NC School Of Science & Mathematics, Phone: 919-416-2793

Object: NC212851 - Boiler - Kewanee - 1984 - Main Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 02/09/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: NCRC NC Research Campus

Location #: 2385708

Violations: 1

600 Laureate Way, , Kannapolis, NC 28081-3374, Phone: 704-250-5017

Contact: Randall Keller, Facilities Technician, NCRC NC Research Campus, Phone: 704-250-5420, Cell:704-785-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC372891 - Boiler - Bryan - 2008 - Penthouse - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Coley, Oscar

OPENED: 06/01/2022

ENTERED BY: Coley, Oscar

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)

REQUIREMENT: 363. Undefined Boiler Violations. Boiler has to be running to perform a safety check of controls.

Location: NCRC UNC Nutrition Research Institute

Location #: 2212698

Violations: 1

500 Laureate Way, , Kannapolis, NC 28081-3379, Phone: 704-250-5017

Contact: Charles Kraus, Facilities Operations/Zone 7 Supervisor, UNC Charlotte, Phone: 704-250-5017, Cell:980-

Object: NC371947 - Boiler - Bryan - 2007 - Penthouse - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Coley, Oscar

OPENED: 06/01/2022

ENTERED BY: Coley, Oscar

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler overdue for a running inspection. (boiler is open and will not be put back together till winter)

REQUIREMENT: 363. Undefined Boiler Violations. Required yearly running inspection has to be performed with the boiler running.

Location: New Gilead Reformed Church

Location #: 1814329

Violations: 1

2400 Old Salisbury Rd, , Concord, NC 28025-1540, Phone: 704-782-9388

Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC351558 - Boiler - Burnham - 2003 - Bsmt Blr Door Always Unlocked - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 08/25/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not running at time of inspection.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is running so that safety devices can be tested for proper operation.

Location: Palziv North America

Location #: 1798543

Violations: 1

7966 NC 56 Hwy, , Louisburg, NC 27549-8633, Phone: 919-497-0010

Contact: Attn Frank Johnson, Facilities & Maintenance Manager, Palziv North America, Phone: 919-455-5117

Object: NC413101 - Boiler - Volcano - 2002 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Smith, Jeremy

OPENED: 09/21/2022

ENTERED BY: Smith, Jeremy

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 2/3/2021.

REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Perfection Dry Cleaners

Location #: 1818517

Violations: 1

10715 Park Rd Ste A, , Charlotte, NC 28210-8550, Phone: 704-541-3032

Contact: Attn Robert Jung, Owner, Perfection Dry Cleaners, Phone: 704-541-3032

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC274221 - Boiler - Columbia - 1996 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Smith, Jeremy

OPENED: 09/21/2022

ENTERED BY: Smith, Jeremy

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 12/18/2020.

REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Professional Rental Services

Location #: 1821288

Violations: 2

220 Frederick St, , Mount Airy, NC 27030-5602, Phone: 336-786-6148

Contact: Attn Mark Wilson, Maintenance, Professional Rental Services, Phone: 336-786-6148, Cell:336-755-7699

Object: NC394000 - Boiler - Cleaver Brooks - 1989 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 08/26/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408

SUBCATEGORY 056. Gauge glass not provided with a drain.

CONDITION: 056. Water Gauge Glass NCAC 13-13.0408: Gauge glass not provided with a drain.

REQUIREMENT: 056. Provide a drain valve or cock and discharge outlet to the bottom most connection of the gauge glass and extend the gauge glass drain line to a point where its discharge will not endanger personnel.

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 08/26/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 25-Operation of PRDs NCAC 13-13.0405

SUBCATEGORY 395. Valve leaking.

CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.

REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Randolph Asheboro YMCA **Location #:** 1822939 **Violations:** 3
343 NC Highway 42 N, , Asheboro, NC 27203-7919, Phone: 336-625-1976
Contact: Morris Ebanks, Maintenance, Randolph Asheboro YMCA, Phone: 336-629-1976

Object: NC435695 - Boiler - Pacific Steam - 2022 - Steam Rm - Active **Violations This Object:** 3

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 09/22/2022 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 056. Gauge glass not provided with a drain.
CONDITION: 056. Water Gauge Glass NCAC 13-13.0408: Sight glass is not provided with a drain valve and discharge pipe.
REQUIREMENT: 056. Install a drain valve and discharge outlet to the bottom most connection of the sight glass and extend the drain line to a point where its discharge will not endanger personnel.

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 09/22/2022 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency boiler shut off switch at the egress.
REQUIREMENT: 235. Install an emergency boiler shut off switch just outside or inside the egress from the boiler room to shut off the boiler. Switch must be marked with a sign indicating it as such.

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 09/22/2022 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 391. Discharge piping not properly supported.
CONDITION: 391. Operation of PRDs NCAC 13-13.0405: Safety valve discharge piping is not properly supported.
REQUIREMENT: 391. Support the safety valve discharge piping so it may not impose excessive stress on the valve.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Regency Cleaners & Laundromat **Location #:** 1823714 **Violations:** 1
3912 University Dr, , Durham, NC 27707-2518, Phone: 919-493-5815
Contact: Attn Mike Foley, Owner, White Star Laundry & Cleaners, Phone: 919-286-2271

Object: NC248230 - Boiler - P M Lattner - 1990 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: SORRENTINO, SEAN
OPENED: 08/25/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 275. Tube/tube ends leak.
CONDITION: 275. Boiler Components: Tube/tube ends leak.
REQUIREMENT: 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Ride With Pride Car Wash #8 **Location #:** 1824441 **Violations:** 3
163 Pride Dr, , Boone, NC 28607-5832, Phone: 828-264-4902
Contact: Roger Fox, Ride With Pride Car Wash #9, , Cell:828-320-6609

Object: NC339998 - Boiler - Raypak - 1984 - Equip Rm 1 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 07/26/2022 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit manual reset temperature control inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Object: NC339999 - Boiler - Raypak - 1984 - Equip Rm 1 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 07/26/2022 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC361623 - Boiler - Raypak - 2005 - Equip Rm 2 - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Hutchens, Mark

OPENED: 07/26/2022

ENTERED BY: Hutchens, Mark

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 12-Casing, Stack Breeching and Flue

SUBCATEGORY 211. Combustion gas leaks.

CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: Siloam Cleaners

Location #: 1829224

Violations: 1

1415 Emerywood Dr, , Charlotte, NC 28210-4105, Phone: 704-553-1769

Contact: Attn Yong Chol Lee, Owner, Siloam Cleaners, Phone: 704-608-9065

Object: NC341562 - PV - Trinity - 2001 - Outside Rear - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 05/18/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 452. Set pressure too high.

CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.

REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Stephenson Millwork Co

Location #: 1832873

Violations: 1

210 Harper St NE, , Wilson, NC 27893-3307, Phone: 252-237-1141

Contact: Stephenson Millwork Co Inc, Phone: 252-237-1141

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC260903 - PV - John Wood - 1972 - Bldg 3 - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Harrell, Danny

OPENED: 07/15/2022

ENTERED BY: Harrell, Danny

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 09-Pressure Gauges NCAC 13-13.0407

SUBCATEGORY 030. Pressure gauge not installed.

CONDITION: 030. Pressure Gauges NCAC 13-13.0407: Pressure gauge not installed.

REQUIREMENT: 030. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407. Install a 300 psi. pressure gauge. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: Swimmer Insurance Agency

Location #: 1834251

Violations: 1

725 Providence Rd, , Charlotte, NC 28207-2370, Phone: 704-333-6694

Contact: David A Swimmer, Swimmer Insurance Agency, Phone: 704-333-6694

Object: NC231974 - Boiler - Teledyne Laars - 1988 - Bsmt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 09/12/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.

REQUIREMENT: 363. Undefined Boiler Violations. Due to warm weather boiler being installed in 2 pipe system. Schedule an inspection when boiler can be placed in operation.

Location: The Carolina Inn

Location #: 1773803

Violations: 1

211 Pittsboro St, , Chapel Hill, NC 27516-2739, Phone: 919-933-2001

Contact: Attn Kevin Pollock, Engineer, The Carolina Inn, Phone: 919-933-2001

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC407783 - PV - Cemline - 2016 - Mech Rm 1 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 09/01/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 04-Installation of PRDs NCAC 13-13.0405

SUBCATEGORY 457. Try lever not installed.

CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed. Try Lever broken.

REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Location: Time Financing Services

Location #: 1836465

Violations: 1

123 S Lamar St, , Roxboro, NC 27573-5205, Phone: 336-597-4444

Contact: Attn Allison Phelps, Manager, Time Financing Services, Phone: 336-597-4444

Object: NC215605 - Boiler - Teledynen Laars - 1986 - Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: SORRENTINO, SEAN

OPENED: 07/07/2022

ENTERED BY: Keyes, Amanda

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Boiler not operating

REQUIREMENT: 363. Operate boilers to allow testing of PRD

Location: US 250 Cleaners

Location #: 1223210

Violations: 1

2785 Charlotte Hwy Ste 11, , Mooresville, NC 28117-9511, Phone: 704-799-3004/704-696-0006

Contact: Attn Grace Lee, Owner, US 250 Cleaners, Phone: 704-799-3004

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC376237 - Boiler - Fulton - 2009 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina

INSPECTOR: Smith, Jeremy

OPENED: 09/21/2022

ENTERED BY: Smith, Jeremy

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 2/26/2020.

REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Viewmont Baptist Church
1246 2nd St NE, , Hickory, NC 28601-2661, Phone: 828-322-6732
Contact: There is no contact information available for this location.

Location #: 1840292

Violations: 1

Object: NC397353 - Boiler - Weil-McLain - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 05/02/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

REQUIREMENT: 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative a detailed service report or boiler log that includes documentation of the successful testing of this devices is also acceptable.

Location: Wade Manufacturing Co
76 Mill St, , Wadesboro, NC 28170-2410, Phone: 704-694-2131
Contact: Wade Manufacturing Co, Phone: 704-694-2131

Location #: 1840985

Violations: 1

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC206516 - Boiler - Babcock & Wilcox - 1985 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022 **ENTERED BY:** Smith, Jeremy
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 4/1/2021.
REQUIREMENT: 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

Location: Wayne Farms Newton Feedmill **Location #:** 3475676 **Violations:** 1
332 E A St, , Newton, NC 28658-2304, Phone: 828-464-1611
Contact: Attn C Cassell, Wayne Farms Llc, Phone: 336-386-8151

Object: NC102786 - Boiler - BE&S - 1970 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Smith, Jeremy
OPENED: 09/21/2022 **ENTERED BY:** Smith, Jeremy
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection once every 12 months. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed within that timeframe. The last external inspection completed was 1/28/2020.
REQUIREMENT: 363. Undefined Boiler Violations.

Location: William G White Jr Family YMCA **Location #:** 1775591 **Violations:** 1
775 W End Blvd, , Winston Salem, NC 27101-2421, Phone: 336-721-2100
Contact: Attn Doug Mansfield, Associate Property Director, William G White Jr Family YMCA, Phone: 336-721-2100

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC137697 - Boiler - Weil-McLain - 1975 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Leonard, Shannon D.

OPENED: 09/07/2022

ENTERED BY: Putek, Terry

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 16-Boiler Components

SUBCATEGORY 277. Other component leaking.

CONDITION: 277. Boiler Components: Other component leaking. Leak of unknown origin.

REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Windstream Communications

Location #: 1779309

Violations: 2

68 Cabarrus Ave E, , Concord, NC 28025-3452, Phone: 704-722-2000

Contact: Attn Danny Craig, Group Leader, Windstream Communications, Phone: 704-722-2000

Object: NC348334 - Boiler - Peerless - 2003 - Bsmt Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/22/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.

REQUIREMENT: 363. Undefined Boiler Violations. Reschedule for another inspection when boiler is running.

Object: NC405385 - Boiler - Peerless - 2015 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler

INSPECTOR: Clay, Steven D.

OPENED: 04/22/2022

ENTERED BY: Judd, Janie

CLOSED:

CLOSED BY:

TYPE: Certificate Blocking

CATEGORY: 23-Undefined Boiler Violations

SUBCATEGORY 363. Undefined Boiler Violations.

CONDITION: 363. Undefined Boiler Violations: Boiler not running for inspection.

REQUIREMENT: 363. Undefined Boiler Violations: Reschedule for another inspection when boiler is running.

Violations This Report: 143

Locations This Report: 99