

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (ASU) Frank Hall **Location #:** 1879969 **Violations:** 1
342 Stadium Heights Dr, , Boone, NC 28608-0001, Phone: 828-262-8633
Contact: Eric Greer, Maintenance Manager, Appalachian State University, Phone: 828-262-3190 X120, Cell:828-262-

Object: NC376778 - PV - Precision - 2009 - Mech Rm 103 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/18/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 477. Try lever inoperative.
CONDITION: 477. Operation of PRDs NCAC 13-13.0405: Try lever inoperative. Try lever bent. Try lever will not properly engage valve stem to allow testing of PRD for proper operation.
REQUIREMENT: 477. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (ASU) Miles Annas Student Services **Location #:** 1880010 **Violations:** 1
614 Howard St, , Boone, NC 28608-0020, Phone: 828-262-8633
Contact: Eric Greer, Maintenance Manager, Appalachian State University, Phone: 828-262-3190 X120, Cell:828-262-

Object: NC202424 - PV - Bell & Gossett - 1979 - Infirmary - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/25/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 456. Shutoff valve installed in inlet/outlet line.
CONDITION: 456. Installation of PRDs NCAC 13-13.0405: Shutoff valve installed in inlet/outlet line. Shutoff valve installed in PRD inlet plumbing.
REQUIREMENT: 456. Remove the shutoff valve from the inlet/outlet line of the relief device.

Location: (BRUNSWICK CS) Cedar Grove Middle **Location #:** 2548413 **Violations:** 1
750 Grove Trl SW, , Supply, NC 28462-5180, Phone: 910-846-3400
Contact: Attn Kem Harmon, Maintenance Supervisor, Brunswick County Schools, Phone: 910-253-1069, Cell:910-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC376627 - Boiler - H B Smith - 2009 - Blr Rm Rear School Bldg - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (CABARRUS CS) Mary Francis Wall Center **Location #:** 1761630 **Violations:** 1
3801 US Highway 601 S, , Concord, NC 28025-8493, Phone: 704-788-2182
Contact: Cabarrus County Schools, Phone: 704-262-6239/704-786-6191

Object: NC335494 - Boiler - Weil-McLain - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Richey, Paul
OPENED: 02/05/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 277. Other component leaking.
CONDITION: 277. Boiler Components: Other component leaking. Boiler is leaking from the flange on the return piping of the boiler.
REQUIREMENT: 277. Repair the leaking component. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: (CASWELL) Historic Courthouse **Location #:** 1816015 **Violations:** 1
144 Court Sq, , Yanceyville, NC 27379-8005, Phone: 336-694-4193
Contact: Caswell County Government, Phone: 336-694-4193

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC305439 - Boiler - Weil-McLain - 1997 - Bsmt - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 12/13/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

Location: (CFCC) Applied Technologies Bldg

Location #: 3763969

Violations: 1

4820 Sidbury Rd, , Wilmington, NC 28405 , Phone: 910-362-7695

Contact: Attn Kal Marton, Maintenance Coordinator, Cape Fear Community College, Phone: 910-362-7353, Cell:

Object: NC411003 - Boiler - Lochinvar - 2016 - Blr Rm 2nd Flr - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/05/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (CHEROKEE CS) Andrews Elem

Location #: 1764013

Violations: 3

205 Walnut St, , Andrews, NC 28901-8061, Phone: 828-321-4415

Contact: Bobby Stalcup, Custodian, Andrews Elem, Phone: 828-321-4415

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC348083 - Boiler - Peerless - 2003 - Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/01/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 371. Inadequate relieving capacity.
CONDITION: 371. Installation of PRDs NCAC 13-13.0405: Inadequate relieving capacity. Requires 1618 Mbh.
REQUIREMENT: 371. Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Object: NC378486 - Boiler - Peerless - 2003 - Bsmt Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/01/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 10-Feedwater, Condensate/Rtrn Sys NCAC 13-13.0411
SUBCATEGORY 170. Check valve(s) not installed.
CONDITION: 170. Feedwater, Condensate/Rtrn Sys NCAC 13-13.0411: Check valve(s) not installed. Check valve missing water inlet.
REQUIREMENT: 170. Install a check valve in the inlet water line on the source side of the shutoff valve.

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/01/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 373. Inlet pipe too small.
CONDITION: 373. Installation of PRDs NCAC 13-13.0405: Inlet pipe too small.
REQUIREMENT: 373. Replace the inlet line to provide for full size to the relief device.

Location: (CHEROKEE CS) The Oaks Academy **Location #:** 1808162 **Violations:** 1
2230 Airport Rd, , Marble, NC 28905-8875, Phone: 828-938-5485
Contact: Attn Shawn Johnson, Cherokee County School District, Phone: 828-644-9325, Cell:828-557-4805

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC320071 - Boiler - Peerless - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (CLEVELAND CS II) Marion Elem **Location #:** 1808225 **Violations:** 2
410 Forest Hill Dr, , Shelby, NC 28150-5561, Phone: 704-487-5931
Contact: Attn Steve Boheler, Director of Plant Operations, Cleveland County Schools Div II, Phone: 704-476-8146,

Object: NC242463 - Boiler - Weil-McLain - 1989 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 02/08/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running, building not in use, owner may disconnect.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is running or disconnect boiler from all energy sources.

Object: NC254064 - PV - Manchester - 1990 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 02/08/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Vessel had no pressure, compressor not working, owner may disconnect.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Schedule an inspection when the compressor has pressure or disconnect vessel from all energy sources.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (CLINTON CS) Clinton High **Location #:** 2858341 **Violations:** 1
340 Indian Town Rd, , Clinton, NC 28328-1400, Phone: 910-592-8688
Contact: Clinton City Schools District, Phone: 910-592-8688

Object: NC381593 - PV - Lochinvar - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 11/04/2022 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Water pipes leaking.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Repair leaking pipes to prevent further corrosion of tank bottom. Call Derek Bailey @919-302-3166 when repairs are complete.

Location: (COLUMBUS CS) East Columbus High **Location #:** 1785232 **Violations:** 1
32 Gator Ln, , Lake Waccamaw, NC 28450-2257, Phone: 910-646-4094
Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Object: NC257092 - Boiler - Weil-McLain - 1992 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 10/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leakage from exhaust stack.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (COLUMBUS CS) West Columbus High **Location #:** 1842827 **Violations:** 1
7294 Andrew Jackson Hwy SW, , Cerro Gordo, NC 28430-9258, Phone: 910-654-6111
Contact: Attn Tim Ward, Plant Operations, Columbus County Schools, Phone: 910-642-0161, Cell:910-770-2303

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC308726 - Boiler - Weil-McLain - 1999 - Auditorium - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 10/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Immediately replace PRD with an ASME/NB certified PRD with a set pressure of not greater than 50 psig, with a relief capacity of not less that 690 Kbh and with a testing lever.

Location: (DPS-C) Buncombe CC - 4675 **Location #:** 1771296 **Violations:** 1
2988 Riverside Dr, , Asheville, NC 28804-8601, Phone: 828-645-7630
Contact: Steve Swiney, Maintenance Supervisor, Buncombe CC - 4675, Phone: 828-259-6020, Cell:828-726-4115

Object: NC321276 - PV - A O Smith - 1988 - Adv Ctr Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 08/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Tank is leaking from bottom.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace the tank or repair the leaking shell. If weld repairs are required, a qualified 'R' certificate holder is necessary to perform the work.

Location: (DPS-C) Enterprise Laundry Chase - 8255 **Location #:** 1786752 **Violations:** 3
201 Stevens Mill Rd, , Goldsboro, NC 27530-1056, Phone: 919-581-1037
Contact: Elvin Gabot, Maintenance Manager, Enterprise Laundry Chase - 8255, Phone: 919-581-1037, Cell:910-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC393521 - Boiler - Miura - 2012 - Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 12/13/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler overdue for internal inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Open boiler for internal inspection.

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 12/13/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 29- Operation Without Inspection Certificate- Article 7A, § 95-69.18
SUBCATEGORY 496. Annual external inspection on high pressure boiler not performed.
CONDITION: 496. Annual high pressure boiler external inspection not performed per 13 NCAC 13 .0211 (b). An external inspection must be performed on each high pressure boiler annually, in addition to the internal certificate inspection.
REQUIREMENT: 496. Contact your North Carolina commissioned inspector and schedule the external inspection. You may also contact the Boiler Safety Bureau for assistance.

Object: NC393522 - Boiler - Miura - 2011 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 12/13/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. Both PRDs leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (DPS-C) Lanesboro CI - 4865

Location #: 1805021

Violations: 3

552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013

Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC340796 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 08/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for cooler weather when boiler can be brought on line for proper inspection.

Object: NC423209 - Boiler - Cleveland Range - 2014 - Kitchen - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/14/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Object: NC430372 - Boiler - Lochinvar - 2020 - Outside Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 08/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection due to cracked heat exchanger.
REQUIREMENT: 363. Undefined Boiler Violations. Repair the cracking. If welding is required, a qualified 'R' certificate holder is necessary to perform the work.

Location: (DPS-C) Lanesboro Minimum CI - 3510 **Location #:** 1770840 **Violations:** 2
248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622
Contact: Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC251889 - Boiler - Peerless - 1991 - Blr Rm Food Service - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 08/01/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler could not be made to run.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is operating so that safety devices can be verified to operate properly.

Object: NC274584 - Boiler - Weil-McLain - 1995 - Blr Rm Unit 8 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 08/01/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler could not be made to run.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is operating so that safety devices can be verified to operate properly.

Location: (DPS-C) Morrison CI - 3930 **Location #:** 1811980 **Violations:** 2
1573 McDonald Church Rd, , Hoffman, NC 28347-9011, Phone: 910-281-3161
Contact: Richard Delfino, Morrison CI - 3930, Phone: 910-565-1731

Object: NC195855 - Boiler - Spencer - 1979 - Kitchen - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when boiler is operating so that safety devices can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC383986 - Boiler - Smith Cast Iron - 2010 - Medium Custody School Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is operating so that safety devices can be verified to operate properly.

Location: (DPS-C) Raleigh CCW - 3030 **Location #:** 1822656 **Violations:** 5
1201 S State St, , Raleigh, NC 27610-3863, Phone: 919-733-4248
Contact: Phillip Jones, Maintenance Supervisor, NCCIW - 3010, Phone: 919-508-1690

Object: NC239251 - Boiler - Peerless - 1988 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC408375 - Boiler - PVI Industries - 2016 - Raleigh Bldg Mech Rm 9 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC408376 - Boiler - Bradford White - 2015 - Raleigh Bldg Mech Rm 9 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC425785 - Boiler - Cleveland Range - 2019 - Kitchen - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC430209 - Boiler - Rheem - 2018 - Dorm E - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Location: (DPS-C) Wake CC - 4265 **Location #:** 1841085 **Violations:** 5
1000 Rock Quarry Rd, , Raleigh, NC 27610-3826, Phone: 919-733-7988
Contact: NC Dept Of Public Safety - 13101, Phone: 919-716-3422

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC353647 - Boiler - Waterpik - 1999 - Courtyard - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC353648 - Boiler - Teledyne Laars - 1999 - Courtyard - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC409475 - Boiler - Teledyne Laars - 2015 - Outside - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Object: NC420086 - Boiler - Teledyne Laars - 2018 - Outside - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC430210 - Boiler - Teledyne Laars - 2020 - Outside - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 09/26/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not in operation.
REQUIREMENT: 363. Undefined Boiler Violations.

Location: (ECSU) Information Technology Center **Location #:** 1800454 **Violations:** 1
1704 Weeksville Rd, , Elizabeth City, NC 27909-7977, Phone: 252-335-3258
Contact: Attn Dennis Leary, Facilities Manager, Elizabeth City State University, Phone: 252-335-3400, Cell:252-340-

Object: NC328310 - Boiler - Weil-McLain - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 12/06/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (EDGECOMBE) County Courthouse **Location #:** 1785871 **Violations:** 1
301 Saint Andrew St, , Tarboro, NC 27886-5136, Phone: 252-883-7841
Contact: Attn Stan Liverman, Maintenance Manager, Edgecombe County Government, Phone: 252-641-7842,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC431467 - PV - LC - 2020 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 02/01/2024 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 471. Discharge piping not properly supported.
CONDITION: 471. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 471. Support the relief valve discharge piping so it may not impose excessive stress on the valve. Contact Danny Harrell @ 919-500-3098 when the repair is completed.

Location: (ELON UNIV) Larose Student Commons **Location #:** 3967051 **Violations:** 2
112 E Labanon Ave, , Elon, NC 27244 , Phone: 336-675-9403
Contact: Attn Brian Chandler, Maintenance Supervisor, Elon University, , Cell:336-675-9403

Object: NC423503 - Boiler - Lochinvar - 2018 - Penthouse - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/31/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Object: NC423504 - Boiler - Lochinvar - 2018 - Penthouse - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/31/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Location: (FSU) Harris Hall **Location #:** 1931456 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC390558 - Boiler - Weil-McLain - 2011 - Bsmt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/06/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) Honors Residence Hall **Location #:** 1931474 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC304549 - Boiler - Raypak - 1996 - Rm 108 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed. Flow switch leaking.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Location: (FSU) Hood Hall **Location #:** 1798598 **Violations:** 2
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC424714 - Boiler - Lochinvar - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/06/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC424716 - Boiler - Lochinvar - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/06/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) Jones Student Center **Location #:** 1931441 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC397627 - Boiler - Aerco - 2013 - Blr Rm Behind New Addition - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) Joyner Hall **Location #:** 1802621 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC414790 - Boiler - Weil-McLain - 2017 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/06/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (FSU) Lyons Science Annex **Location #:** 1931971 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC402345 - Boiler - Camus - 2014 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/06/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) McLeod Bldg **Location #:** 3658040 **Violations:** 3
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-273-3446
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC404347 - Boiler - Lochinvar - 2014 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Object: NC404348 - Boiler - Lochinvar - 2014 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC430890 - Boiler - A O Smith - 2019 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) Nursing School **Location #:** 2864083 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1433
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC382402 - Boiler - Hydrotherm - 2010 - Mech Rm 1st Flr - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (FSU) School Of Business **Location #:** 1931461 **Violations:** 1
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881
Contact: Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

Object: NC430891 - Boiler - Weil-McLain - 2018 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 09/07/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (FTCC) YMCA Sandhills **Location #:** 2227097 **Violations:** 1
2717 Fort Bragg Rd, , Fayetteville, NC 28303-4720, Phone: 910-426-9622
Contact: Trey Ivey, Maintenance Supervisor, Fayetteville Technical Community College, , Cell:910-899-6294

Object: NC379617 - Boiler - Reimers - 2009 - Womens Steam Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/29/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 058. Leaking.
CONDITION: 058. Water Gauge Glass NCAC 13-13.0408: Leaking.
REQUIREMENT: 058. Repair or replace the leaking gauge and test to ensure proper operation. Ensure isolation valves are open during boiler operation.

Location: (HPU) Centennial Village II Club House **Location #:** 3637344 **Violations:** 1
945 Script St, , High Point, NC 27268-0001, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC403289 - Boiler - Teledyne Laars - 2015 - Pool Mech Rm 126 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 378. Discharge opening directed improperly.
CONDITION: 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. PRD discharge not piped to a safe location.
REQUIREMENT: 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

Location: (HPU) Greek Village Pool House **Location #:** 2976610 **Violations:** 1
833 Montlieu Ave, , High Point, NC 27268-0001, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC386156 - Boiler - Teledyne Laars - 2011 - Filter Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Location: (HPU) Jerry And Kitty Steele Sports Center **Location #:** 2128236 **Violations:** 1
1010 W College Dr, , High Point, NC 27262-3516, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC367321 - Boiler - Giannoni - 2006 - Mech Rm 117 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection, PRD and flow switch could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed service or boiler log that includes documentation of successful testing of devices is also acceptable.

Location: (HPU) Millis Hall **Location #:** 1810834 **Violations:** 2
1 University Pkwy, , High Point, NC 27268-0002, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC240910 - Boiler - American Standard - 1969 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection, LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the LWCO and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that provides documentation of successful testing of the LWCO and PRD is also acceptable.

Object: NC341660 - Boiler - Lochinvar - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints. Flow switch leaking/corroded.
REQUIREMENT: 020. Replace gaskets as necessary and tighten mechanical joints to stop leakage.

Location: (HPU) Plato S Wilson School Of Commerce **Location #:** 2505745 **Violations:** 1
1030 O A Kirkman Way, , High Point, NC 27262-4200, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC428706 - Boiler - AIC Gdynia - 2020 - 1st Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Inoperative. Combination temperature/pressure gauge inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HPU) R G Wanek Center **Location #:** 2609124 **Violations:** 4
1 University Pkwy, , High Point, NC 27268-0002, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC377556 - Boiler - Lochinvar - 2008 - Bldg 1 Section A Blr Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection, flow switch and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailer boiler log or service report that provides documentation of successful testing of LWCO and PRD is also acceptable.

Object: NC377558 - Boiler - Lochinvar - 2008 - Bldg 1 Section A Blr Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection, flow switch and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that provides documentation of successful testing of LWCO and PRD is also acceptable.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC377565 - Boiler - Camus - 2009 - Bldg 1 Section C Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints. Flow switch leaking/corroded.
REQUIREMENT: 020. Replace the leaking/corroded flow switch. Once complete, test the replacement flow switch to verify proper operation.

Object: NC377566 - Boiler - Camus - 2009 - Bldg 1 Section C Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 020. Leaking gasket or joints.
CONDITION: 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints.
REQUIREMENT: 020. Replace the leaking/corroded flow switch. Once complete, test the replacement flow switch to verify proper operation.

Location: (HPU) Village 1 **Location #:** 2330200 **Violations:** 3
1350 N College Dr, , High Point, NC 27262-3456, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC372525 - Boiler - Lochinvar - 2007 - Dorm 1 Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC372532 - Boiler - Lochinvar - 2008 - Dorm 1 Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Object: NC372534 - PV - LTC - 2008 - Dorm 1 Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (HPU) Village 2 **Location #:** 2984222 **Violations:** 1
1340 N College Dr, , High Point, NC 27262-3456, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC372527 - Boiler - Lochinvar - 2007 - Dorm 2 Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 11/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection, PRD and flow switch could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of successful testing of devices is also acceptable.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (HPU) Wilson Hall **Location #:** 2060685 **Violations:** 2
833 Montlieu Ave, , High Point, NC 27268-0001, Phone: 336-841-9154
Contact: Attn Ramone Richardson, Maintenance Manager, High Point University, Phone: 336-841-9157, Cell:336-

Object: NC289892 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASAME/NB stamped PRD having a set pressure of 50 psi or less and a relieving capacity of 163,000 Btu/Hour or more. The replacement PRD must be mounted in the vertical position and equipped with a testing lever. The PRD discharge must be piped full size to a safe location (I.E. 6" above the boiler room floor) and properly supported.

Object: NC289893 - Boiler - Weil-McLain - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the leaking PRD with an ASME/NB stamped PRD having a set pressure of 50 psi or less and a relieving capacity of 153,000 Btu/Hour or more. The replacement PRD must be mounted in the vertical position and equipped with a testing lever. The PRD discharge must be piped full size to a safe location (I.E. above the boiler room floor) and properly supported.

Location: (IREDELL) Courthouse/Hall Of Justice **Location #:** 1795110 **Violations:** 2
221 E Water St, , Statesville, NC 28677-5229, Phone: 704-878-3102/704 878-3043
Contact: Iredell County Government, Phone: 704-878-3102

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC441930 - PV - Trane - 2023 - Chiller Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/15/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 459. Discharge piping too small.
CONDITION: 459. Installation of PRDs NCAC 13-13.0405: Discharge piping too small.
REQUIREMENT: 459. Repipe the discharge line full size to a safe point of discharge.

Object: NC441931 - PV - Trane - 2023 - Chiller Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/15/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 459. Discharge piping too small.
CONDITION: 459. Installation of PRDs NCAC 13-13.0405: Discharge piping too small.
REQUIREMENT: 459. Repipe the discharge line full size to a safe point of discharge.

Location: (IREDELL) Public Library **Location #:** 1800354 **Violations:** 1
201 N Tradd St, , Statesville, NC 28677-5241, Phone: 704-878-3098
Contact: Iredell County Government, Phone: 704-878-3102

Object: NC441932 - Boiler - AIC Gydnia - 2023 - Mech Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/15/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: (ISS) Brawley Middle **Location #:** 1770189 **Violations:** 1
132 Swift Arrow Dr, , Mooresville, NC 28117-5209, Phone: 704-664-4430
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC356378 - Boiler - Lochinvar - 2002 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/13/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (ISS) Central Elem **Location #:** 1775357 **Violations:** 1
4083 Wilkesboro Hwy, , Statesville, NC 28625-1237, Phone: 704-876-0746
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Object: NC289459 - Boiler - H B Smith - 1998 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/11/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (ISS) East Iredell Middle **Location #:** 1785309 **Violations:** 2
590 Chestnut Grove Rd, , Statesville, NC 28625-9127, Phone: 704-872-4666
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC441929 - Boiler - Weil-McLain - 2021 - Blr Rm - Active **Violations This Object:** 2

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/15/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Temperature Controls NCAC 13-13.0406
SUBCATEGORY 093. High limit temperature control inoperative.
CONDITION: 093. Temperature Controls NCAC 13-13.0406: High limit temperature control manual reset inoperative.
REQUIREMENT: 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 02/15/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: (ISS) Lake Norman Elem **Location #:** 1804756 **Violations:** 1
255 Oak Tree Rd, , Mooresville, NC 28117-9129, Phone: 704-662-8261
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Object: NC277864 - Boiler - Weil-McLain - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/13/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (ISS) Third Creek Elem **Location #:** 1836008 **Violations:** 1
361 E Barkley Rd, , Statesville, NC 28677-2450, Phone: 704-873-3002
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC338666 - Boiler - Lochinvar - 2001 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Immediately replace with an ASME/NB certified PRD with a set pressure of not greater than 160 psig, with a total relief capacity of not less than 2000 Kbh and with a testing lever.

Location: (ISS) Troutman Middle **Location #:** 1837864 **Violations:** 1
305 Rumble St, , Troutman, NC 28166-8525, Phone: 704-528-6028
Contact: Attn Eddie Odom, Iredell Statesville Schools, Phone: 704-873-3755

Object: NC155813 - Boiler - Burnham - 1975 - Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leaks.
REQUIREMENT: 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

Location: (JACKSON CS) Smoky Mountain High **Location #:** 1829861 **Violations:** 3
100 Smoky Mountain Dr, , Sylva, NC 28779-5600, Phone: 828-586-2177
Contact: Jason Watson, Maintenance Supervisor, Jackson County Public Schools, Phone: 828-586-2311

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC325448 - Boiler - H B Smith - 2000 - Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/31/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 273. Shell leaks.
CONDITION: 273. Boiler Components: Shell leaks. Boiler not running because a section is leaking.
REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Object: NC335319 - Boiler - H B Smith - 2001 - Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/31/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was not running due to the repairs on the other boiler.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection once the boiler is back in operation.

Object: NC372492 - Boiler - Peerless - 2008 - Voc Bldg Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/31/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 232. Gas train has improper venting.
CONDITION: 232. Burners and Fuel Supply Systems: Gas train has improper venting.
REQUIREMENT: 232. Vent the gas train to a safe point .

Location: (LEX CS) Lexington Senior High **Location #:** 1805975 **Violations:** 3
26 Penry St, , Lexington, NC 27292-2638, Phone: 336-242-1574
Contact: Tim Curry, Maintenance Supervisor, Lexington City Schools, , Cell:336-240-0812

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC011227 - PV - Novelty - 1952 - Blr Rm 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/26/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Leakage/corrosion on outlet plumbing connections at bottom of tank.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace the leaking/corroded plumbing connections.

ENTERED BY: Putek, Terry

CLOSED BY:

Object: NC260793 - Boiler - Peerless - 1993 - Blr Rm 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/26/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested in order to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the LWCO and PRD ,ay be tested to verify proper operation. As an alternative, a detailed boiler log or service report that provides documentation of successful testing of the LWCO and PRD is also acceptable.

ENTERED BY: Putek, Terry

CLOSED BY:

Object: NC260794 - Boiler - Peerless - 1993 - Blr Rm 2 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/26/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested in order to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that the LWCO and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that provides documentation of successful testing of the LWCO and PRD is also acceptable.

ENTERED BY: Putek, Terry

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (MCDO CS) Marion Elem **Location #:** 1808224 **Violations:** 2
209 Robert St, , Marion, NC 28752-3094, Phone: 828-652-2141
Contact: Attn Garvin Trinks, McDowell County Schools, Phone: 828-652-5504

Object: NC248813 - Boiler - Weil-McLain - 1990 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running due to a control issue.
REQUIREMENT: 363. Undefined Boiler Violations. Have boiler controls evaluated to ensure boiler can run during inspection.

Object: NC330133 - Boiler - Teledyne Laars - 1999 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 009. Water level control inoperative or bypassed.
CONDITION: 009. LWCO and Flow Sensing Devices NCAC 13-13.0409: Water level control inoperative or bypassed. Leak noted within LWCO.
REQUIREMENT: 009. Repair or replace the inoperable water level control and test to ensure proper operation.

Location: (MCDO CS) McDowell High **Location #:** 1809339 **Violations:** 2
600 McDowell High Dr, , Marion, NC 28752-9131, Phone: 828-652-7920
Contact: Attn Garvin Trinks, McDowell County Schools, Phone: 828-652-5504

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC358716 - Boiler - PVI Industries - 2005 - New ROTC Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/09/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations. Boiler not running, leak at hot water outlet, severe corrosion.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations. Repair the corrosion. If welding is required, a qualified 'R' certificate holder is necessary to perform the work.

Object: NC396428 - Boiler - Patterson Kelley - 2013 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/09/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating. Control circuit board has gone bad.
REQUIREMENT: 363. Undefined Boiler Violations. Assess if boiler is to be repaired, if not, disconnect boiler from piping, gas and electrical systems.

Location: (MCDO CS) West Marion Elem **Location #:** 1842923 **Violations:** 1
820 Marler Rd, , Marion, NC 28752-9693, Phone: 828-738-3353
Contact: Attn Garvin Trinks, McDowell County Schools, Phone: 828-652-5504

Object: NC252753 - Boiler - Weil-McLain - 1989 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler would not run.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is operating.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (MCDO CS) West McDowell Middle **Location #:** 1842933 **Violations:** 1
346 W McDowell Jr High Sch Rd, , Marion, NC 28752-6203, Phone: 828-652-3390
Contact: Attn Garvin Trinks, McDowell County Schools, Phone: 828-652-5504

Object: NC114839 - Boiler - Spencer - 1971 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Baccus, Bryan
OPENED: 09/13/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not ready for external inspection. Boiler not in operation. Unable to test controls and safety devices.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is in operation so that controls and safety devices can be tested.

Location: (MITCHELL CC) Current House **Location #:** 1781510 **Violations:** 1
507 W End Ave, , Statesville, NC 28677-5155, Phone: 704-878-3200
Contact: Attn Chad Lackey, Director Safety And Security, Mitchell Community College,

Object: NC374837 - Boiler - ECR International - 2008 - Bsmt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed. The primary LWCO is inoperative.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: (NC A And T) T E Neal Heating Plt **Location #:** 1834439 **Violations:** 3
1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025
Contact: Garrett Blount, Plant Manager, T E Neal Heating Plt, Phone: 336-285-4583, Cell:336-430-6205

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC206485 - Boiler - Nebraska - 1982 - Power House Blr 4 - Active **Violations This Object:** 3

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/25/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 12-Casing, Stack Breeching and Flue
SUBCATEGORY 211. Combustion gas leaks.
CONDITION: 211. Casing, Stack Breeching and Flue: Combustion gas leakage due to damage to boiler stack breeching..
REQUIREMENT: 211. Repair the damaged sections of stack breeching.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/25/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 236. Undefined Boiler Piping and Other Systems Violations.
CONDITION: 236. Burners and Fuel Supply Systems: Undefined Boiler Piping and Other Systems Violations. Possible boiler operational control issues.
REQUIREMENT: 236. Undefined Boiler Piping and Other Systems Violations. Complete a diagnostic evaluation of the boiler control system and gas train to identify any operational and safety issues with this equipment.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/25/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 17-Baffles and/or Refractory
SUBCATEGORY 293. Out of place.
CONDITION: 293. Baffles and/or Refractory: Out of place. Displaced section of refractory material in fire box.
REQUIREMENT: 293. Replace the displaced section of boiler refractory material in boiler fire box.

Location: (NCSU) Fitts Woodard Hall Z8

Location #: 4029871

Violations: 1

915 Partners Way, , Raleigh, NC 27606-5200, Phone: 919-513-6312

Contact: Attn Chris Hill Facilities Operations Div, Maintenance Director, NC State University Zone 4, Phone: 919-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC429010 - PV - BMT - 2019 - Rm 3151 Eng Bldg Oval - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Kinney, Donald
OPENED: 09/20/2023 **ENTERED BY:** Kinney, Donald
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.

10/23/2023 Still within 60 days. Violation not corrected yet. EKF

REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (NCSU) Headhouse Unit 2 BD 172-Z5 **Location #:** 2154669 **Violations:** 1
840 Method Rd, , Raleigh, NC 27607-5383, Phone: 919-513-6485
Contact: Andrew Langdon, Headhouse Unit 2 BD 172-Z5, Phone: 919-513-6485

Object: NC118739 - PV - Bell & Gossett - 1971 - Mech Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Kinney, Donald
OPENED: 09/20/2023 **ENTERED BY:** Kinney, Donald
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Not in operation for inspection.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Remove vessel from energy sources or prepare for inspection.

Location: (NCSU) Hillsborough Bldg 48-Z1 **Location #:** 1797652 **Violations:** 1
2820 Hillsborough St, , Raleigh, NC 27607-7142, Phone: 919-515-9917
Contact: Robert Bowman, Hillsborough Bldg 48-Z1, Phone: 919-515-9917

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC242185 - Boiler - Weil-McLain - 1989 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 08/08/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler is currently disassembled for replacement of a section. Unable to test PRDs and LWCOs.

10/23/2023 Section removed, realigning sections and piping. Still within 60 days.
EKF
REQUIREMENT: 363. Undefined Boiler Violations. Repair or replace boiler and operate boiler so that safety devices can be tested.

Location: (NCSU) Terry Companion Animal Medical Ctr CVM-Z5 **Location #:** 2930475 **Violations:** 1
1052 William Moore Dr, , Raleigh, NC 27607-4065, Phone: 919-513-6485
Contact: Andrew Langdon, Terry Companion Animal Medical Ctr, Phone: 919-513-6485

Object: NC384731 - PV - Aerco - 2009 - Mech Rm 1480 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Fish, Emily
OPENED: 10/23/2023 **ENTERED BY:** Fish, Emily
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. There is a leak around the bolts on top of the object.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Address the leak.

Location: (NEWTON) City Hall **Location #:** 1777238 **Violations:** 1
401 N Main Ave, , Newton, NC 28658-3101, Phone: 828-695-4310
Contact: Attn Eddie Johnson, Buildings And Grounds Superintendent, City Of Newton, Phone: 828-217-4448

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC149253 - Boiler - Dewey Shepard - 1975 - Equip Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Baccus, Bryan
OPENED: 09/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not ready for inspection. Boiler not in operation. Unable to test controls and safety devices.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler is in operation so that controls and safety devices can be tested.

Location: (ROBESON CS) Purnell Swett High **Location #:** 1821636 **Violations:** 3
11344 Deep Branch Rd, , Maxton, NC 28364-8959, Phone: 910-738-4841
Contact: Attn Earney Hammonds, Director of Maintenance, Public Schools of Robeson County, Phone: 910-738-

Object: NC440846 - Boiler - Lochinvar - 2023 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 01/04/2024 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Object: NC440847 - Boiler - Lochinvar - 2023 - Main Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 01/04/2024 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC440848 - Boiler - AIC Gydnia - 2023 - Bldg 700 Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 01/04/2024 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: (ROBESON CS) Red Springs High **Location #:** 1823527 **Violations:** 2
509 N Vance St, , Red Springs, NC 28377-1376, Phone: 910-738-4841
Contact: Attn Earney Hammonds, Director of Maintenance, Public Schools of Robeson County, Phone: 910-738-

Object: NC440849 - Boiler - Lochinvar - 2023 - Rear Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 01/04/2024 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Object: NC440850 - Boiler - Lochinvar - 2023 - Rear Gym Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Bailey, Derek
OPENED: 01/04/2024 **ENTERED BY:** Bailey, Derek
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: (ROBESON CS) Rosenwald Elem **Location #:** 1825531 **Violations:** 1
301 Martin Luther King Dr, , Fairmont, NC 28340-1327, Phone: 910-738-4841
Contact: Attn Earney Hammonds, Director of Maintenance, Public Schools of Robeson County, Phone: 910-738-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC376871 - Boiler - Weil-McLain - 2009 - Blr Rm Cafeteria - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 10/03/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: (ROBESON CS) South Robeson High **Location #:** 1830353 **Violations:** 2
3268 S Robeson Rd, , Rowland, NC 28383-6712, Phone: 910-738-4841
Contact: Attn Earney Hammonds, Director of Maintenance, Public Schools of Robeson County, Phone: 910-738-

Object: NC201462 - Boiler - Weil-McLain - 1981 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 11/16/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 371. Inadequate relieving capacity.
CONDITION: 371. Installation of PRDs NCAC 13-13.0405: Inadequate relieving capacity.
REQUIREMENT: 371. Replace the pressure relieving device with one with a capacity required by the boiler manufacturer.

Object: NC358375 - Boiler - PVI Industries - 2004 - C115 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 11/16/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: (SMS) Natatorium Pool **Location #:** 1832204 **Violations:** 1
900 Hillsborough St, , Raleigh, NC 27603-1610, Phone: 919-424-4132
Contact: Attn Eric Poss, Director of Facilities, Saint Marys School, Phone: 919-424-4132

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC433933 - Boiler - Laars - 2021 - Outside Pool - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 01/31/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 394. Valve inoperative.
CONDITION: 394. Operation of PRDs NCAC 13-13.0405: Valve inoperative.
REQUIREMENT: 394. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (ST AUGUSTINES) Atkinson Hall **Location #:** 1765302 **Violations:** 1
1315 Oakwood Ave, , Raleigh, NC 27610-2247, Phone: 919-516-4482
Contact: Physical Plt Director, St Augustines College, Phone: 919-516-4929, Cell:919-827-2797

Object: NC366479 - PV - Roy E Hanson - 2006 - Bsmt Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 457. Try lever not installed.
CONDITION: 457. Installation of PRDs NCAC 13-13.0405: Try lever not installed.
REQUIREMENT: 457. Replace the relief valve with one with a try lever. The replacement relief valve must be ASME/NB certified.

Location: (ST AUGUSTINES) Latham Hall **Location #:** 1805151 **Violations:** 1
1315 Oakwood Ave, , Raleigh, NC 27610-2247, Phone: 919-516-4482
Contact: Physical Plt Director, St Augustines College, Phone: 919-516-4929, Cell:919-827-2797

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC356153 - Boiler - Burnham - 1997 - Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 24-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 372. Set pressure too high.
CONDITION: 372. Installation of PRDs NCAC 13-13.0405: Set pressure too high. Mawp is 60 psi and SV#1 is 75 psi.
REQUIREMENT: 372. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer.

Location: (ST AUGUSTINES) Lynch Hall **Location #:** 1807219 **Violations:** 3
1315 Oakwood Ave, , Raleigh, NC 27610-2247, Phone: 919-516-4482
Contact: Physical Plt Director, St Augustines College, Phone: 919-516-4929, Cell:919-827-2797

Object: NC278007 - Boiler - Peerless - 1995 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating. Unable to test PRD.
REQUIREMENT: 363. Undefined Boiler Violations. Operate boiler in order to test PRD.

Object: NC278008 - Boiler - Teledyne Laars - 1996 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating. Unable to test PRD.
REQUIREMENT: 363. Undefined Boiler Violations. Operate boiler in order to test PRD.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC366478 - PV - Roy E Hanson - 2006 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 03/02/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. PRD not tested because not currently in service.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Operate tank under pressure in order to test PRD.

Location: (STOKES) County Courthouse **Location #:** 1780492 **Violations:** 2
1012 N Main St, , Danbury, NC 27016-7418, Phone: 336-593-9173
Contact: Attn Brad Montgomery, Stokes County Government, Phone: 336-593-2811, Cell:336-813-3996

Object: NC203177 - Boiler - Precision - 1981 - 1012 Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 02/05/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 019. Drain clogged.
CONDITION: 019. LWCO and Flow Sensing Devices NCAC 13-13.0409: Drain clogged.
REQUIREMENT: 019. Clean or replace drain pipe to reestablish full flow.

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 02/05/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: (UNCC) Regional Utility Plt 5 **Location #:** 3968972 **Violations:** 1
9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-0564
Contact: Attn Karen Lockard, UNC Charlotte, Phone: 704-687-8880

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC423477 - Boiler - Hurst - 2019 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 06/14/2022
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Forced fan impeller cracked and broken/awaiting repair parts
REQUIREMENT: 363. Undefined Boiler Violations. Replace cracked and broken impeller on main forced air fan. Upon completion of repairs schedule a follow up inspection.

Location: (UNCG) Sullivan Science Bldg

Location #: 3461464

Violations: 1

800 Oakland Ave, , Greensboro, NC 27412-5059, Phone: 336-256-0499

Contact: Richard Ratcliffe, Maintenance, UNC Greensboro, Phone: 336-334-5554, Cell:336-880-7092

Object: NC439873 - Boiler - TDC Mfg - 2022 - Rm 460 - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 11/21/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency boiler shut off switch.
REQUIREMENT: 235. Install an emergency boiler shut off switch at each egress from the room to shut off the boiler. Switch must be marked with a sign indicating it as such.

Location: (WCU) Steam Plant

Location #: 1832783

Violations: 3

111 Central Dr, , Cullowhee, NC 28723-9500, Phone: 828-227-3583

Contact: Mike Hoyle, Plant Supervisor, WCU Steam Plant, Phone: 828-227-3583

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC436464 - Boiler - Cleaver Brooks - 2021 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/02/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed. Primary LWCO failed to shut the boiler down.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Object: NC436465 - Boiler - Cleaver Brooks - 2021 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/02/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed. Primary LWCO failed to shut down the boiler.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Object: NC436466 - Boiler - Cleaver Brooks - 2021 - New Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/02/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed. Primary LWCO failed to shut down the boiler.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: (WCU) Tom Apodaca Science Bldg **Location #:** 4045994 **Violations:** 2
460 Memorial Dr, , Cullowhee, NC 28723 , Phone: 828-227-7224
Contact: Michael Frazier, PM Coordinator, Western Carolina University, Phone: 828-227-7224, Cell:828-507-3871

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC430982 - PV - BMT Medical Technology - 2019 - Rm 422 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 06/21/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Could not locate safety valve on chamber.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Locate safety valve on chamber or contact the manufacturer and point it out to the inspector during the followup inspection.

ENTERED BY: Putek, Terry
CLOSED BY:

Object: NC430984 - PV - BMT Medical Technology - 2019 - Rm 422 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 06/21/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Could not locate safety valve on chamber.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Locate safety valve on chamber or contact the manufacturer and point it out to the inspector during the followup inspection.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: (WFU) Biotech Place

Location #: 3012653

Violations: 3

575 Patterson Ave, , Winston Salem, NC 27101-4101, Phone: 336-758-3488

Contact: Attn Jimmy Nifong, Utilities Manager, Wake Forest University, Phone: 336-758-3332, Cell:336-757-6628

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC388007 - Boiler - Sussman-Automatic - 2011 - Rm 2S-051 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 01/02/2024 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 391. Discharge piping not properly supported.
CONDITION: 391. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 391. Support the relief valve discharge piping so it may not impose excessive stress on the relief valve.

contact Richard Parker @ 336-202-8341

Object: NC388008 - PV - Getinge - 2011 - Rm 2S-051 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 01/02/2024 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 471. Discharge piping not properly supported.
CONDITION: 471. Operation of PRDs NCAC 13-13.0405: Discharge piping not properly supported.
REQUIREMENT: 471. Support the relief valve discharge piping so it may not impose excessive stress on the valve.

contact Richard Parker @ 336-202-8341

Object: NC388010 - PV - Getinge - 2011 - 1N021 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 01/02/2024 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Steam leak in piping.
REQUIREMENT: 479. Repair steam leak and contact inspector.

contact Richard Parker @ 336-202-8341

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: (WILMINGTON) City Hall **Location #:** 1777099 **Violations:** 1
102 N 3rd St, , Wilmington, NC 28401-4035, Phone: 910-470-0553
Contact: City Of Wilmington, Phone: 910-341-7810

Object: NC424744 - Boiler - Lochinvar - 2019 - Penthouse - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 02/20/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

Location: A Cleaner World #168 **Location #:** 1761459 **Violations:** 1
1949 Battleground Ave, , Greensboro, NC 27408-7123, Phone: 336-288-5312
Contact: Attn Kevin Lawson, Maintenance, Tri State Laundry Equipment Co, Phone: 336-804-0031, Cell:336-992-

Object: NC373476 - Boiler - Parker - 2008 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 10/09/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 054. Glass is too cloudy to see water level.
CONDITION: 054. Water Gauge Glass NCAC 13-13.0408: Glass is too cloudy to see water level.
REQUIREMENT: 054. Clean or replace gauge glass with material designed for temperature and service.

Location: Alamance Community College **Location #:** 1762605 **Violations:** 1
1247 Jimmie Kerr Rd, , Haw River, NC 27258-9570, Phone: 336-506 4117
Contact: Biff Hulsey, Maintenance, Alamance Community College, Phone: 336-506-4323, Cell:336-437-7200

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC427388 - Boiler - Rheem - 2020 - Bldg A Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/30/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Thermometer NCAC 13-13.0410
SUBCATEGORY 111. Thermometer inoperative.
CONDITION: 111. Thermometer NCAC 13-13.0410: Thermometer inoperative.
REQUIREMENT: 111. Replace inoperative thermometer at/in the boiler outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

Location: Angel Medical Center **Location #:** 1764066 **Violations:** 5
120 Riverview St, , Franklin, NC 28734-2612, Phone: 828-369-4201
Contact: Attn David Williams, Facilities Manager, MH Angel Medical Center Llp, Phone: 828-349-6644

Object: NC298806 - Boiler - Weil-McLain - 1999 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/13/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler has been taken out of service but it has not been properly disconnected.
REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

Object: NC328817 - Boiler - Weil-McLain - 2000 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/13/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service but it has not been properly disconnected.
REQUIREMENT: 363. Undefined Boiler Violations. Disconnected the boiler from all sources of potential energy including fuel and electricity.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC335291 - PV - Trane - 2001 - AH #8 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/13/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. This vessel has been take out of service but it has not been properly disconnected.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Disconnect the vessel from all sources of potential energy including electricity.

Object: NC405774 - PV - Trane - 2015 - AH #8 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/13/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. This vessel has been taken out of service but it has not been properly disconnected.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Disconnect the vessel from all sources of potential energy including electricity.

Object: NC424526 - Boiler - Weil-McLain - 2010 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/13/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. This boiler has been taken out of service but it has not been properly disconnected.
REQUIREMENT: 363. Undefined Boiler Violations. Disconnect the boiler from all sources of potential energy including fuel and electricity.

Location: Baker Furniture Co

Location #: 1222904

Violations: 1

1 Baker Way, , Connelly Springs, NC 28612-7602, Phone: 828-397-5551

Contact: Attn Robert Jordan, Maintenance Supervisor, Baker Furniture Co Inc, Phone: 828-397-5551 X4332,

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC218740 - Boiler - Bigelow - 1969 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/23/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler overdue for required internal certificate inspection.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an internal inspection as soon as possible.

Location: Bonnie Mist Car Wash **Location #:** 1769661 **Violations:** 1
1046 Morganton Blvd SW, , Lenoir, NC 28645 , Phone: 828-754-7230
Contact: Attn David Cloer, Owner, Bonnie Mist Car Wash Inc, Phone: 828-754-7230, Cell:828-499-4366

Object: NC413160 - Boiler - Raypak - 2017 - Blr Rm 2 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 08/31/2023 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: Bonnie Mist Car Wash **Location #:** 2303933 **Violations:** 2
225 Harper Ave SW, , Lenoir, NC 28645-5059, Phone: 828-754-7230
Contact: Attn David Cloer, Owner, Bonnie Mist Car Wash Inc, Phone: 828-754-7230, Cell:828-499-4366

Object: NC369645 - Boiler - Raypak - 2007 - Equip Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 08/31/2023 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC369646 - Boiler - Raypak - 2007 - Equip Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 08/31/2023 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.
REQUIREMENT: 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

Location: Bragtown Baptist Church **Location #:** 1770058 **Violations:** 1
3218 N Roxboro St, , Durham, NC 27704-3254, Phone: 919-428-7918
Contact: Attn Gene Magnum, Maintenance, Bragtown Baptist Church, Phone: 919-220-1166

Object: NC289263 - Boiler - Weil-McLain - 1999 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 11/29/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 006. Low water cutoff device inoperative or bypassed.
CONDITION: 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.
REQUIREMENT: 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

Location: Broughton Hospital New Hospital **Location #:** 3904479 **Violations:** 1
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: Bruce Elder, Maintenance Supervisor, Broughton Hospital New Hospital, Phone: 828 -608-4503

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414260 - Boiler - Cleaver Brooks - 2014 - NBH M-4 Mech Rm - **Violations This Object:** 1
Active

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 07/14/2022 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. LWCO and PRD could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when safety devices can be tested to verify proper operation.

Location: Broughton Hospital Old Hospital **Location #:** 1770791 **Violations:** 2
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828-433-2329
Contact: There is no contact information available for this location.

Object: NC012534 - Boiler - Edgemoor - 1950 - Blr Rm Power Plt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/15/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. PRD could not be tested during the inspection due to low boiler operating pressure in relation to PRD set pressure rating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler pressure may be adjusted to a suitable level for testing of PRD. As an alternative, a new or recertified ASME/NB stamped PRD having a set pressure of 300 psi or less and a relieving capacity of 32600 pph or more may be installed annually so that testing of PRD is not required. A second alternative would be to install a PRD with a lower set pressure rating in relation to the normal operating pressure. New PRD must have a relieving capacity of 32600 pph or more.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC012535 - Boiler - Edgemoor - 1950 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/15/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. PRD could not be tested during the inspection due to low boiler operating pressure in relation to PRD set pressure rating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler pressure may be adjusted to a suitable level for testing of PRD. As an alternative, a new or recertified ASME/NB stamped PRD having a set pressure of 300 psi or less and a relieving capacity of 32600 pph or more may be installed annually so that testing of PRD is not required. A second alternative would be to install a PRD with a lower set pressure rating in relation to the normal operating pressure. New PRD must have a relieving capacity of 32600 pph or more.

Location: Burlington Industries Finishing Plant

Location #: 1800179

Violations: 1

906 N Anthony St, , Burlington, NC 27217-6663, Phone: 336-228-2457

Contact: Attn Mack Johnson, Maintenance Director, Burlington Industries Finishing Plant, Phone: 336-266-3475,

Object: NC367266 - PV - Gcdmc - 2000 - Dye House 63 - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 01/30/2024
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 453. Inlet pipe too small.
CONDITION: 453. Installation of PRDs NCAC 13-13.0405: Inlet pipe too small. PRD inlet piping between tank and PRD inlet opening too small.
REQUIREMENT: 453. Replace the inlet line to provide for full size to the relief device. Replace the PRD with an ASME/NB stamped PRD having a set pressure of 53 psi or less and a relieving capacity sufficient to fully relieve pressure on vessel. The PRD inlet piping between the tank and the new PRD inlet must be at least equal to the cross sectional area of the PRD inlet opening.

Location: Carolina Glove And Safety Co

Location #: 3288566

Violations: 2

2813 N College Ave, , Newton, NC 28658-2741, Phone: 828-244-3026

Contact: Carolina Glove And Safety Co Inc, Phone: 828-464-1132

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC084073 - Boiler - BE&S - 1967 - Blr Rm - Active

Violations This Object: 2

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 01/11/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 056. Gauge glass not provided with a drain.
CONDITION: 056. Water Gauge Glass NCAC 13-13.0408: Gauge glass not provided with a drain.
REQUIREMENT: 056. Provide a drain valve or cock and discharge outlet to the bottom most connection of the gauge glass and extend the gauge glass drain line to a point where its discharge will not endanger personnel.

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 01/11/2024 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Condensate return tank requires a second vent with internal flote.
REQUIREMENT: 363. Undefined Boiler Violations. Install a second vent on condensate return tank with internal flote in accordance with NCAC1313.

Location: Carolina Mountain

Location #: 2284341

Violations: 5

235 Milton Mashburn Dr, , Andrews, NC 28901-8051, Phone: 828-321-3335

Contact: Attn Danny West, Carolina Mountain Inc, Phone: 828-321-3335

Object: NC372475 - Boiler - Parker - 2007 - Blr Rm - Active

Violations This Object: 5

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/14/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 009. Water level control inoperative or bypassed.
CONDITION: 009. LWCO and Flow Sensing Devices NCAC 13-13.0409: Water level control inoperative or bypassed.
REQUIREMENT: 009. Repair or replace the inoperable water level control and test to ensure proper operation.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/14/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Pressure Controls NCAC 13-13.0406
SUBCATEGORY 073. High limit pressure control inoperative.
CONDITION: 073. Pressure Controls NCAC 13-13.0406: High limit pressure control inoperative.
REQUIREMENT: 073. Repair or replace the inoperative high limit pressure control. Test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/14/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Bottom Blow and Drain Systems NCAC 13-13.0411
SUBCATEGORY 155. Piping/fitting not sufficient schedule/grade or improper material.
CONDITION: 155. Bottom Blow and Drain Systems NCAC 13-13.0411: Piping/fitting not sufficient schedule/grade or improper material.
REQUIREMENT: 155. Replace piping/fitting with proper material of sufficient schedule and grade.

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/14/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 232. Gas train has improper venting.
CONDITION: 232. Burners and Fuel Supply Systems: Gas train has improper venting.
REQUIREMENT: 232. Vent the gas train to a safe point .

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/14/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Discharge pipe reduced.
REQUIREMENT: 363. Undefined Boiler Violations. Repipe the discharge line full size to a safe point of discharge.

Location: Carolina Specialty Fabrics Plts 3 And 4

Location #: 1222959

Violations: 3

28 N Caldwell Ave, , Newton, NC 28658-2300, Phone: 828-464-1901

Contact: Billy Stallings, Maintenance Supervisor, Carolina Specialty Fabrics Plts 3 And 4, Phone: 828-464-1901

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC188270 - Boiler - Cleaver Brooks - 1977 - Blr Rm - Active

Violations This Object: 3

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 01/11/2024
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Cross tee's on low water colum needs open .
REQUIREMENT: 363. Undefined Boiler Violations. Cross Tee's on low water colum's both side on boiler needs open to perform internal inspection inside piping.

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 01/11/2024
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. All hand hole opening are not open for internal inspection.
REQUIREMENT: 363. Undefined Boiler Violations. All hand hole opening needs to be removed to completed internal inspection.

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 01/11/2024
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Large amount of scale build up in bottom of boiler.
REQUIREMENT: 363. Undefined Boiler Violations. Large amount of scale needs cleaning out on boiler.

Location: Community CarePartners

Location #: 1836233

Violations: 1

68 Sweeten Creek Rd, , Asheville, NC 28803-2318, Phone: 828-775-1737

Contact: Brandon Musty, Maintenance, Community CarePartners, , Cell:828-775-1726

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC424552 - Boiler - Raypak - 2016 - Pool Heater - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/15/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler was out of service due to no water in the boiler.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection for a day and time when the boiler is back in service.

Location: CSX Transflo Inc **Location #:** 1781353 **Violations:** 1
601 N Hoskins Rd, , Charlotte, NC 28216-3426, Phone: 704-560-9601
Contact: There is no contact information available for this location.

Object: NC243111 - Boiler - York Shipley - 1989 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 01/11/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Crack noted in Morrison tube and 1 fire tube.
REQUIREMENT: 363. Undefined Boiler Violations. Repair the cracking. If welding is required, a qualified 'R' certificate holder is necessary to perform the work.

Location: Elevate Textiles **Location #:** 1771590 **Violations:** 3
1001 Turnpike Rd, , Raeford, NC 28376-8566, Phone: 910-875-3731
Contact: Attn David Limbacher, Maintenance Manager, Elevate Textiles, Phone: 910-875-3731 X472, Cell:910-725-

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC197937 - PV - Gcdmc - 1964 - Dye Kier #5 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/30/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 476. Missing nameplate.
CONDITION: 476. Operation of PRDs NCAC 13-13.0405: Missing nameplate. PRD label plate unreadable.
REQUIREMENT: 476. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC366618 - PV - Gcdmc - 1995 - Jet #20 HX - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/30/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 475. Valve leaking.
CONDITION: 475. Operation of PRDs NCAC 13-13.0405: Valve leaking.
REQUIREMENT: 475. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Object: NC366619 - PV - Gcdmc - 1994 - Jet #21 - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 01/30/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 05-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 476. Missing nameplate.
CONDITION: 476. Operation of PRDs NCAC 13-13.0405: Missing nameplate. PRD label plate unreadable.
REQUIREMENT: 476. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Emerald Oasis Car Wash **Location #:** 231092 **Violations:** 1
1002 Gum Branch Rd, , Jacksonville, NC 28540-5741, Phone: 252-241-7702
Contact: Attn Rob Grote, Owner, Emerald Oasis Car Wash, Phone: 252-241-7702

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC427794 - PV - Morganton - 2015 - Car Wash - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Kirkland, John
OPENED: 10/18/2023 **ENTERED BY:** Kirkland, John
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 031. Out of calibration.
CONDITION: 031. Pressure Gauges NCAC 13-13.0407: Out of calibration.
REQUIREMENT: 031. Recalibrate pressure gauge or replace with a calibrated gauge ranged in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407. Once the repair or replacement has been done, contact John Kirkland @ 252-204-7789 for a follow up inspection.

Location: Erlanger Western Carolina Hospital **Location #:** 1812750 **Violations:** 1

3990 E US 64 Alt, , Murphy, NC 28906-6843, Phone: 828-835-7684

Contact: Attn Bubba Spell, Plant Ops Manager, Erlanger Western Carolina Hospital, Phone: 828-835-7630

Object: NC411962 - Boiler - Sussman - 2016 - Electric Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/10/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 273. Shell leaks.
CONDITION: 273. Boiler Components: Shell leaks. Leaking around elements.
REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Falcon Dyeing And Finishing **Location #:** 2322723 **Violations:** 2

101 Forest St, , Windsor, NC 27983-1451, Phone: 252-794-9902

Contact: Attn Larry Dunlow, Manager, Falcon Dyeing And Finishing, Phone: 252-794-9902

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC278066 - Boiler - Kewanee - 1995 - Blr Rm - Active

Violations This Object: 2

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 06/26/2023 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 057. Drain inoperative.
CONDITION: 057. Water Gauge Glass NCAC 13-13.0408: Water gauge glass drain valve not equipped with a drain line.
REQUIREMENT: 057. Install a drain line on the water gauge drain valve and extend to within 6 inches of the floor of the boiler room.

COMPANY: State of North Carolina
INSPECTOR: Harrell, Danny
OPENED: 06/26/2023 **ENTERED BY:** Harrell, Danny
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. The front bottom blowdown valve is seized.
REQUIREMENT: 363. Undefined Boiler Violations. Repair or replace the front bottom blowdown valve. Contact Danny Harrell @ 919-500-3098 when the repair is completed to schedule a re-inspection.

Location: First Presbyterian Church

Location #: 1789203

Violations: 2

308 W Fisher St, , Salisbury, NC 28144-4830, Phone: 704-636-1321

Contact: Attn Archie Tucker, First Presbyterian Church, Phone: 704-636-1321

Object: NC348377 - Boiler - Heat Transfer Products - 2003 - Sanctuary Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 02/05/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. Safety devices could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that safety devices may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of successful testing of these devices is also acceptable.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC348378 - Boiler - Heat Transfer Products - 2003 - Sanctuary Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 02/05/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating at time of inspection. Safety devices could not be tested to verify proper operation.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection at a time when the boiler is operating so that safety devices may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of successful testing of these devices is also acceptable.

Location: Glam O Rama Cleaners **Location #:** 1162434 **Violations:** 2
303 Northeast Blvd, , Clinton, NC 28328-2423, Phone: 910-592-5509
Contact: Attn Chris Lee, Owner, Glam O Rama Cleaners, Phone: 910-592-5509, Cell:910-364-2795

Object: NC270483 - Boiler - Weben Jarco - 1992 - Blr Rm - Active **Violations This Object:** 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 11/13/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 11/13/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 26-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 399. Undefined Pressure Relieving Devices Violations.
CONDITION: 399. Undefined Pressure Relieving Devices Violations. PRD reduced flow.
REQUIREMENT: 399. Undefined Pressure Relieving Devices Violations. Determine and correct cause of reduced PRD flow. If necessary, replace PRD with one that is ASAME/NB certified, has a set pressure of not greater than 160 psig, with a relief capacity of not less than 1,440,000 Btu/Hr, and with a testing lever.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Greater Galilee Baptist Church **Location #:** 1793987 **Violations:** 1
501 W Park Ave, , Charlotte, NC 28203-4322, Phone: 704-376-8600
Contact: There is no contact information available for this location.

Object: NC130326 - Boiler - Peerless - 1974 - Bsmt - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 07/11/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not running for inspection. Boiler is installed in a two pipe system. Boiler has been drained for summer time and can not be run due to chillers running.
REQUIREMENT: 363. Undefined Boiler Violations. Inspection delayed until cooler weather when boiler can be readied for operation.

Location: John Umstead Hospital **Location #:** 1802165 **Violations:** 1
1003 12th St, , Butner, NC 27509-1626, Phone: 919-575-7536
Contact: Attn Edd Lovette, John Umstead Hospital, Phone: 919-575-7971

Object: NC370074 - PV - Manchester - 2005 - Bsmt Admin Bldg - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 01/26/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Pressure gauge inoperative.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Install a pressure gauge on the equipment that is visible to the operator from the floor to work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: La Quinta By Wyndham **Location #:** 1804620 **Violations:** 1
1201 Lanada Rd, , Greensboro, NC 27407-2705, Phone: 336-316-0100
Contact: Attn Sherry Shough, General Manager, La Quinta By Wyndham, Phone: 336-316-0100, Cell:434-942-8753

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC422371 - Boiler - Teledyne Laars - 2018 - 2nd Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 12/20/2023 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch is leaking water through the control.
REQUIREMENT: 012. Install a flow switch that will shut off the boiler in case of stoppage of water flow and test to ensure proper operation.

Location: Mars Hill Baptist Church **Location #:** 1808332 **Violations:** 1
67 N Main St, , Mars Hill, NC 28754-9503, Phone: 828-689-2911
Contact: Sharon Welsch, Secretary, Mars Hill Baptist Church, Phone: 828-689-2911

Object: NC262845 - Boiler - Burnham - 1993 - Bsmt Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 12/08/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 003. Required manual reset low water cutoff device not installed.
CONDITION: 003. LWCO and Flow Sensing Devices NCAC 13-13.0409: Required manual reset low water cutoff device not installed. The manual reset function is on the primary LWCO and not the secondary.
REQUIREMENT: 003. Install a low-water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset; or install a manual reset on the existing low water fuel cutoff if appropriate. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: Meridian **Location #:** 1776993 **Violations:** 1
633 W 4th St Ste 200, Winston Salem, NC 27101-2776, Phone: 336-722-1986
Contact: There is no contact information available for this location.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC210442 - Boiler - Raypak - 1984 - Blr Rm 2 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 02/24/2024 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. No access to boiler room.
REQUIREMENT: 363. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341 or richard.parker@labor.nc.gov

Location: Motel 6 Concord Kannapolis **Location #:** 1768043 **Violations:** 1
2808 Lane St, , Kannapolis, NC 28083-9223, Phone: 704-933-5080
Contact: Priyesh Patel, Owner, Motel 6 Concord Kannapolis, Phone: 705-933-5080, Cell:704-502-2444

Object: NC428515 - Boiler - A O Smith - 2020 - Wash Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Coley, Oscar
OPENED: 01/25/2024 **ENTERED BY:** Coley, Oscar
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Thermometer NCAC 13-13.0410
SUBCATEGORY 110. Thermometer not installed.
CONDITION: 110. Thermometer NCAC 13-13.0410: Thermometer not installed.
REQUIREMENT: 110. Install a thermometer at/in the boiler outlet to measure the temperature in degrees Fahrenheit of the water. The thermometer shall have a range of approximately 2 times the intended operating temperature but not less than 1 1/2 times the intended operating temperature, nor more than 4 times the intended operating temperature.

Location: National Guard Armory **Location #:** 1813560 **Violations:** 1
1501 Old Charlotte Rd, , Concord, NC 28027-7082, Phone: 704-786-0123/704-786-0124
Contact: Attn Danny Dottin, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC264351 - Boiler - Weil-McLain - 1993 - Maint Shop Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 10/16/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 003. Required manual reset low water cutoff device not installed.
CONDITION: 003. LWCO and Flow Sensing Devices NCAC 13-13.0409: Required manual reset low water cutoff device not installed.
REQUIREMENT: 003. Install a low-water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset; or install a manual reset on the existing low water fuel cutoff if appropriate. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

Location: National Guard Armory **Location #:** 1814939 **Violations:** 1
845 Spaulding Rd, , Marion, NC 28752-5215, Phone: 828-652-4595
Contact: Attn Danny Dottin, Director of Facility Maintenance, NGA Facilities Maintenance, Phone: 984-664-6094

Object: NC243724 - Boiler - Peerless - 1987 - Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 12/14/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: NC Justice Academy **Location #:** 1802720 **Violations:** 1
3971 Chimney Rock Rd, , Hendersonville, NC 28792-9385, Phone: 828-685-3600
Contact: Doran Harris, Physical Plant Supervisor, NC Justice Academy, Phone: 828-685-1183 X246

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC398527 - Boiler - Lochinvar - 2013 - Cafeteria Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/15/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Location: NC Zoological Park **Location #:** 1813243 **Violations:** 1
4401 Zoo Pkwy, , Asheboro, NC 27205-1425, Phone: 336-879-7500
Contact: Eric 1-Oldham, NC Zoological Park, Phone: 336-879-7530, Cell:919-548-3505

Object: NC439867 - Boiler - Lochinvar - 2022 - Veterinary Bldg Mech Rm 110 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 11/16/2023 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 13-Burners and Fuel Supply Systems
SUBCATEGORY 235. No emergency fuel shut off switch.
CONDITION: 235. Burners and Fuel Supply Systems: No emergency boiler shut off switch at the egress of the room.
REQUIREMENT: 235. Install an emergency boiler shut off switch just outside or just inside the egress of the boiler room to shut off the boiler. Switch must be marked with a sign of indicating it as such.

Location: NCCE Broughton Enterprise Laundry **Location #:** 1805213 **Violations:** 3
1000 S Sterling St, , Morganton, NC 28655-3938, Phone: 828 438 5571
Contact: Leo Witkowski, Manager, NCCE Broughton Enterprise Laundry, Phone: 828 438 5571

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC409010 - Boiler - Miura - 2016 - 2nd Flr Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/15/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. PRD could not be tested during the inspection due to low boiler operating pressure in relation to PRD set pressure rating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler pressure may be adjusted to a suitable level for testing of PRD. As an alternative, a new or recertified ASME/NB stamped PRD having a set pressure of 300 psi or less and a relieving capacity of 6900 pph or more may be installed annually so that testing of PRD is not required. A second alternative would be to install a PRD with a lower set pressure rating in relation to the normal operating pressure. New PRD must have a relieving capacity of 6900 pph or more.

ENTERED BY: Putek, Terry

CLOSED BY:

Object: NC409011 - Boiler - Miura - 2016 - 2nd Flr Mech Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/15/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. PRD could not be tested during the inspection due to low boiler operating pressure in relation to PRD set pressure rating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler pressure may be adjusted to a suitable level for testing of PRD. As an alternative, a new or recertified ASME/NB stamped PRD having a set pressure of 300 psi or less and a relieving capacity of 6900 pph or more may be installed annually so that testing of PRD is not required. A second alternative would be to install a PRD with a lower set pressure rating in relation to the normal operating pressure. New PRD must have a relieving capacity of 6900 pph or more.

ENTERED BY: Putek, Terry

CLOSED BY:

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC409012 - Boiler - Miura - 2016 - 2nd Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 08/15/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. PRD could not be tested during the inspection due to low boiler operating pressure in relation to PRD set pressure rating.
REQUIREMENT: 363. Undefined Boiler Violations. Schedule an inspection when the boiler pressure may be adjusted to a suitable level for testing of PRD. As an alternative, a new or recertified ASME/NB stamped PRD having a set pressure of 300 psi or less and a relieving capacity of 6900 pph or more may be installed annually so that testing of PRD is not required. A second alternative would be to install a PRD with a lower set pressure rating in relation to the normal operating pressure. New PRD must have a relieving capacity of 6900 pph or more.

Location: NCFR Mountain Training Facility **Location #:** 1812324 **Violations:** 1
6065 Linville Falls Hwy, , Newland, NC 28657-8097, Phone: 828-733-4242
Contact: NC Division Of Forest Resources, Phone: 919-857-4801

Object: NC355491 - Boiler - Mestek Canada - 2004 - Bldg B - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 04/17/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 273. Shell leaks.
CONDITION: 273. Boiler Components: Shell leaks.
REQUIREMENT: 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

Location: Old Edwards Inn Conference Center **Location #:** 1880783 **Violations:** 2
21 Church St, , Highlands, NC 28741-2130, Phone: 828-342-0709
Contact: Josh Watson, Engineering Director, Old Edwards Inn Conference Center, Phone: 828 787 2770, Cell:864

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC362255 - Boiler - Rbi - 2005 - Upstairs Blr Rm - Active

Violations This Object: 2

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/07/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Improper storage in boiler room.
REQUIREMENT: 363. Undefined Boiler Violations. Remove items from boiler area. Boxes and combustible material must not be within close proximity to boiler. The boiler room should not be used for storage.

ENTERED BY: Putek, Terry
CLOSED BY:

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 03/07/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Electrical wiring exposed. Covers missing.
REQUIREMENT: 363. Undefined Boiler Violations. Install proper covers on electrical junction boxes. Energized electrical wiring should not be exposed.

ENTERED BY: Putek, Terry
CLOSED BY:

Location: Quality Inn

Location #: 1779023

Violations: 1

1633 Winston Rd, , Jonesville, NC 28642-0126, Phone: 336-835-9400

Contact: Anita Darnell, Manager, Quality Inn, Phone: 336-835-9400

Object: NC240649 - PV - A O Smith - 1989 - Blr Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 07/07/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Tank leaking water.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. If repaired by welding, Welder must have a "R" stamp and be registered with the National Board to weld on vessel. R-1 report must be sent to Raleigh office once repair is completed.

ENTERED BY: Hutchens, Mark
CLOSED BY:

Location: RHA Health Care Services

Location #: 1799026

Violations: 1

5840 Greenwood Dr, , La Grange, NC 28551-6815, Phone: 252-566-9181

Contact: Attn Kevin Wilt, DSPN, RHA Health Care Services LLC, Phone: 252-566-9181, Cell:919-288-9101

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC414516 - Boiler - Sermeta - 2017 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Rudolph, Jay
OPENED: 12/18/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 01-LWCO and Flow Sensing Devices NCAC 13-13.0409
SUBCATEGORY 012. Flow switch inoperative or bypassed.
CONDITION: 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch inoperative or bypassed. Flow switch internal leak.
REQUIREMENT: 012. Install a flow switch that will shut off the fuel supply in case of stoppage of water flow or a low-water condition and test to ensure proper operation.

Location: Rutherford Regional Health System **Location #:** 1826126 **Violations:** 1
288 S Ridgecrest Ave, , Rutherfordton, NC 28139-2838, Phone: 828-286-5373
Contact: Attn Jon Tidball, Director Plt Operations And Maintenance Security, Rutherford Regional Health System,

Object: NC228447 - PV - Bell & Gossett - 1987 - 3rd Flr Mech Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 02/07/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Vessel leaking from shell.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Repair the leaking shell. If weld repairs are required, a qualified 'R' certificate holder is necessary to perform the work.

Location: Shores Fine Fabric Care **Location #:** 590910 **Violations:** 1
804 Westchester Dr, , High Point, NC 27262-7347, Phone: 336-886-4009
Contact: Attn David King, Shores Fine Fabric Care, Phone: 336-886-4009

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC378909 - Boiler - Parker - 2009 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 02/14/2024 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 03-Water Gauge Glass NCAC 13-13.0408
SUBCATEGORY 054. Glass is too cloudy to see water level.
CONDITION: 054. Water Gauge Glass NCAC 13-13.0408: Sight glass is corroded water level is not visible.
REQUIREMENT: 054. Clean or replace the sight glass with material designed for temperature and service.

Location: Siloam Cleaners **Location #:** 1829224 **Violations:** 1
1415 Emerywood Dr, , Charlotte, NC 28210-4105, Phone: 704-553-1769
Contact: Attn Yong Chol Lee, Owner, Siloam Cleaners, Phone: 704-608-9065

Object: NC341562 - PV - Trinity - 2001 - Outside Rear - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 05/18/2022 **ENTERED BY:** Judd, Janie
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 04-Installation of PRDs NCAC 13-13.0405
SUBCATEGORY 452. Set pressure too high.
CONDITION: 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.
REQUIREMENT: 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Snider Tire **Location #:** 595705 **Violations:** 1
200 E Meadowview Rd, , Greensboro, NC 27406-4521, Phone: 336-691-5480
Contact: Attn Glen Blackburn, Retread Manager, Snider Tire Inc, Phone: 336-691-5480 X133, Cell:336-669-7352

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC384478 - Boiler - Parker - 2009 - Production Area - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 02/07/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 02-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 033. Inoperative.
CONDITION: 033. Pressure Gauges NCAC 13-13.0407: Inoperative.
REQUIREMENT: 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Solenis **Location #:** 4074675 **Violations:** 1
2408 Doyle St, , Greensboro, NC 27406-2912, Phone: 336-335-3777
Contact: Attn Paul Ritchey, Plant Engineer, Solenis, Phone: 336-335-3777, Cell:336-897-8840

Object: NC355916 - PV - Wolfe Mech - 2004 - P3 T-0402 - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Johnson, Dean
OPENED: 10/17/2023 **ENTERED BY:** Johnson, Dean
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. Pinhole in bottom head to shell circumferential weld.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Hydro test vessel to determine extent of leak. If welding is required for this repair, such welding must be performed by a 'R' Stamp Holder. R-1 Repair of Repair must be returned to this Inspector.

Location: St James Lutheran Church **Location #:** 607322 **Violations:** 1
104 Union St S, , Concord, NC 28025-5012, Phone: 704-786-0166
Contact: Attn Debbie Wilkinson, St James Lutheran Church, Phone: 704-786-0166

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC359026 - Boiler - Weil-McLain - 2005 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Clay, Steven
OPENED: 12/12/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 16-Boiler Components
SUBCATEGORY 270. Water Leaks.
CONDITION: 270. Boiler Components: Water Leaks. Indication of small leak noted between sections.
REQUIREMENT: 270. Repair the water leaks identified on the inspection report.

Location: Take 5 Oil Change **Location #:** 4113898 **Violations:** 1
8175 Fayetteville Rd, , Raleigh, NC 27603-5635, Phone: 919-424-7600
Contact: There is no contact information available for this location.

Object: NC433919 - PV - Morganton - 2021 - Comp Room - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 12/15/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 06-Undefined Pressure Relieving Devices Violations
SUBCATEGORY 478. Undefined Pressure Relieving Devices Violations.
CONDITION: 478. Undefined Pressure Relieving Devices Violations. Pressure gauge inoperative.
REQUIREMENT: 478. Undefined Pressure Relieving Devices Violations. Install a pressure gauge on the equipment that is visible from the floor to work platform, Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Location: Tortilla Factory **Location #:** 1786084 **Violations:** 1
2390 E Sprague St, , Winston Salem, NC 27107-2441, Phone: 336-749-3227
Contact: Attn Edixon Baca, Tortilla Factory Inc, , Cell:336-995-0755

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC416436 - Boiler - Parker - 2017 - Blr Rm - Active **Violations This Object:** 1

COMPANY: State of North Carolina
INSPECTOR: Parker, Richard
OPENED: 02/22/2024 **ENTERED BY:** Parker, Richard
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Controls Violations
SUBCATEGORY 112. Undefined Controls Violations.
CONDITION: 112. Overdue for operational inspection.
REQUIREMENT: 112. Contact inspector and schedule inspection.

contact Richard Parker @ 336-202-8341 or richard.parker@labor.nc.gov

Location: Tri County Industries **Location #:** 1837475 **Violations:** 2
1250 Atlantic Ave, , Rocky Mount, NC 27801-2710, Phone: 252-977-3800
Contact: Reba Marshmon, Office Manager, Tri County Industries Inc, Phone: 252-977-3800

Object: NC218820 - PV - Brunner - 1982 - Shipping Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 02/20/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 032. Incorrect range or insufficient pointer travel.
CONDITION: 032. Pressure Gauges NCAC 13-13.0407: Incorrect range or insufficient pointer travel.
REQUIREMENT: 032. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Object: NC245422 - PV - Brunner - 1987 - Rear Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 02/20/2024 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 09-Pressure Gauges NCAC 13-13.0407
SUBCATEGORY 032. Incorrect range or insufficient pointer travel.
CONDITION: 032. Pressure Gauges NCAC 13-13.0407: Incorrect range or insufficient pointer travel.
REQUIREMENT: 032. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Location: Trinity United Methodist Church **Location #:** 1837775 **Violations:** 1
587 Haywood Rd, , Asheville, NC 28806-3553, Phone: 828-253-5471
Contact: Attn Lee Thomas, Custodian, Trinity United Methodist Church, Phone: 828-253-5471

Object: NC323891 - Boiler - Weil-McLain - 2000 - Ed Bldg Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 10/04/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 396. Missing nameplate.
CONDITION: 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.
REQUIREMENT: 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: Wayne Farms **Location #:** 1842292 **Violations:** 1
10949 NC 268, , Elkin, NC 28621-8790, Phone: 336-366-4471
Contact: Attn C Cassell, Wayne Farms Llc, Phone: 336-386-8151

Object: NC324117 - PV - Bryan - 2000 - New Blr Rm 1200 Bldg - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Leonard, Shannon
OPENED: 06/27/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations. A leaking gasket was observed on a blank flange on tank.
REQUIREMENT: 479. Undefined Pressure Vessels Violations. Replace the leaking gasket. If additional welded repairs are required to stop leakage, they must be performed by a qualified 'R' stamp holder.

Location: Woodgrain Millworks **Location #:** 1222941 **Violations:** 2
810 Complex Pl, , Lenoir, NC 28645-8338, Phone: 828-754-9037
Contact: David Burns, Supervisor, Woodgrain Millworks Inc, Phone: 828-754-9037, Cell:828-612-6850

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC400052 - Boiler - Johnston - 2002 - Lumberyard - Active **Violations This Object:** 2

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 07/21/2023 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. R-1 report on welking preformed on tubing.
REQUIREMENT: 363. Undefined Boiler Violations. A R-1 report must be filled out on retubing before cert released on boiler.

COMPANY: State of North Carolina
INSPECTOR: Hutchens, Mark
OPENED: 07/26/2023 **ENTERED BY:** Hutchens, Mark
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Found four more tubes leaking on boiler during hydro test.
REQUIREMENT: 363. Undefined Boiler Violations. If repaired by welding, Welder must have a "R" stamp and be registered with rhe National Board to weld on boiler. A R-1 report filled out on repair and sent to Raleigh Office.

Location: Woodhaven Baptist Church **Location #:** 1845073 **Violations:** 1
4000 Kildaire Farm Rd, , Apex, NC 27539-8838, Phone: 919-362-0127
Contact: Emily Hayne, Admin, Woodhaven Baptist Church,

Object: NC272210 - Boiler - Raypak - 1992 - Blr Rm - Active **Violations This Object:** 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Sorrentino, Sean
OPENED: 08/21/2023 **ENTERED BY:** Putek, Terry
CLOSED: **CLOSED BY:**
TYPE: Certificate Blocking
CATEGORY: 23-Undefined Boiler Violations
SUBCATEGORY 363. Undefined Boiler Violations.
CONDITION: 363. Undefined Boiler Violations. Boiler not operating.
REQUIREMENT: 363. Undefined Boiler Violations. Operate boiler in order to test PRD and LWCOs.

Location: YMCA Of Western NC **Location #:** 1845627 **Violations:** 1
810 6th Ave W, , Hendersonville, NC 28739-4138, Phone: 828-692-5774
Contact: Rick Holden, Property Manager, YMCA Of Western NC, Phone: 828-692-5774, Cell:828-808-1137

Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

Object: NC346968 - Boiler - Rbi - 2003 - Blr Rm - Active

Violations This Object: 1

COMPANY: Hartford Steam Boiler
INSPECTOR: Possidente, James
OPENED: 01/25/2024
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 25-Operation of PRDs NCAC 13-13.0405
SUBCATEGORY 395. Valve leaking.
CONDITION: 395. Operation of PRDs NCAC 13-13.0405: Valve leaking. SV leaking but lifted OK.
REQUIREMENT: 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

Location: ZHF Group Llc

Location #: 1798444

Violations: 1

100 West St, , Oxford, NC 27565-2943, Phone: 919-693-1002

Contact: There is no contact information available for this location.

Object: NC154323 - PV - Wayne - 1970 - Comp Rm - Active

Violations This Object: 1

COMPANY: State of North Carolina
INSPECTOR: Gunto III, Andrew
OPENED: 10/10/2023
CLOSED:
TYPE: Certificate Blocking
CATEGORY: 07-Undefined Pressure Vessels Violations
SUBCATEGORY 479. Undefined Pressure Vessels Violations.
CONDITION: 479. Undefined Pressure Vessels Violations.
At the time of this objects 10/10/23 inspection an operational demonstration was not done.
REQUIREMENT: 479. Undefined Pressure Vessels Violations.
Before the issuance of the required Inspection Certificate, an operational demonstration must be done.

Violations This Report: 201

Locations This Report: 128