

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Location:** (CATAWBA COLL) Corriher Linn Black Library **Location #:** 1806082 **Violations:** 1  
2300 W Innes St, , Salisbury, NC 28144-2441, Phone: 704-637-4111  
**Contact:** Billy White, Supervisor of Facilities, Catawba College, Phone: 704-645-4502, Cell:704-232-9173

**Object:** NC419578 - Boiler - Peerless - 2018 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 10/14/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 006. Low water cutoff device inoperative or bypassed.  
**CONDITION:** 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.  
**REQUIREMENT:** 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

---

**Location:** (CATAWBA COLL) Robertson College Community Center **Location #:** 1774906 **Violations:** 1  
2300 W Innes St, , Salisbury, NC 28144-2441, Phone: 704-637-4111  
**Contact:** Billy White, Supervisor of Facilities, Catawba College, Phone: 704-645-4502, Cell:704-232-9173

**Object:** NC286542 - Boiler - Teledyne Laars - 1998 - Bsmt Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 08/24/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; could not test low water cutoff (LWCO) and pressure relief device (PRD).  
**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the LWCO and PRD may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of the successful testing of these devices is also acceptable.

---

**Location:** (CRAVEN) Judicial Center **Location #:** 2410700 **Violations:** 1  
1100 Clarks Rd, , New Bern, NC 28562-9730, Phone: 252-636-6679  
**Contact:** Brian Fultz, Maintenance Tech III, Craven County Judicial Center, Phone: 252-636-6624, Cell:252-671-2189

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC375104 - Boiler - Patterson Kelley - 2008 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 07/01/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405

**SUBCATEGORY** 395. Valve leaking.

**CONDITION:** 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure relief device leaking

**REQUIREMENT:** 395. Replace pressure relief device with a ASME certified pressure relief device with a set pressure of not greater than 100 psig, with a relief capacity of not less than 1,940,000 BTU/hr, and has a testing lever.

---

**Location:** (CRAVEN) New Bern Riverfront Convention Center

**Location #:** 1780796

**Violations:** 1

203 S Front St, , New Bern, NC 28560-2135, Phone: 252-637-1551

**Contact:** Attn Steve Creel, Maintenance Director, Craven County Government, Phone: 252-636-6613, Cell:252-670-

---

**Object:** NC392065 - Boiler - Rheem - 2012 - Wtr Htr #2 Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 07/01/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 16-Boiler Components

**SUBCATEGORY** 270. Water Leaks.

**CONDITION:** 270. Boiler Components: Water Leaks.

**REQUIREMENT:** 270. Repair the water leaks identified on the inspection report. Replace vessel

---

**Location:** (DPS-C) Johnston CI - 4230

**Location #:** 1802369

**Violations:** 7

2465 US Highway 70 W, , Smithfield, NC 27577-7617, Phone: 919-934-8386

**Contact:** Attn Frank Hobbs, Facility Maintenance Supervisor 3, (DPS-C) Johnston CI - 4230, Phone: 919-934-8386

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC246866 - Boiler - Peerless - 1989 - Dorm 1041 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 08/12/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating

**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for when the boiler can be operated so that safety devices can be verified to operate properly.

---

**Object:** NC246868 - Boiler - A O Smith - 1990 - Dorm 1041 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 08/12/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

**SUBCATEGORY** 020. Leaking gasket or joints.

**CONDITION:** 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking flow switch.

**REQUIREMENT:** 020. Repair or replace flow switch. Test to verify proper operation.

---

**Object:** NC249976 - Boiler - Peerless - 1991 - Dorm 1043 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 08/12/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating.

**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for when the boiler can be operated so that safety devices can be verified to operate properly.

---

**Object:** NC269593 - Boiler - Weil-McLain - 1994 - Dorm 1044 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 08/12/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating.

**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for when the boiler can be operated so that safety devices can be verified to operate properly.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC294205 - Boiler - Teledyne Laars - 1997 - Bldg 100 - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 08/12/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating.  
**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for when the boiler can be operated so that safety devices can be verified to operate properly.

---

**Object:** NC343225 - Boiler - A O Smith - 2001 - Dorm 1042 - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 08/12/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 020. Leaking gasket or joints.  
**CONDITION:** 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints: Leaking flow switch.  
**REQUIREMENT:** 020. Repair or replace flow switch. Test to verify proper operation.

---

**Object:** NC407118 - Boiler - A O Smith - 2015 - Dorm 1044 - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 08/12/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 020. Leaking gasket or joints.  
**CONDITION:** 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket or joints: Leaking flow switch.  
**REQUIREMENT:** 020. Repair or replace flow switch. Test to verify proper operation.

---

**Location:** (DPS-C) Lanesboro CI - 4865 **Location #:** 1805021 **Violations:** 1  
552 Prison Camp Rd, , Polkton, NC 28135-6118, Phone: 704-695-1013  
**Contact:** NC Dept Of Public Safety - 13101, Phone: 919-716-3422

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC340797 - Boiler - Cleaver Brooks - 2002 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 06/07/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler could not run due to missing components.

**REQUIREMENT:** 363. Undefined Boiler Violations. Boiler is scheduled to be reinspected or disconnected.

---

**Location:** (DPS-C) Lanesboro Minimum CI - 3510

**Location #:** 1770840

**Violations:** 3

248 Prison Camp Rd, , Polkton, NC 28135-6115, Phone: 704-694-2622

**Contact:** Ernie Thomas, Maintenance Supervisor, Brown Creek CI - 3510, Phone: 704-694-2622 X222 X285

---

**Object:** NC251876 - Boiler - Peerless - 1991 - Blr Rm Unit 6 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 07/19/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409

**SUBCATEGORY** 022. Faulty electrical wiring.

**CONDITION:** 022. LWCO and Flow Sensing Devices NCAC 13-13.0409: Faulty electrical wiring. LWCO (float) wired backwards.

**REQUIREMENT:** 022. Repair or replace the faulty electrical wiring and test control to ensure proper operation.

---

**Object:** NC251882 - Boiler - Lochinvar - 1991 - Blr Rm Unit 5 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 07/19/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 24-Installation of PRDs NCAC 13-13.0405

**SUBCATEGORY** 378. Discharge opening directed improperly.

**CONDITION:** 378. Installation of PRDs NCAC 13-13.0405: Discharge opening directed improperly. Discharge piping not installed on PRD.

**REQUIREMENT:** 378. Redirect the discharge to a safe point at required in NCAC 13-13.0405.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC396137 - Boiler - Teledyne Laars - 2011 - Outside Admin Bldg - **Violations This Object:** 1  
Active

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Clay, Steven D.  
**OPENED:** 07/22/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler would not run for inspection due to controls and hot weather.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule the inspection when the boiler is in operation so that safety devices can be tested.

---

**Location:** (DPS-C) NCCIW - 3010  
1034 Bragg St, , Raleigh, NC 27610-3846, Phone: 919-733-4340  
**Contact:** Phillip Jones, Maintenance Supervisor, NCCIW - 3010, Phone: 919-508-1690

**Location #:** 1779964

**Violations:** 2

---

**Object:** NC381483 - Boiler - PVI Industries - 2010 - Falcom Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 12/08/2020  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 16-Boiler Components  
**SUBCATEGORY** 270. Water Leaks.  
**CONDITION:** 270. Boiler Components: Water Leaks.  
**REQUIREMENT:** 270. Repair the water leaks identified on the inspection report. If welding is required, a qualified "R" certificate holder is necessary to perform the repair.

**ENTERED BY:** Keyes, Amanda  
**CLOSED BY:**

---

**Object:** NC401596 - Boiler - PVI Industries - 2014 - Sparrow N - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 12/08/2020  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 16-Boiler Components  
**SUBCATEGORY** 270. Water Leaks.  
**CONDITION:** 270. Boiler Components: Water Leaks. Tank leaking at unknown location.  
**REQUIREMENT:** 270. Repair the water leaks identified on the inspection report. If welding is required, a qualified "R" certificate holder is necessary to perform the repair.

**ENTERED BY:** Keyes, Amanda  
**CLOSED BY:**

---

**Location:** (DPS-C) New Hanover CC - 4170  
330 Division Dr, , Wilmington, NC 28401-8883, Phone: 910-251-2666  
**Contact:** NC Dept Of Public Safety - 13101, Phone: 919-716-3422

**Location #:** 1814361

**Violations:** 2

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC248063 - Boiler - Teledyne Laars - 1991 - Food Services Bldg - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 08/11/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating  
**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for a time the boiler can be operated so that safety devices can be verified to operate properly.

---

**Object:** NC409777 - Boiler - Weil-McLain - 2016 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 08/11/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating.  
**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for a time the boiler can be operated so that safety devices can be verified to operate properly.

---

**Location:** (FSU) Honors Residence Hall **Location #:** 1931474 **Violations:** 1  
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881  
**Contact:** Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,

---

**Object:** NC424720 - Boiler - Raypak - 2019 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/30/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 012. Flow switch inoperative or bypassed.  
**CONDITION:** 012. LWCO and Flow Sensing Devices NCAC 13-13.0409: Flow switch leaking.  
**REQUIREMENT:** 012. Repair or replace flow switch. Test to verify proper operation.

---

**Location:** (FSU) Jones Student Center **Location #:** 1931441 **Violations:** 3  
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1881  
**Contact:** Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC397629 - Boiler - Aerco - 2013 - Blr Rm Behind New Addition - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/30/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not running.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Reschedule inspection for a time when the boiler is operating so that safety devices can be verified to operate properly

---

**Object:** NC400960 - Boiler - A O Smith - 2013 - Bronco Bldg - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/30/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 394. Valve inoperative.  
**CONDITION:** 394. Operation of PRDs NCAC 13-13.0405: Pressure Relief Device inoperative.  
**REQUIREMENT:** 394. Immediately replace with a ASME/NB certified pressure relief device with a set pressure of not greater than 160 psig, with a relief capacity of not less than 500,000 BTU/hr, and with a testing lever.

---

**Object:** NC430888 - Boiler - AO SMITH - 2019 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Bailey, Derek  
**OPENED:** 10/18/2021 **ENTERED BY:** Bailey, Derek  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 396. Missing nameplate.  
**CONDITION:** 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.  
**REQUIREMENT:** 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

---

**Location:** (FSU) Nursing School **Location #:** 2864083 **Violations:** 1  
1200 Murchison Rd, , Fayetteville, NC 28301-4252, Phone: 910-672-1433  
**Contact:** Attn Allen Hearon PO#0032868, Facility Management, Fayetteville State University, Phone: 910-672-1881,



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC382403 - Boiler - Hydrotherm - 2010 - Mech Rm 1st Flr - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/30/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Reschedule inspection for a time when the boiler is operating so that safety devices can be verified to operate properly.

---

**Location:** (FTCC) Spring Lake Campus **Location #:** 1831819 **Violations:** 1  
171 Laketree Blvd, , Spring Lake, NC 28390-3189, Phone: 910-678-1000  
**Contact:** Attn Scott Ivy, Maintenance Supervisor, Fayetteville Technical Community College, , Cell:910-740-7838

---

**Object:** NC352133 - Boiler - Weil-McLain - 2003 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 10/07/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 395. Valve leaking.  
**CONDITION:** 395. Operation of PRDs NCAC 13-13.0405: Pressure relief device leaking.  
**REQUIREMENT:** 395. Immediately replace with a ASME/NB certified pressure relief device with a set pressure of not greater than 50 psig, with a relief capacity of not less than 1,904,000 BTU/hr, and with a testing lever.

---

**Location:** (FTCC) YMCA Sandhills **Location #:** 2227097 **Violations:** 2  
2717 Fort Bragg Rd, , Fayetteville, NC 28303-4720, Phone: 910-426-9622  
**Contact:** Attn Scott Ivy, Maintenance Supervisor, Fayetteville Technical Community College, , Cell:910-740-7838

---

**Object:** NC379617 - Boiler - Reimers - 2009 - Womens Steam Rm - Active **Violations This Object:** 2

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/15/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 03-Water Gauge Glass NCAC 13-13.0408  
**SUBCATEGORY** 058. Leaking.  
**CONDITION:** 058. Water Gauge Glass NCAC 13-13.0408: Leaking.  
**REQUIREMENT:** 058. Repair or replace the leaking gauge and test to ensure proper operation.

---

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 09/15/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 395. Valve leaking.  
**CONDITION:** 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure relief device leaking.  
**REQUIREMENT:** 395. Replace pressure relief device with a ASME/NB certified pressure relief device with a set pressure of not greater than 100 psig, with a relief capacity of not less than 105 pounds per hour, and with a testing lever.

---

**Location:** (LEX CS) Lexington Senior High  
26 Penry St, , Lexington, NC 27292-2638, Phone: 336-242-1574  
**Contact:** Finance, Lexington City Schools, Phone: 336-242-1527

**Location #:** 1805975      **Violations:** 2

**Object:** NC260793 - Boiler - Peerless - 1993 - Blr Rm 2 - Active      **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 07/29/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC260794 - Boiler - Peerless - 1993 - Blr Rm 2 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 07/29/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable.

---

**Location:** (LEX CS) Pickett Primary

**Location #:** 1819089

**Violations:** 1

200 Biesecker Rd, , Lexington, NC 27295-1501, Phone: 336-242-1546

**Contact:** Finance, Lexington City Schools, Phone: 336-242-1527

---

**Object:** NC224866 - Boiler - Weil-McLain - 1986 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 07/29/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler was not operating at time of inspection; low water cutoff (LWCO) and pressure relief device (PRD) could not test to verify proper operation

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

---

**Location:** (MARTIN CS) Jamesville Elem

**Location #:** 1801377

**Violations:** 1

1220 Hardison St, , Jamesville, NC 27846-2784, Phone: 252-792-6637

**Contact:** Martin County Schools, Phone: 252-792-1575

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC369163 - Boiler - Lochinvar - 2007 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 10/19/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405

**SUBCATEGORY** 395. Valve leaking.

**CONDITION:** 395. Operation of PRDs NCAC 13-13.0405: Valve leaking: Pressure relief device leaking.

**REQUIREMENT:** 395. Replace pressure relief device with a ASME/NB certified pressure relief device with a set pressure of not greater than 160 PSIG, with a relief capacity appropriate to achieve a combined relief capacity of not less than 2,000,000 BTU/HR, and with a testing lever.

---

**Location:** (MARTIN CS) Rodgers Elem

**Location #:** 1825274

**Violations:** 1

2277 Rodgers School Rd, , Williamston, NC 27892-8249, Phone: 252-792-6637

**Contact:** Martin County Schools, Phone: 252-792-1575

---

**Object:** NC303644 - Boiler - Weil-McLain - 1996 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Rudolph, Jay

**OPENED:** 10/19/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 12-Casing, Stack Breeching and Flue

**SUBCATEGORY** 211. Combustion gas leaks.

**CONDITION:** 211. Casing, Stack Breeching and Flue: Combustion gas leaks.

**REQUIREMENT:** 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

---

**Location:** (MARTIN CS) WC Chance Center

**Location #:** 1785250

**Violations:** 1

1121 3rd Street Ext, , Robersonville, NC 27871-9389, Phone: 252-792-6637

**Contact:** Sondra McCleary, Administrator, WC Chance Center, Phone: 252-799-6853

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC303631 - Boiler - Weil-McLain - 1996 - Blr Rm 61 - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Rudolph, Jay  
**OPENED:** 10/20/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating.  
**REQUIREMENT:** 363. Undefined Boiler Violations: Reschedule inspection for a time the boiler is running so that safety devices can be verified to operate properly.

---

**Location:** (MH UNIV) Dogwood Residence Hall **Location #:** 3357213 **Violations:** 1  
400 Park Dr, , Mars Hill, NC 28754-6519, Phone: 828-689-1246  
**Contact:** Attn David May, Director Of Facilities, Mars Hill University, Phone: 828-689-1172, Cell:864-653-0230

---

**Object:** NC395566 - Boiler - A O Smith - 2013 - 1st Flr Mech Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Possidente, James  
**OPENED:** 09/15/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 16-Boiler Components  
**SUBCATEGORY** 273. Shell leaks.  
**CONDITION:** 273. Boiler Components: Shell leaks.  
**REQUIREMENT:** 273. Repair the leaking shell. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

---

**Location:** (NC A&T) Band Bldg **Location #:** 1776866 **Violations:** 1  
1120 E Bessemer Ave, , Greensboro, NC 27405-7106, Phone: 336-334-7025  
**Contact:** NC A & T State University, Phone: 336-334-3806

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC007630 - Boiler - Atlantic - 1948 - Blr Rm 1 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/08/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

---

**Location:** (NC A&T) Bluford Library

**Location #:** 1900678

**Violations:** 1

1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025

**Contact:** NC A & T State University, Phone: 336-334-3806

---

**Object:** NC250889 - Boiler - Bryan - 1989 - Penthouse - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 06/17/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable.

---

**Location:** (NC A&T) C H Moore Agricultural

**Location #:** 1900558

**Violations:** 2

1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025

**Contact:** NC A & T State University, Phone: 336-334-3806

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC239390 - Boiler - Weil-McLain - 1988 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 06/17/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

---

**Object:** NC343287 - Boiler - Lochinvar - 2003 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 06/17/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable.

---

**Location:** (NC A&T) Coltrane Hall

**Location #:** 2921477

**Violations:** 1

1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025

**Contact:** Ricky Richmond, Facilities Manager, NC A & T State University, Phone: 336-285-4583, Cell:336-906-9620



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC383297 - Boiler - Giannoni - 2010 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 06/17/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection; pressure relief device (PRD) and low water cutoff (LWCO) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the PRD and LWCO may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

---

**Location:** (NC A&T) T E Neal Heating Plt

**Location #:** 1834439

**Violations:** 1

1601 E Market St, , Greensboro, NC 27411-0002, Phone: 336-334-7025

**Contact:** Ricky Richmond, Facilities Manager, NC A & T State University, Phone: 336-285-4583, Cell:336-906-9620

---

**Object:** NC206485 - Boiler - Nebraska - 1982 - Power House Blr 4 - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/08/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Evidence of tube leakage present on the outter wall of the fire box.

**REQUIREMENT:** 363. Undefined Boiler Violations. Identify all leaking tubes and make repairs as necessary to correct this condition. If welded repairs are required, these must be performed by a qualified "R" certificate holder.

---

**Location:** (NC A&T) University Farm

**Location #:** 1820542

**Violations:** 1

3136 McConnell Rd, , Greensboro, NC 27405-9610, Phone: 336-398-8690

**Contact:** Ricky Richmond, Facilities Manager, NC A & T State University, Phone: 336-285-4583, Cell:336-906-9620

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC431629 - PV - Steel Fab - 2005 - Dairy Barn - Active

**Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Johnson, Dean  
**OPENED:** 09/13/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 05-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 476. Missing nameplate.  
**CONDITION:** 476. Operation of PRDs NCAC 13-13.0405: Safety valve stamping is illegible.  
**REQUIREMENT:** 476. Install a 1/4" ASME/NB stamped safety valve having a set pressure not exceeding 200 psi and a minimum relieving capacity of 60 scfm. Valve must have a test lever or pull ring.

---

**Location:** (NCSU) Lake Wheeler Rd Field Lab DEU-Z5

**Location #:** 2155086

**Violations:** 3

3720 Lake Wheeler Rd, , Raleigh, NC 27603-3334, Phone: 919-513-6485

**Contact:** Attn Andrew Langdon, Supv, Lake Wheeler Road Field Lab DEU-Z5, Phone: 919-513-6485

---

**Object:** NC247867 - PV - John Wood - 1956 - Office Dock - Active

**Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 07/27/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 05-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 474. Valve inoperative.  
**CONDITION:** 474. Operation of PRDs NCAC 13-13.0405: Valve inoperative.  
**REQUIREMENT:** 474. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

---

**Object:** NC431970 - Boiler - Lochinvar - 2020 - Milk Mech Rm - Active

**Violations This Object:** 2

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 08/25/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 05-Temperature Controls NCAC 13-13.0406  
**SUBCATEGORY** 093. High limit temperature control inoperative.  
**CONDITION:** 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.  
**REQUIREMENT:** 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 08/25/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 13-Burners and Fuel Supply Systems  
**SUBCATEGORY** 235. No emergency fuel shut off switch.  
**CONDITION:** 235. Burners and Fuel Supply Systems: No emergency fuel shut off switch.  
**REQUIREMENT:** 235. Install an emergency fuel shut off switch at each egress from the boiler room to shut off all fuel to the boilers.

---

**Location:** (NCSU) Pulp & Paper Labs Z3  
431 Dan Allen Dr, , Raleigh, NC 27695-0001, Phone: 919-515-9902  
**Contact:** James Lindsey, Pulp & Paper Labs 113B-Z3, Phone: 919-515-9902

**Location #:** 2154347

**Violations:** 1

**Object:** NC431284 - PV - Samuel Pressure Vessel Group - 2020 - 2nd Flr  
Pilot Plt Mezzanine - Active

**Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 06/16/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 04-Installation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 452. Set pressure too high.  
**CONDITION:** 452. Installation of PRDs NCAC 13-13.0405: Set pressure too high.  
**REQUIREMENT:** 452. Replace the pressure relieving device with one with a set pressure no higher than the maximum allowable working pressure as determined by the manufacturer.

---

**Location:** (NRMS) Nash Central Middle  
1638 S 1st St, , Nashville, NC 27856-9342, Phone: 252-937-5632  
**Contact:** Nash Rocky Mount Public Schools, Phone: 252-451-8500

**Location #:** 1813375

**Violations:** 1

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC229915 - Boiler - Weil-McLain - 1988 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** State of North Carolina

**INSPECTOR:** Harrell, Danny

**OPENED:** 10/08/2021

**ENTERED BY:** Harrell, Danny

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 12-Casing, Stack Breeching and Flue

**SUBCATEGORY** 211. Combustion gas leaks.

**CONDITION:** 211. Casing, Stack Breeching and Flue: Combustion gas leaks. Personnel carbon monoxide detector alarmed while boiler was operation. Found flue gas leak on the exhaust flue between boiler and the chimney stack .

**REQUIREMENT:** 211. Repair all combustion gas leaks in the casing, stack breeching, or flue. Contact Danny Harrell @ 919-500-3098 when the repair is completed to schedule a re-inspection.

---

**Location:** (UNCC) Regional Utility Plt 1

**Location #:** 1930002

**Violations:** 1

9201 University City Blvd, , Charlotte, NC 28223-0001, Phone: 704-687-6993

**Contact:** Attn Kelly Herron, UNC Charlotte, Phone: 704-687-0567

---

**Object:** NC328646 - Boiler - Hurst - 2002 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 02/10/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 16-Boiler Components

**SUBCATEGORY** 275. Tube/tube ends leak.

**CONDITION:** 275. Boiler Components: Tube/tube ends leak. Boiler is down for repairs.

**REQUIREMENT:** 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

---

**Location:** A Cleaner

**Location #:** 1761407

**Violations:** 1

4506 W Gate City Blvd, , Greensboro, NC 27407-4238, Phone: 336-676-4309

**Contact:** Attn Phillip Sim, Manager, A Cleaner, Phone: 336-676-4309

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC406736 - Boiler - Fulton - 2016 - Blr Rm - Active

**Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 10/19/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 020. Leaking gasket or joints.  
**CONDITION:** 020. LWCO and Flow Sensing Devices NCAC 13-13.0409: Leaking gasket on low water cutoff (LWCO) drainage plumbing.  
**REQUIREMENT:** 020. Replace the leaking pipe joint in the LWCO drainage plumbing in order to correct this condition.

---

**Location:** A Cleaner World #205

**Location #:** 1761485

**Violations:** 1

2321 Davis Dr, , Cary, NC 27519-8480, Phone: 919-461-1722

**Contact:** Attn Mike Smith, Owner, A Cleaner World #205, Phone: 919-461-1722

---

**Object:** NC387995 - Boiler - Parker - 2010 - Blr Rm - Active

**Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 09/13/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 03-Water Gauge Glass NCAC 13-13.0408  
**SUBCATEGORY** 050. Water gauge glass not installed.  
**CONDITION:** 050. Water Gauge Glass NCAC 13-13.0408: Water gauge glass not installed.  
**REQUIREMENT:** 050. Install a visible gauge glass in the steam column or connected to the steam space in the boiler. The gauge glass will be so located so that it is visible to the operator while reading the boiler pressure gauge.

---

**Location:** Blue Ridge Preservation

**Location #:** 1827367

**Violations:** 1

136 Virgil Day Rd, , Boone, NC 28607-9464, Phone: 828-264-6040

**Contact:** Attn Corey Arbogost, Property Manager, Blue Ridge Preservation Inc, , Cell:603-801-8211

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC429535 - Boiler - AIC Tuchom - 2020 - Bsmt - Active

**Violations This Object:** 1

**COMPANY:** State of North Carolina

**INSPECTOR:** Hutchens, Mark

**OPENED:** 08/31/2021

**ENTERED BY:** Hutchens, Mark

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 07-Undefined Controls Violations

**SUBCATEGORY** 112. Undefined Controls Violations.

**CONDITION:** 112. Undefined Controls Violations. Unable to test safety's on boiler due to warm weather.

**REQUIREMENT:** 112. Undefined Controls Violations. Boiler must be in operation to test safety's on boiler.

---

**Location:** Brookdale Reynolda Road

**Location #:** 1824122

**Violations:** 1

2980 Reynolda Rd, , Winston Salem, NC 27106-3047, Phone: 336-722-1617

**Contact:** There is no contact information available for this location.

---

**Object:** NC338711 - Boiler - Rheem/Ruud - 1996 - Kitchen Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 10/19/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 14-Blr Mfr's Data Rpt/Nameplate NCAC 13-13.0401

**SUBCATEGORY** 251. Nameplate Stamping Is Incorrect, Missing, or Illegible.

**CONDITION:** 251. Blr Mfr's Data Rpt/Nameplate NCAC 13-13.0401: Nameplate Stamping Is Incorrect, Missing, or Illegible: Nameplate corroded and the National Board Number stamping is illegible.

**REQUIREMENT:** 251. Obtain a replacement nameplate from the manufacturer or a replacement in accordance with the National Board Inspection Code.

---

**Location:** Canterbury School

**Location #:** 3322604

**Violations:** 2

5400 Old Lake Jeanette Rd, , Greensboro, NC 27455-1322, Phone: 336-288-2007

**Contact:** Attn Jeffrey Davis, Canterbury School, Phone: 336-288-2007, Cell:336-215-1881

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

**Object:** NC431614 - Boiler - Rbi - 2021 - Outside Mech Area - Active

**Violations This Object:** 2

<b>COMPANY:</b>	State of North Carolina		
<b>INSPECTOR:</b>	Johnson, Dean		
<b>OPENED:</b>	09/07/2021	<b>ENTERED BY:</b>	Johnson, Dean
<b>CLOSED:</b>		<b>CLOSED BY:</b>	
<b>TYPE:</b>	Certificate Blocking		
<b>CATEGORY:</b>	23-Undefined Boiler Violations		
<b>SUBCATEGORY</b>	363. Undefined Boiler Violations.		
<b>CONDITION:</b>	363. Undefined Boiler Violations. Boiler is not operating for an external inspection.		
<b>REQUIREMENT:</b>	363. Undefined Boiler Violations. Place boiler into service and contact this Inspector to schedule an external inspection.		
<b>COMPANY:</b>	State of North Carolina		
<b>INSPECTOR:</b>	Johnson, Dean		
<b>OPENED:</b>	09/07/2021	<b>ENTERED BY:</b>	Johnson, Dean
<b>CLOSED:</b>		<b>CLOSED BY:</b>	
<b>TYPE:</b>	Certificate Blocking		
<b>CATEGORY:</b>	25-Operation of PRDs NCAC 13-13.0405		
<b>SUBCATEGORY</b>	391. Discharge piping not properly supported.		
<b>CONDITION:</b>	391. Operation of PRDs NCAC 13-13.0405: Safety valve discharge piping is not properly supported.		
<b>REQUIREMENT:</b>	391. Support the safety valve discharge piping so it may not impose excessive stress on the valve.		

**Location:** Carolina Casting

**Location #:** 1773449

**Violations:** 1

1416 Progress Ave, , High Point, NC 27260-8319, Phone: 336-885-1960

**Contact:** Carolina Casting Inc, Phone: 336-885-1960

**Object:** NC231027 - Boiler - Hurst - 1988 - Blr Rm - Active

**Violations This Object:** 1

<b>COMPANY:</b>	Hartford Steam Boiler		
<b>INSPECTOR:</b>	Leonard, Shannon D.		
<b>OPENED:</b>	09/22/2021	<b>ENTERED BY:</b>	Judd, Janie
<b>CLOSED:</b>		<b>CLOSED BY:</b>	
<b>TYPE:</b>	Certificate Blocking		
<b>CATEGORY:</b>	16-Boiler Components		
<b>SUBCATEGORY</b>	275. Tube/tube ends leak.		
<b>CONDITION:</b>	275. Boiler Components: Tube/tube ends leak.		
<b>REQUIREMENT:</b>	275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.		

**Location:** Century Furniture Upholstery Plt 2

**Location #:** 1775644

**Violations:** 1

535 27th St NW, , Hickory, NC 28601-4551, Phone: 336-328-1851

**Contact:** Attn Howard Martin, Manufacturing Engineer, Century Furniture Llc, Phone: 704-498-6880



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC045219 - Boiler - Cleaver Brooks - 1958 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Richey, Paul D.

**OPENED:** 09/20/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 16-Boiler Components

**SUBCATEGORY** 275. Tube/tube ends leak.

**CONDITION:** 275. Boiler Components: Tube/tube ends leak. The boiler appears to have a leaking tube at the lower left area of boiler adjacent to boiler.

**REQUIREMENT:** 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

---

**Location:** Covenant Presbyterian Church

**Location #:** 308846

**Violations:** 2

3627 Konnoak Dr, , Winston Salem, NC 27127-6037, Phone: 336-788-7511

**Contact:** Harry Wilson, Maintenance, Covenant Presbyterian Church, Phone: 336-788-7511

---

**Object:** NC394434 - Boiler - Crown - 2012 - Blr Rm - Active

**Violations This Object:** 2

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/07/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 07-Undefined Controls Violations

**SUBCATEGORY** 112. Undefined Controls Violations.

**CONDITION:** 112. Undefined Controls Violations: Low water cutoff (LWCO) drain valve leaking.

**REQUIREMENT:** 112. Undefined Controls Violations: Replace the LWCO drain in order to correct this condition.

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/07/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection LWCO and Pressure relief device (PRD) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the LWCO controls and PRD may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of the successful testing of these devices is also acceptable.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Location:** Dolly Madison Apartments **Location #:** 1783816 **Violations:** 1  
1013 N Elm St, , Greensboro, NC 27401-1443, Phone: 336-230-2054  
**Contact:** Tim Carroll, Dolly Madison Apartments HOA, Phone: 336-230-2054

**Object:** NC344817 - Boiler - Weil-McLain - 2002 - Bsmt - Active **Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Johnson, Dean  
**OPENED:** 08/17/2021 **ENTERED BY:** Johnson, Dean  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. This boiler must be operating to perform an external certificate inspection.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Contact your Insurer or this Inspector to schedule a boiler inspection.

---

**Location:** Electronic Data Magnetic Co **Location #:** 1786155 **Violations:** 2  
210 Old Thomasville Rd, , High Point, NC 27260-8187, Phone: 336-688-6147  
**Contact:** Attn Mike Birt, Electronic Data Magnetic Co, Phone: 336-882-8115, Cell:336-688-5821

**Object:** NC326114 - Boiler - Hurst - 2000 - Trailer - Active **Violations This Object:** 2

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Johnson, Dean  
**OPENED:** 09/08/2021 **ENTERED BY:** Johnson, Dean  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 03-Water Gauge Glass NCAC 13-13.0408  
**SUBCATEGORY** 056. Gauge glass not provided with a drain.  
**CONDITION:** 056. Water Gauge Glass NCAC 13-13.0408: Sight glass is not provided with a drain valve.  
**REQUIREMENT:** 056. Install a drain valve rated for 150 WSP and discharge pipe to the bottom most connection of the sight glass and extend the discharge pipe to a point where its discharge will not endanger personnel.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Johnson, Dean  
**OPENED:** 09/08/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. This boiler is past due for an internal certificate inspection.  
**REQUIREMENT:** 363. Undefined Boiler Violations. Contact your Insurer or this Inspector to schedule an internal certificate inspection.

---

**Location:** ESC Central Office Kendall Complex  
700 Wade Ave, , Raleigh, NC 27605-1154, Phone: 919-733-7310  
**Contact:** Attn Joe Katzburg, Director Support Services, NC Dept Of Commerce ESC Div, Phone: 919-733-7310

**Location #:** 1786586 **Violations:** 1

**Object:** NC266398 - Boiler - Kewanee - 1993 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 08/13/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 16-Boiler Components  
**SUBCATEGORY** 275. Tube/tube ends leak.  
**CONDITION:** 275. Boiler Components: Tube/tube ends leak.  
**REQUIREMENT:** 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

---

**Location:** Fairmont United Methodist Church  
2501 Clark Ave, , Raleigh, NC 27607-7213, Phone: 919-832-3316  
**Contact:** There is no contact information available for this location.

**Location #:** 1787578 **Violations:** 2

**Object:** NC079780 - Boiler - American Standard - 1960 - Wesley Hart Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 07/26/2021  
**CLOSED:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 26-Undefined Pressure Relieving Devices Violations  
**SUBCATEGORY** 399. Undefined Pressure Relieving Devices Violations.  
**CONDITION:** 399. Boiler not operating Unable to test PRD  
**REQUIREMENT:** 399. Operate Boiler

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC415550 - Boiler - Weil-McLain - 2017 - Lower Level Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 07/26/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 26-Undefined Pressure Relieving Devices Violations  
**SUBCATEGORY** 399. Undefined Pressure Relieving Devices Violations.  
**CONDITION:** 399. Boiler not operating Unable to test PRD  
**REQUIREMENT:** 399. Operate Boiler

---

---

**Location:** Fast Lane Auto Care **Location #:** 1934271 **Violations:** 1  
130 Uzzle Industrial Dr, , Clayton, NC 27520-6041, Phone: 919-934-9211  
**Contact:** Attn Ronnie Green, Owner, Fast Lane Auto Care, Phone: 919-934-9211

---

**Object:** NC380410 - PV - Manchester - 2004 - Shed Rear - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 08/03/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 09-Pressure Gauges NCAC 13-13.0407  
**SUBCATEGORY** 032. Incorrect range or insufficient pointer travel.  
**CONDITION:** 032. Pressure Gauges NCAC 13-13.0407: Incorrect range or insufficient pointer travel.  
**REQUIREMENT:** 032. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

---

---

**Location:** First Baptist Church **Location #:** 1788765 **Violations:** 3  
99 N Salisbury St, , Raleigh, NC 27603-1737, Phone: 919-832-4485  
**Contact:** Attn: Wayne Hagger, Admin, First Baptist Church, , Cell:918-279-5731

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

**Object:** NC328077 - PV - Carrier - 1999 - Education Bldg Bsmt Chiller Rm - **Violations This Object:** 1  
Active

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 10/13/2021 **ENTERED BY:** Fish, Emily  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 04-Installation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 460. Seals broken/ missing.  
**CONDITION:** 460. Installation of PRDs NCAC 13-13.0405: Seals broken/ missing.  
**REQUIREMENT:** 460. Replace the relief valve with one with an ASME/NB certified valve.

**Object:** NC405972 - Boiler - Peerless - 2016 - Bsmt Mech Rm Below **Violations This Object:** 2  
Sanctuary Bldg - Active

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 10/13/2021 **ENTERED BY:** Fish, Emily  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 006. Low water cutoff device inoperative or bypassed.  
**CONDITION:** 006. LWCO and Flow Sensing Devices NCAC 13-13.0409: Low water cutoff device inoperative or bypassed.  
**REQUIREMENT:** 006. Repair or replace the inoperable low water fuel cutoff control and test to ensure proper operation.

**COMPANY:** State of North Carolina  
**INSPECTOR:** Fish, Emily  
**OPENED:** 10/13/2021 **ENTERED BY:** Fish, Emily  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 02-Pressure Gauges NCAC 13-13.0407  
**SUBCATEGORY** 033. Inoperative.  
**CONDITION:** 033. Pressure Gauges NCAC 13-13.0407: Inoperative.  
**REQUIREMENT:** 033. Install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper range in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

**Location:** Harris Regional Hospital **Location #:** 1795916 **Violations:** 1  
68 Hospital Rd, , Sylva, NC 28779-2722, Phone: 828-586-7000  
**Contact:** Attn Mark Huston, Maintenance Supervisor, Harris Regional Hospital, , Cell:828-768-2837

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC046098 - Boiler - Kewanee - 1958 - West Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Possidente, James  
**OPENED:** 09/16/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 16-Boiler Components  
**SUBCATEGORY** 275. Tube/tube ends leak.  
**CONDITION:** 275. Boiler Components: Tube/tube ends leak.  
**REQUIREMENT:** 275. Repair the leaking tubes/tube ends. If weld repairs are required, a qualified "R" certificate holder is necessary to perform the work.

---

**Location:** Haywood Regional Medical Center **Location #:** 1796249 **Violations:** 1  
262 Leroy George Dr, , Clyde, NC 28721-7430, Phone: 828-456-7311  
**Contact:** Jeremy Brown, Mgr Engineering, Haywood Regional Medical Center, Phone: 828-452-8033, Cell:828-768-

---

**Object:** NC387671 - PV - Thrush - 2011 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Possidente, James  
**OPENED:** 10/06/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 07-Undefined Pressure Vessels Violations  
**SUBCATEGORY** 479. Undefined Pressure Vessels Violations.  
**CONDITION:** 479. Undefined Pressure Vessels Violations. Vessel is not in use. Pressurized and empty.  
**REQUIREMENT:** 479. Undefined Pressure Vessels Violations. Pressurize vessel and return to service for inspection.

---

**Location:** Hazelwood Baptist Church **Location #:** 1796278 **Violations:** 1  
265 Hazelwood Ave, , Waynesville, NC 28786-1944, Phone: 828-456-9434  
**Contact:** Allen Mathis, Caretaker, Hazelwood Baptist Church, Phone: 828-456-9434

---

**Object:** NC239755 - Boiler - Weil-McLain - 1988 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Possidente, James  
**OPENED:** 06/28/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 12-Casing, Stack Breeching and Flue  
**SUBCATEGORY** 211. Combustion gas leaks.  
**CONDITION:** 211. Casing, Stack Breeching and Flue: Combustion gas leaks. Combustion gas leaks between sections.  
**REQUIREMENT:** 211. Repair all combustion gas leaks in the casing, stack breeching, or flue.

---

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Location:** Kernersville Family YMCA **Location #:** 1845634 **Violations:** 1  
1113 W Mountain St, , Kernersville, NC 27284-2125, Phone: 336-996-2231

**Contact:** There is no contact information available for this location.

**Object:** NC418867 - Boiler - Teledyne Laars - 1998 - Hot Tub Wtr Htr - **Violations This Object:** 1  
Active

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 10/14/2020 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the flow switch and PRD is also acceptable.

---

**Location:** La Quinta Inn & Suites **Location #:** 1804611 **Violations:** 1  
1001 Hospitality Ct, , Morrisville, NC 27560-8401, Phone: 919-461-1771

**Contact:** There is no contact information available for this location.

**Object:** NEW - Boiler - RHEEM - 2021 - LAUNDRY - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 10/04/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 396. Missing nameplate.  
**CONDITION:** 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.  
**REQUIREMENT:** 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

---

**Location:** Lakewood YMCA **Location #:** 1845618 **Violations:** 2  
2119 Chapel Hill Rd, , Durham, NC 27707-1405, Phone: 919-401-9622

**Contact:** Jeff Jackson, Maintenance, Lakewood YMCA, Phone: 919-308-7083



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC395436 - Boiler - TDC Mfg - 2011 - Mens Locker Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 08/18/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 395. Valve leaking.  
**CONDITION:** 395. Operation of PRDs NCAC 13-13.0405: Valve leaking.  
**REQUIREMENT:** 395. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

---

**Object:** NC395437 - Boiler - TDC Mfg - 2011 - Mens Locker Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 08/18/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 03-Water Gauge Glass NCAC 13-13.0408  
**SUBCATEGORY** 053. Glass broken.  
**CONDITION:** 053. Water Gauge Glass NCAC 13-13.0408: Glass broken.  
**REQUIREMENT:** 053. Replace the broken gauge glass with material designed for temperature and service.

---

**Location:** Machine Specialties **Location #:** 526138 **Violations:** 1  
6511 Franz Warner Pkwy, , Whitsett, NC 27377-9215, Phone: 336-603-1919  
**Contact:** Attn Hunter Bowne, Machine Specialties Inc, Phone: 336-603-1919, Cell:336-423-3976

---

**Object:** NC355926 - PV - Steel Fab - 2002 - Comp Rm - Active **Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Johnson, Dean  
**OPENED:** 10/14/2021 **ENTERED BY:** Johnson, Dean  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 04-Installation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 451. Inadequate relieving capacity.  
**CONDITION:** 451. Installation of PRDs NCAC 13-13.0405: Safety valve has inadequate relieving capacity.  
**REQUIREMENT:** 451. Install an ASME/NB stamped safety valve having a set pressure not exceeding 137 psi and a minimum relieving capacity of 1,013 scfm. Valve must have a test lever or pull ring.

---

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Location:** Marlowe Van Loan Corp **Location #:** 1223163 **Violations:** 1  
1224 W Ward Ave, , High Point, NC 27260-1534, Phone: 336-886-7126  
**Contact:** Attn Paul Tharp, Marlowe Van Loan Corp, Phone: 336-886-7126

**Object:** NC243228 - Boiler - Burnham - 1989 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 10/18/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 19-Waterside  
**SUBCATEGORY** 321. Corrosion on internal surfaces.  
**CONDITION:** 321. Waterside: Corrosion on internal surfaces: Corrosion on internal waterside surfaces. Significant oxygen corrosion on multiple tube surfaces.  
**REQUIREMENT:** 321. Repair corrosion damage by replacing affected tubes. If welding is required, a qualified "R" certificate holder in necessary to perform the work.

---

**Location:** Mars Hill Baptist Church **Location #:** 1808332 **Violations:** 1  
67 N Main St, , Mars Hill, NC 28754-9503, Phone: 828-689-2911  
**Contact:** Sharon Welsch, Secretary, Mars Hill Baptist Church, Phone: 828-689-2911

**Object:** NC262845 - Boiler - Burnham - 1993 - Bsmt Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Possidente, James  
**OPENED:** 09/15/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 01-LWCO and Flow Sensing Devices NCAC 13-13.0409  
**SUBCATEGORY** 002. Only one of two low water cutoff devices required installed.  
**CONDITION:** 002. LWCO and Flow Sensing Devices NCAC 13-13.0409: Only one of two low water cutoff devices required installed.  
**REQUIREMENT:** 002. Install a second low-water fuel cutoff device (LWCO) designed for the appropriate service (Steam or Hot Water) that is equipped with a manual reset. When the LWCO shuts off the fuel supply to the boiler in the event of a low water condition, the fuel supply must be restarted manually by an operator. Test to ensure proper operation.

---

**Location:** Mt Zion Missionary Baptist Church **Location #:** 1812556 **Violations:** 1  
47 Eagle St, , Asheville, NC 28801-3762, Phone: 828-252-0515  
**Contact:** Rosa Hearst, Office Manager, Mt Zion Missionary Baptist Church, Phone: 828-252-0515

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC284580 - Boiler - Weil-McLain - 1997 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Possidente, James

**OPENED:** 10/08/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler controls could not be tested due to weather. Too warm.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule an inspection when the boiler is in operation so that pressure relieving devices can be tested.

---

**Location:** National Guard Armory

**Location #:** 1813586

**Violations:** 2

130 Culbreth Ave, , Thomasville, NC 27360-2909, Phone: 336-472-7032

**Contact:** Attn Blane Boyd, Director of Facility Maintenance, Facilities Maintenance, Phone: 984-664-6094

---

**Object:** NC392929 - Boiler - Lochinvar - 2012 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/13/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC392930 - Boiler - Lochinvar - 2012 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/13/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; flow switch and pressure relief device (PRD) could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the flow switch and PRD may be tested to verify proper operation. As an alternative, a detailed boiler log or service report that includes documentation of the successful testing of the controls is also acceptable

---

**Location:** National Guard Armory

**Location #:** 1813514

**Violations:** 1

700 Charles St, , Monroe, NC 28112-5725, Phone: 704-283-5512

**Contact:** Attn Blane Boyd, Director of Facility Maintenance, Facilities Maintenance, Phone: 984-664-6094

---

**Object:** NC374095 - Boiler - Weil-McLain - 2008 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 09/13/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 05-Temperature Controls NCAC 13-13.0406

**SUBCATEGORY** 093. High limit temperature control inoperative.

**CONDITION:** 093. Temperature Controls NCAC 13-13.0406: High limit temperature control inoperative.

**REQUIREMENT:** 093. Repair or replace the inoperative high limit temperature control. Test to ensure proper operation.

---

**Location:** Paul J Rizzo Conference Center

**Location #:** 1817817

**Violations:** 1

150 Dubose Home Ln, , Chapel Hill, NC 27517-8944, Phone: 919-913-2098

**Contact:** There is no contact information available for this location.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC364029 - Boiler - Lochinvar - 2006 - Outside Dubose House - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Ollison, Jr., James C.  
**OPENED:** 06/11/2020 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 25-Operation of PRDs NCAC 13-13.0405  
**SUBCATEGORY** 396. Missing nameplate.  
**CONDITION:** 396. Operation of PRDs NCAC 13-13.0405: Missing nameplate.  
**REQUIREMENT:** 396. Replace the relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by the manufacturer. The replacement valve must be ASME/NB certified.

---

**Location:** Piper Automotive **Location #:** 1819767 **Violations:** 1  
1119 N West St, , Raleigh, NC 27603-1143, Phone: 919-828-3045  
**Contact:** Attn Dave Piper, Owner, Piper Automotive Inc, Phone: 919-838-3045

---

**Object:** NC396535 - PV - Melben - 1985 - Shop Under Stairs - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** SORRENTINO, SEAN  
**OPENED:** 07/27/2021 **ENTERED BY:** Keyes, Amanda  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 09-Pressure Gauges NCAC 13-13.0407  
**SUBCATEGORY** 037. Glass missing.  
**CONDITION:** 037. Pressure Gauges NCAC 13-13.0407: Glass missing.  
**REQUIREMENT:** 037. Replace glass or install a pressure gauge on the equipment that is visible to the operator from the floor or work platform. Gauge must be the proper size in accordance with NC Administrative Code, Title 13, Chapter 13, Section .0407.

---

**Location:** Poplar Cleaners **Location #:** 1820416 **Violations:** 1  
359 George W Liles Pkwy NW, , Concord, NC 28027-6532, Phone: 704-794-6218  
**Contact:** There is no contact information available for this location.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC348346 - Boiler - Fulton - 2003 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Clay, Steven D.

**OPENED:** 10/02/2021

**ENTERED BY:** Putek, Terry

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 24-Installation of PRDs NCAC 13-13.0405

**SUBCATEGORY** 379. Discharge piping too small.

**CONDITION:** 379. Installation of PRDs NCAC 13-13.0405: Discharge piping too small. Reducer installed in PRD discharge line. Owner to remove.

**REQUIREMENT:** 379. Repipe the discharge line full size to a safe point of discharge.

---

**Location:** Professional Bldg

**Location #:** 1821273

**Violations:** 1

230 Gilmer St, , Reidsville, NC 27320-3853, Phone: 336-349-4372

**Contact:** J Michael Fargis & Associates Llp, Phone: 336-349-4372

---

**Object:** NC057137 - Boiler - Kewanee - 1960 - Blr Rm - Active

**Violations This Object:** 1

**COMPANY:** Hartford Steam Boiler

**INSPECTOR:** Leonard, Shannon D.

**OPENED:** 09/21/2021

**ENTERED BY:** Judd, Janie

**CLOSED:**

**CLOSED BY:**

**TYPE:** Certificate Blocking

**CATEGORY:** 23-Undefined Boiler Violations

**SUBCATEGORY** 363. Undefined Boiler Violations.

**CONDITION:** 363. Undefined Boiler Violations. Boiler not operating at time of inspection; safety devices could not be tested to verify proper operation.

**REQUIREMENT:** 363. Undefined Boiler Violations. Schedule a reinspection at a time when the boiler is operating so that the safety devices may be tested to verify proper operation. As an alternative, a detailed service report or boiler log that includes documentation of the successful testing of the controls is also acceptable

---

**Location:** Russell Realty

**Location #:** 1766584

**Violations:** 1

50 Salem St, , Thomasville, NC 27360-3937, Phone: 336-476-3999

**Contact:** There is no contact information available for this location.

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC156014 - Boiler - Slant Fin - 1976 - Bsmt Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 09/17/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations: Boiler not operating at time of inspection safety devices could not be tested to verify proper operation.  
**REQUIREMENT:** 363. Undefined Boiler Violations: Schedule a reinspection at a time when the boiler is operating so that the safety devices may be tested to verify proper operation. As an alternative, a detailed service report of boiler log that includes documentation of the successful testing of these devices is also acceptable.

---

**Location:** Smile Cleaners **Location #:** 1829630 **Violations:** 1  
9518 Northeast Pkwy, , Matthews, NC 28105-3741, Phone: 704-708-8788  
**Contact:** Attn Soon Jang, Owner, Smile Cleaners, Phone: 704-708-8788

---

**Object:** NC404156 - Boiler - Fulton - 2015 - Blr Rm - Active **Violations This Object:** 1

---

**COMPANY:** State of North Carolina  
**INSPECTOR:** Smith, Jeremy  
**OPENED:** 07/01/2021 **ENTERED BY:** Smith, Jeremy  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations. All high-pressure boilers require an external inspection every year. Contrary to 13 NCAC 13.0211(b), an external inspection has not been completed on an annual basis. The last external inspection completed was 12/11/2019.  
**REQUIREMENT:** 363. Undefined Boiler Violations. An External Non-certificate inspection shall be completed. Contact your inspector or the Boiler Safety Bureau at 919-707-7918 to schedule an external inspection.

---

**Location:** Snider Tire **Location #:** 595705 **Violations:** 1  
200 E Meadowview Rd, , Greensboro, NC 27406-4521, Phone: 336-691-5480  
**Contact:** Attn Glen Blackburn, Retread Manager, Snider Tire Inc, Phone: 336-691-5480 X133, Cell:336-669-7352



# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status: Active; Order Results by: Location Name; Then Order by: Address;

---

**Object:** NC384478 - Boiler - Parker - 2009 - Production Area - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Leonard, Shannon D.  
**OPENED:** 10/08/2021 **ENTERED BY:** Judd, Janie  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 23-Undefined Boiler Violations  
**SUBCATEGORY** 363. Undefined Boiler Violations.  
**CONDITION:** 363. Undefined Boiler Violations: Feed water tank has multiple leaks.  
**REQUIREMENT:** 363. Undefined Boiler Violations: Identify and repair all leaks. If welded repairs are required these must be performed by a qualified "R" certificate holder.

---

**Location:** Top Tobacco **Location #:** 1836886 **Violations:** 2  
204 Top Tobacco Rd, , Lake Waccamaw, NC 28450-2220, Phone: 910-646-3014  
**Contact:** Attn Richard Hopkins, Plant Engineer, Top Tobacco, Phone: 910-646-3014 X4125

---

**Object:** NC373543 - PV - Wolfe Mech - 2008 - NE Side - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Clay, Steven D.  
**OPENED:** 08/25/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 06-Undefined Pressure Relieving Devices Violations  
**SUBCATEGORY** 478. Undefined Pressure Relieving Devices Violations.  
**CONDITION:** 478. Undefined Pressure Relieving Devices Violations. Lock wire broken. PRD needs to be recertified.  
**REQUIREMENT:** 478. Undefined Pressure Relieving Devices Violations. Repair PRD or replace relief device with one set at a pressure not exceeding the maximum allowed working pressure determined by manufacturer. Replacement valve must be ASME/NB certified.

---

**Object:** NC373566 - PV - W H Capper - 2007 - Skid 1 - Active **Violations This Object:** 1

---

**COMPANY:** Hartford Steam Boiler  
**INSPECTOR:** Clay, Steven D.  
**OPENED:** 08/25/2021 **ENTERED BY:** Putek, Terry  
**CLOSED:** **CLOSED BY:**  
**TYPE:** Certificate Blocking  
**CATEGORY:** 06-Undefined Pressure Relieving Devices Violations  
**SUBCATEGORY** 478. Undefined Pressure Relieving Devices Violations.  
**CONDITION:** 478. Undefined Pressure Relieving Devices Violations. Lockwire is not sealed properly.  
**REQUIREMENT:** 478. Undefined Pressure Relieving Devices Violations. Have a VR shop recertify and reseat this PRD in accordance with requirements of NBIC.

---

# Violation Detail

Search Criteria: NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Location #: ;Schedule Type: My Company - External  
Cert~My Company - Internal Cert~My Company - Recurring Cert; Violation Status: Open; Ins Co: Hartford Steam Boiler; Status:  
Active; Order Results by: Location Name; Then Order by: Address;

---

**Violations This Report:** 90

**Locations This Report:** 64